

DEPARTMENT OF ENVIRONMENTAL QUALITY  
AIR QUALITY DIVISION

**FCE Summary Report**

Facility : Diesel Plant	SRN : N6524
Location : 518 S. Harbor Dr.	District : Grand Rapids
	County : OTTAWA
City : GRAND HAVEN State: MI Zip Code : 49417	Compliance Status : Compliance
Source Class : SM OPT OUT	Staff : Steve Lachance
FCE Begin Date : 7/20/2014	FCE Completion Date : 7/20/2015
Comments : FCE for FY '015. On-site activities 7/20/15. (SLachance, 7/20./15)	

**List of Partial Compliance Evaluations :**

Activity Date	Activity Type	Compliance Status	Comments
07/20/2015	Scheduled Inspection	Compliance	FCE for FY '015. <i>see CA- N6524/015</i>
03/18/2015	MAERS	Compliance	Audited on 3/18/15. See notes in e-MAERS Audit Console. (SLachance, 3/18/15)
08/26/2014	Scheduled Inspection	Compliance	Scheduled Inspection for FY '014
08/26/2014	Stack Test	Compliance	CO emissions/reduction test report for Engine No. 1. Indicates about 98% reduction and about 4 ppmc CO. Only Unit 1 is fitted with catalytic control per Engine MACT. Area Source MACT. (SLachance, 8/26/14)

*see CA- N6524/015*  
*SL*

Name: *Steve Lachance* Date: *7/20/15* Supervisor: *[Signature]*