

FINAL REPORT



DEARBORN INDUSTRIAL GENERATION

DEARBORN, MICHIGAN

2023 RELATIVE ACCURACY TESTING AUDIT (RATA)
SOURCE TESTING REPORT PART 75:
EUBOILERS 1, 2, & 3 AND EUCTG TURBINES 1, 2, & 3

RWDI #2400110

February 1, 2024

SUBMITTED TO

April Wendling
District Supervisor | Air Quality Division
Wendinga@michigan.gov

**Michigan Department of Environment, Great
Lakes and Energy (EGLE)**
27700 Donald Court
Warren, Michigan 48092-2793

Jeremy Howe
Dept. of Environmental Quality | ADQ
Howej1@michigan.gov

**Michigan Department of Environment, Great
Lakes and Energy (EGLE)**
Constitution Hall | 3 North
525 West Allegan
Lansing, Michigan 48909-7760

Dearborn Industrial Generation
Kathryn Cunningham
Corporate Environmental
Kathryn.cunningham@cmsenergy.com

SUBMITTED BY

Brad Bergeron, A.Sc.T., d.E.T.
Technical Director | Principal
Brad.Bergeron@rwdi.com | ext. 2428

Mason Sakshaug, QSTI
Supervisor, USA Field Operations | Associate
Principal
Mason.Sakshaug@rwdi.com

Steve Smith, QSTI
Project Manager | Associate
Steve.Smith@rwdi.com

Ben Durham
Senior Field Technician
Ben.Durham@rwdi.com

RWDI USA LLC
Consulting Engineers & Scientists
2239 Star Court
Rochester Hills, Michigan 48309

T: 248.841.8442
F: 519.823.1316



rwdi.com

©2024 RWDI USA LLC ("RWDI") ALL RIGHTS RESERVED.

This document is intended for the sole use of the party to whom it is addressed and may contain information that is privileged and/or confidential. If you have received this in error, please notify us immediately. Accessible document formats provided upon request.

® RWDI name and logo are registered trademarks in Canada and the United States of America.

116631 - TEST - 2023 1206



EXECUTIVE SUMMARY

RWDI USA LLC (RWDI) was retained by Dearborn Industrial Generation (DIG) to complete the Relative Accuracy Testing Audit (RATA) emission sampling program at their facility located at 2400 Miller Road, Dearborn, Michigan. The test program was conducted to fulfill the requirements of the Michigan Department of Environment, Great Lakes and Energy (EGLE) Renewable Operating Permit (ROP) # MI-ROP-N6631-2012a to demonstrate compliance with 40 CFR 75, Appendices A and B. The testing program included EUBOILER1, 2 & 3 (noted as Boiler 1100 (EUBOILER1) Boiler 2100 (EUBOILER 2) and Boiler 3100 (EUBOILER3) and EUCTG TURBINE 1, 2 & 3 (noted as Turbine 1100 (EUCTG TURBINE1), Turbine 2100 (EUCTG TURBINE2) and Turbine 3100 (EUCTG TURBINE3).

The following parameters were measured/calculated in the source testing program:

Boiler 1100, Boiler 2100 and Boiler 3100 in accordance with Performance Specification 2 (PS-2) and 16 (PS-16):

- Oxides of Nitrogen (NOx) (ppmvd and lb/MMBTU)
- Oxygen (O₂) (% dry)

Turbine 1100, Turbine 2100 and Turbine 3100 in accordance with Performance Specification 2 (PS-2) and 16 (PS-16):

- Oxides of Nitrogen (NOx) (ppmvd and lb/MMBTU)
- Oxygen (O₂) (% dry)

As per Section 9.4 of Performance Specification 16, the annual RATA was completed under normal operating conditions.

Executive Table i: Results Summary - Boiler2 1100, 2100 & 3100

Parameter	Boiler 1100 Relative Accuracy (RA)	Boiler 2100 Relative Accuracy (RA)	Boiler 3100 Relative Accuracy (RA)	Rata Requirement	
				Annual	Semi-Annual
Oxygen Concentration (RA)	1.3%	3.6%	3.3%	10%	7.5%
Nitrogen Oxide Emission Rate (absolute difference Idl)	0.000002 lb/MMBTU	0.0006 lb/MMBTU	0.0008 lb/MMBTU	0.020 lb/MMBTU	0.15 lb/MMBTU
Nitrogen Oxide Emission Rate (RA)	6.1%	5.6%	6.7%	10%	7.5%
Total Number of Runs	12	12	12	--	--
Number of Runs Used in RA	9	9	9	Minimum of 9	
BF Gas Flow (kscf/hr)	3,636.2	3,663.1	3,244.3	--	--
Nat. Gas Flow (kscf/hr)	30.59	32.64	32.90	--	--



Executive Table ii: Results Summary – Turbine 1100, 2100 & 3100

Parameter	Turbine 1100 Relative Accuracy (RA)	Turbine 2100 Relative Accuracy (RA)	Turbine 3100 Relative Accuracy (RA)	Rata Requirement	
				Annual	Semi-Annual
Oxygen Concentration (RA)	2.3%	1.6%	3.4%	10%	7.5%
Nitrogen Oxide Emission Rate (absolute difference d)	0.00019 lb/MMBTU	0.00071 lb/MMBTU	0.00015 lb/MMBTU	0.020 lb/MMBTU	0.15 lb/MMBTU
Nitrogen Oxide Emission Rate (RA)	4.1%	3.0%	1.3%	10%	7.5%
Total Number of Runs	12	12	12	--	--
Number of Runs Used in RA	9	9	9	Minimum of 9	
Power Generated (MW)	181.3	193.0	186.7	--	--



TABLE OF CONTENTS

1	INTRODUCTION	1
1.1	Location and Dates of Testing.....	1
1.2	Purpose of Testing.....	1
1.3	Personnel Involved in Testing.....	2
1.4	Qualified Source Testing Individual - Part 75.....	3
2	SOURCE DESCRIPTION	3
2.1	Boilers 1100, 2100 and 3100	4
2.2	Turbines 1100, 2100 and 3100	5
2.3	Operating Data.....	5
2.4	Applicable Permit Number	5
2.5	Description of Process and Emission Control Equipment.....	5
2.6	Process Flow Sheet or Diagram (if applicable).....	6
2.7	Type and Quantity of Raw and Finished Materials.....	6
2.8	Normal Rated Capacity of Process.....	6
2.9	Process Instrumentation Monitored During the Test	6
2.10	Predictive Emission Monitors Specifications	7
2.11	Reference Method Analyzers	7
3	SAMPLING AND ANALYTICAL PROCEDURES	8
3.1	Description of Sampling Train and Field Procedures	8
3.1.1	Summary of Specific Methodologies for Boiler 1100, 2100 and 3100	8
3.1.2	Summary of Specific Methodologies for Turbine 1100, 2100 and 3100.....	10
3.2	Description of Recovery and Analytical Procedures	12
3.3	Sampling Port Description	12
4	PERFORMANCE LIMITS	12
5	TEST RESULTS AND DISCUSSION	13
5.1	Detailed Results.....	13
5.2	Discussion of Results.....	14
5.3	Variations in Testing Procedures.....	14
5.4	Process Upset Conditions During Testing	14
5.5	Maintenance Performed in Last Three Months	14
5.6	Re-Test	14
5.7	Audit Samples	14
5.8	Field Data Sheets	14



5.9 Calibration Records14
5.10 Sample Calculations.....15
5.11 Laboratory Data15
5.12 Source Testing Plan15

LIST OF TABLES

(Found Within the Report)

Table 1.3.1: List of Testing Personnel.....2
Table 2.1.1: Summary of Sampling Program – Boilers 1100, 2100 & 3100.....4
Table 2.2.1: Summary of Sampling Program – Turbines 1100, 2100 & 3100.....5
Table 2.11.1: CEMS Analyzers.....7
Table 4.1: Part 75 RA Requirements – Boilers 1100, 2100 & 3100 and
Turbines 1100, 2100 & 3100.....11
Table 5.1.1: Results Summary – Boilers 1100, 2100 & 3100.....12
Table 5.1.2: Results Summary – Turbines 1100, 2100 & 3100.....12

LIST OF TABLES

(Found After the Report Text)

Table 1: Boiler 1100 – 2023 RATA Results
Table 2: Boiler 2100 – 2023 RATA Results
Table 3: Boiler 3100 - 2023 RATA Results
Table 4: Turbine 1100 – 2023 RATA Results
Table 5: Turbine 2100 - 2023 RATA Results
Table 6: Turbine 3100 - 2023 RATA Results

LIST OF FIGURES

Figure 1: USEPA Method 3A and 7E
Figure 2: Schematic of Traverse Locations Boilers 1100, 2100 & 3100
Figure 3: Schematic of Traverse Locations Turbine 1100
Figure 4: Schematic of Traverse Locations Turbines 2100 and 3100



LIST OF APPENDICES

Appendix A:	PEMs Data
Appendix A1:	Boiler 1100
Appendix A2:	Boiler 2100
Appendix A3:	Boiler 3100
Appendix A4:	Turbine 1100
Appendix A5:	Turbine 2100
Appendix A6:	Turbine 3100
Appendix B:	Reference Method CEMS Data
Appendix B1:	Boiler 1100
Appendix B2:	Boiler 2100
Appendix B3:	Boiler 3100
Appendix B4:	Turbine 1100
Appendix B5:	Turbine 2100
Appendix B6:	Turbine 3100
Appendix C:	Field Sheets
Appendix C1:	Boiler 1100
Appendix C2:	Boiler 2100
Appendix C3:	Boiler 3100
Appendix C4:	Turbine 1100
Appendix C5:	Turbine 2100
Appendix C6:	Turbine 3100
Appendix D:	Calibration Records
Appendix E:	Example Calculations
Appendix F:	EGLE Correspondence & Source Testing Plan
Appendix G:	QSTI Certification



1 INTRODUCTION

RWDI USA LLC (RWDI) was retained by Dearborn Industrial Generation (DIG) to complete the Relative Accuracy Testing Audit (RATA) emission sampling program at their facility located at 2400 Miller Road, Dearborn, Michigan. The test program was conducted to fulfill the requirements of the Michigan Department of Environment, Great Lakes and Energy (EGLE) Renewable Operating Permit (ROP) # MI-ROP-N6631-2012a and Permit to Install (PTI) 163-17 and 8-17 to demonstrate compliance with 40 CFR 75, Appendices A and B. The testing program included EUBOILER1, 2 & 3 (noted as Boiler 1100 (EUBOILER1) Boiler 2100 (EUBOILER 2) and Boiler 3100 (EUBOILER3) and EUCTG TURBINE 1, 2 & 3 (noted as Turbine 1100 (EUCTG TURBINE1), Turbine 2100 (EUCTG TURBINE2) and Turbine 3100 (EUCTG TURBINE3).

The following parameters were measured/calculated in the source testing program:

Boiler 1100, Boiler 2100 and Boiler 3100 in accordance with Performance Specification 2 (PS-2) and 16 (PS-16):

- Oxides of Nitrogen (NO_x) (ppmvd and lb/MMBTU)
- Oxygen (O₂) (% dry)

Turbine 1100, Turbine 2100 and Turbine 3100 in accordance with Performance Specification 2 (PS-2) and 16 (PS-16):

- Oxides of Nitrogen (NO_x) (ppmvd and lb/MMBTU)
- Oxygen (O₂) (% dry)

As per Section 9.4 of Performance Specification 16, the annual RATA was completed under normal operating conditions.

1.1 Location and Dates of Testing

The test program was completed December 5th-7th, 2023 at Dearborn Industrial Generation in Dearborn, MI.

1.2 Purpose of Testing

The testing was conducted to fulfill the requirements of Michigan Department of Environment, Great Lakes and Energy (EGLE) Renewable Operating Permit (ROP) # MI-ROP-N6631-2012a and Permit to Install (PTI) 163-17 and 8-17.



1.3 Personnel Involved in Testing

Table 1.3.1: Testing Personnel

Personnel (Title & Email)	Affiliation	Phone Number
Kathryn Cunningham Corporate Environmental Kathryn.Cunningham@cmsenergy.com	CMS Energy	(517) 375-3043
Ken Mroczkowski Sr. Environmental Compliance Coordinator Kenneth.Mroczkowski@cmsenergy.com		734-691-0795
Jonathan Lamb AQD District Office Lanbj1@michigan.gov	EGLE Detroit District Office Cadillac Place 3058 West Grand Blvd, Suite 2-300 Detroit, MI 48202	313-348-2527
Andrew Riley Technical Program Unit Rileya8@michigan.gov	EGLE Air Quality Division Technical Program Unit (TPU) Constitution Hall 2 nd Floor South 525 West Allegan Street Lansing, MI 48933	586-565-7379
Brad Bergeron Technical Director Brad.Bergeron@rwdi.com	RWDI USA LLC 2239 Star Court Rochester Hills, MI 48309	(248) 234-3885
Steve Smith Project Manager Steve.Smith@rwdi.com		(971) 940-5038
Mason Sakshaug Senior Scientist Mason.Sakshaug@rwdi.com		(989) 323-0355
Mike Nummer Senior Field Technician Michael.Nummer@rwdi.com		(586) 863-8237
Ben Durham Senior Field Technician Ben.Durham@rwdi.com		(734) 474-1731
Cade Smith Field Technician Cade.Smith@rwdi.com		(734) 552-7270
Hunter Griggs Field Technician Hunter.Griggs@rwdi.com		(810) 441-8351



1.4 Qualified Source Testing Individual – Part 75

Certification documentation regarding Part 75 requirements for Qualified Source Testing Individual for this project is provided in **Appendix G**.

2 SOURCE DESCRIPTION

Dearborn Industrial Generation (DIG) located at 2400 Miller Road in Dearborn, Michigan, operates three (3) natural gas fired or a mixture of Blast Furnace Gas (BFG) and natural gas (NG). The BFG to NG ratio is approximately 90% BFG and 10% NG. In addition, DIG operates two (2) combined-cycle turbines and one (1) simple-cycle turbine. The turbines are fired only with natural gas.

Each boiler is rated at an output capacity of 500,000 pounds per hour of superheated steam at a minimum pressure of 1,230 psig and a temperature of 960°F. The input capacity of the boilers while firing NG and BFG is 746 MMBTU/hr and 763 MMBTU/hr under natural gas only firing. The steam from the boilers is sent to the steam turbine for electrician generation and/or utilized as process steam. NOx from the boilers is controlled by low-NOx combustors.

The simple-cycle turbine is rated at an output capacity of 181 Megawatts (MW) and 1,638 Million British Thermal Units (MMBTU) heat input. The combined-cycle turbines are rated at an output capacity of 179 MW and 1,626 MMBTU heat input. The turbines consist of a compressor, combustion turbine, and generator. Energy is generated at the combustion turbine by drawing in ambient air by means if burning fuel and expanding the hot combustion gases in a three-stage turbine. The hot exhaust gases from the combined-cycle combustion turbines are directed to a multi-pressure heat recovery steam generator (HRSG) to produce steam. NOx is controlled by low NOx combustors. The CO and SO₂ are controlled by equipment combustion efficiencies and low-sulfur fuel.



2.1 Boilers 1100, 2100 and 3100

The sampling locations for Boilers 1100, 2100 and 3100 is through individual stacks.

Table 2.1.1: Summary of Sampling Program – Boilers 1100, 2100 and 3100

	Boiler 1100	Boiler 2100	Boiler 3100
Emission Unit Description [Including Process Equipment & Control Device(s)]	Each boiler is nominally rated at an output of 500,000 pounds of hour of superheated steam at a minimum pressure of 1350 psig at a temperature of 960°F. Heat input rating of each unit when firing on natural gas and blast furnace gas is 746 MMBTU/hr and 763 MMBTU/hr with natural gas only. Steam from boilers is delivered to steam turbine for electrical generation or process steam. All boilers are equipped with low-NOx combustors.		
Parameter Tested	O ₂ and NOx		
Stack Dimensions	126"	126"	126"
Traverse Points	3	3	3
Testing Monitoring Methods	Refer to Section 3.0		

The sampling ports for the RATA testing are located outside the building within the exhaust duct. During the RATA, DIG personnel operated each of the boilers to ensure they are operating at normal operating loads and that each boiler was utilizing at least 90% BFG on a volume basis.

For each 21-minute test, three (3) points were traversed as per Performance Specification 2 Section 8.1.3.2 located on a line at 0.4m 1.2m and 2.0m from the stack wall (16", 47" and 79" from stack wall) as noted in the Source Testing Plan.



2.2 Turbines 1100, 2100 and 3100

The sampling locations for Turbines 1100, 2100 and 3100 is through individual stacks.

Table 2.2.1: Summary of Sampling Program – Turbines 1100, 2100 and 3100

	Turbine 1100	Turbine 2100	Turbine 3100
Emission Unit Description [Including Process Equipment & Control Device(s)]	Simple-cycle turbine fired by natural gas, nominally rated at an output capacity of 181 Megawatts (MW) and 1,638 MMTU/hr heat input. Low-NOx combustors installed to minimize NOx emissions. CO and SO2 are minimized by the efficient combustion and low-sulfur fuel (natural gas)	Each Turbine is a combined-cycle turbine fired by natural gas. Each have a nominally rated at an output capacity of 179 Megawatts (MW) and 1,626 MMTU/hr heat input. Low-NOx combustors installed to minimize NOx emissions. CO and SO2 are minimized by the efficient combustion and low-sulfur fuel (natural gas)	
Parameter Tested	O ₂ and NO _x		
Stack Dimensions	19' x 22'	210"	210"
Traverse Points	3	3	3
Testing Monitoring Methods	Refer to Section 4.0		
Testing Schedule	Refer to Section 1.2		

The sampling ports for the RATA testing are located outside the building within the exhaust duct. During the RATA, DIG personnel operated each of the turbine to ensure they are operating within at least 90% of maximum load. For each 21-minute test, three (3) points were traversed as per Performance Specification 2 Section 8.1.3.2 located on a line at 0.4m 1.2m and 2.0m from the stack wall (16", 47" and 79" from stack wall) as noted in the Source Testing Plan.

2.3 Operating Data

Dearborn Industrial Generation personnel collected the process data and verified the unit was operating correctly and production was at acceptable capacity. The process data can be found in **Appendix A**.

2.4 Applicable Permit Number

MI-ROP-N6631-2012a and PTI 163-17 and 8-17.

2.5 Description of Process and Emission Control Equipment

All boilers and turbines are equipped with low-NOx combustors to minimize NOx emissions.



2.6 Process Flow Sheet or Diagram (if applicable)

Process flow diagram is available upon request.

2.7 Type and Quantity of Raw and Finished Materials

This a power generation facility.

2.8 Normal Rated Capacity of Process

Each boiler is nominally rated at an output of 500,000 pounds of hour of superheated steam at a minimum pressure of 1350 psig at a temperature of 960°F. Heat input rating of each unit when firing on natural gas and blast furnace gas is 746 MMBTU/hr and 763 MMBTU/hr with natural gas only.

Turbine 1100 is a simple-cycle turbine fired by natural gas, nominally rated at an output capacity of 181 Megawatts (MW) and 1,638 MMTU/hr heat input

Turbines 2100 and 3100 are combined-cycle turbines fired by natural gas. Each are nominally rated at an output capacity of 179 Megawatts (MW) and 1,626 MMTU/hr heat input.

2.9 Process Instrumentation Monitored During the Test

Plant personnel recorded the following process data:

Boilers 1100, 2100, and 3100

- Steam load rate (lb/hr)
- Natural gas usage
- Blast Furnace Gas (BFG) usage
- Site Specific F-Factor
- PEMS data

The DIG site monitors heat input to the boilers per ROP requirements. DIG also monitors steam load (klb/hr); however, does not have steam load by the minute increment within the data acquisition and handling system. Steam load is calculated on an hourly basis for EPA EDR reporting. While steam load is provided in the process data within this report, it should not be considered valid minute data. Blast Furnace Gas (BFG) and Natural Gas flow rate process data is provided for the stack test run times for the Boiler Units. Hourly steam load can be provided upon request.

Turbines 1100, 2100, and 3100

- Natural gas usage
- MW generation
- PEMS data



2.10 Predictive Emission Monitors Specifications

Boilers 1100, 2100 and 3100 and Turbine 1100, 2100 and 3100 are equipped with the CMC Solutions SmartCEMS®-75 PEMS. The SmartCEMS®-75 PEMS are PLC-based system which calculates pollutant emissions from sensors inputs using high-order polynomial equations. The process sensor inputs are read by the PLC via signals from the facility distributive control system (DCS). Sensor data is validated, and predicted gas concentrations for each sensor are calculated using relationships that are defined by calculating a weighted average of the individual predictions. The PEMS hardware is comprised of four (4) basic components: the PLC, a touch panel PC, a data historian, and report server.

The CMC Solutions SmartCEMS®-75 PEMS records data continuously and generates reports in compliance with 40 CFR Part 60 and Part 75 regulations. These reports can be operated on any workstation on the local area network and provide the operators information on compliance status of the boilers and turbines in real-time.

The CMC Solutions SmartCEMS®-75 PEMS at Dearborn Industrial have the following Serial Numbers:

Unit	Model	Serial Number
Boiler 1100	CMC Solutions SmartCEMS®-75	DIG.BL1100.256738
Boiler 2100	CMC Solutions SmartCEMS®-75	DIG.BL2100.256738
Boiler 3100	CMC Solutions SmartCEMS®-75	DIG.BL3100.256738
Turbine 1100	CMC Solutions SmartCEMS®-75	DIG.GT1100.97341
Turbine 2100	CMC Solutions SmartCEMS®-75	DIG.GT2100.52081
Turbine 3100	CMC Solutions SmartCEMS®-75	DIG.GT3100.52081

2.11 Reference Method Analyzers

The following outlines the Reference Method analyzers used on-site during the RATA testing.

Table 2.11.1: Reference Method (RM) CEMS Analyzers

Pollutant	Specifications		
	Manufacturer	Serial Number	Range
Nitrogen Oxide	Teledyne T200H	942	0-5,000 ppm
Nitrogen Oxide	Teledyne T200H	851	0-5,000 ppm
Oxygen	Teledyne T200H	851	0-100%
Oxygen	Servomex 4900 Multigas	200116	0-100%



3 SAMPLING AND ANALYTICAL PROCEDURES

3.1 Description of Sampling Train and Field Procedures

3.1.1 Summary of Specific Methodologies for Boiler 1100, 2100 and 3100

3.1.1.1 Relative Accuracy Testing Audit (RATA) O₂ and NO_x

To satisfy the NO_x PEMs data accuracy requirement, the relative accuracy result for a minimum of nine performance test runs must meet the criteria outlined in section 13.1 of the US EPA Performance Specification 16. A 21-minute period is used for each test run. To satisfy the O₂ PEMs data accuracy requirement, the relative accuracy result for a minimum of nine performance test runs must be less than or equal to 1.0% absolute O₂. As per Performance Specification 2 Section 8.1.3.2 the sampling points were located on a line at 0.4m 1.2m and 2.0m from the stack wall (16", 47" and 79" from stack wall). Each point was 7 minutes in duration for each RATA run.

Prior to the RATA, a NO₂-to-NO conversion efficiency check was performed. It must meet the criteria of $\geq 90\%$. Also prior to the RATA, an interference response test was performed on the analyzers used for this test program.

RWDI operated the reference method heated line at between 250 and 340°F to avoid any condensation. The RATA data for NO_x was calculated for measurements reported in ppmvd and lb/MMBTU for NO_x. O₂ was measured as %-dry.

Method Listing:

The following test methods are referenced for the test program. These methods can be found in 40 CFR, Part 60, Appendix A and B.

Method 3A: Determination of Oxygen and Carbon Dioxide Concentrations in Emissions from Stationary Sources.

Method 7E: Determination of Nitrogen Oxides Emissions from Stationary Sources.

Method 19: Determination of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur Dioxide and Nitrogen Oxide Emission Rates.

Performance Specification 2: Specifications and Test Procedures for SO₂ and NO_x Continuous Emissions Monitoring Systems in Stationary Sources

Performance Specification 16: Specifications and Test Procedures for Predictive Emission Monitoring Systems in Stationary Sources.



EPA Method 3A and 7E (O₂ and NO_x):

A three-point (zero, mid-, and high-range) analyzer calibration error check is conducted on each reference analyzer before initiating the relative accuracy testing. This check is conducted (after final calibration adjustments are made) by injecting the calibration gases directly into each gas analyzer and recording the responses.

Zero and upscale calibration checks are conducted both before and after each test run in order to quantify measurement system calibration drift and sampling system bias. Upscale is either the mid- or high-range gas, whichever most closely approximates the flue gas level. During these checks, the calibration gases are introduced into the sampling system at the probe outlet so that the calibration gases are analyzed in the same manner as the flue gas samples.

A gas sample is continuously extracted from the stack and delivered to a series of gas analyzers, which measure the pollutant or diluent concentrations in the gas. The analyzers are calibrated on-site using EPA Protocol No. 1 certified calibration mixtures. The probe tip is equipped with a sintered stainless-steel filter for particulate removal. The end of the probe is connected to a heated Teflon sample line, which delivers the sample gases from the stack to the CEM system. The heated sample line is designed to maintain the gas temperature above 250°F in order to prevent condensation of stack gas moisture within the line.

Before entering the analyzers, the gas sample passes directly into a refrigerated condenser, which cools the gas to approximately 35°F to remove the stack gas moisture. After passing through the condenser, the dry gas enters a Teflon-head diaphragm pump and a flow control panel, which delivers the gas in series to the O₂ and NO_x analyzers. Each of these analyzers measures the respective gas concentrations on a dry volumetric basis.

NO_x Emission Rate Calculation (US EPA Methods 19):

USEPA Method 19, "Determination of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur Dioxide and Nitrogen Oxide Emission Rates," was used to calculate a NO_x emission rates based on Oxygen concentrations and appropriate F-factors. Equation 19-1 from the method was used. Table 19-1 was used to determine the conversion factor for concentration (1.194x10⁻⁷ for NO_x). A site specific F-Factor was provided for the Boilers based on mixture of natural gas and blast furnace gas (BFG).

$$E = (1.194 \times 10^{-7}) \times C_d \times F_d \times ((20.9 / (20.9 - \%O_{2d}))) \text{ for NO}_x$$

Where:

- E = Pollutant Emission Rate (lb/10⁶ BTU)
- C_d = Pollutant Concentration, Dry Basis (ppm)
- F_d = Fuel Factor, Dry Basis (dscf/10⁶ BTU)
- %O_{2d} = Oxygen Concentration, Dry Basis (%)



3.1.2 Summary of Specific Methodologies for Turbine 1100, 2100 and 3100

3.1.2.1 Relative Accuracy Testing Audit (RATA) O₂ and NO_x

To satisfy the NO_x PEMs data accuracy requirement, the relative accuracy result for a minimum of nine performance test runs must meet the criteria outlined in section 13.1 of the US EPA Performance Specification 16. A 21-minute period was used for each test run. To satisfy the O₂ PEMs data accuracy requirement, the relative accuracy result for a minimum of nine performance test runs must be less than or equal to 1.0% absolute O₂. As per Performance Specification 2 Section 8.1.3.2 the sampling points were located on a line at 0.4m 1.2m and 2.0m from the stack wall (16", 47" and 79" from stack wall). Each point was 7 minutes in duration for each RATA run.

Prior to the RATA, a NO₂-to-NO conversion efficiency check was performed. It must meet the criteria of $\geq 90\%$. Also prior to the RATA, an interference response test was performed on the analyzers used for this test program.

RWDI operated our heated line at between 250 and 340°F to avoid any condensation. The RATA data for NO_x was calculated for measurements reported in ppmvd and lb/MMBTU. O₂ was measured as %-dry.

Method Listing:

The following test methods are referenced for the test program. These methods can be found in 40 CFR, Part 60, Appendix A and B.

Method 3A: Determination of Oxygen and Carbon Dioxide Concentrations in Emissions from Stationary Sources.

Method 7E: Determination of Nitrogen Oxides Emissions from Stationary Sources.

Method 19: Determination of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur Dioxide and Nitrogen Oxide Emission Rates.

Performance Specification 2: Specifications and Test Procedures for SO₂ and NO_x Continuous Emissions Monitoring Systems in Stationary Sources

Performance Specification 16: Specifications and Test Procedures for Predictive Emission Monitoring Systems in Stationary Sources.



EPA Method 3A and 7E (O₂ and NO_x):

A three-point (zero, mid-, and high-range) analyzer calibration error check is conducted on each reference analyzer before initiating the relative accuracy testing. This check is conducted (after final calibration adjustments are made) by injecting the calibration gases directly into each gas analyzer and recording the responses.

Zero and upscale calibration checks are conducted both before and after each test run in order to quantify measurement system calibration drift and sampling system bias. Upscale is either the mid- or high-range gas, whichever most closely approximates the flue gas level. During these checks, the calibration gases are introduced into the sampling system at the probe outlet so that the calibration gases are analyzed in the same manner as the flue gas samples.

A gas sample is continuously extracted from the stack and delivered to a series of gas analyzers, which measure the pollutant or diluent concentrations in the gas. The analyzers are calibrated on-site using EPA Protocol No. 1 certified calibration mixtures. The probe tip is equipped with a sintered stainless-steel filter for particulate removal. The end of the probe is connected to a heated Teflon sample line, which delivers the sample gases from the stack to the CEM system. The heated sample line is designed to maintain the gas temperature above 250°F in order to prevent condensation of stack gas moisture within the line.

Before entering the analyzers, the gas sample passes directly into a refrigerated condenser, which cools the gas to approximately 35°F to remove the stack gas moisture. After passing through the condenser, the dry gas enters a Teflon-head diaphragm pump and a flow control panel, which delivers the gas in series to the O₂ and NO_x analyzers. Each of these analyzers measures the respective gas concentrations on a dry volumetric basis.

NO_x Emission Rate Calculation (US EPA Methods 19):

USEPA Method 19, "Determination of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur Dioxide and Nitrogen Oxide Emission Rates," was used to calculate a NO_x emission factor based on Oxygen concentrations and appropriate F-factors. Equation 19-1 from the method was used. Table 19-1 was used to determine the conversion factor for concentration (1.194x10⁻⁷ for NO_x). Table 19-2 was used for the F-Factor (natural gas 8,710 dscf/10⁶ BTU).

$$E = (1.194 \times 10^{-7}) \times C_d \times F_d \times ((20.9 / (20.9 - \%O_{2d})) \text{ for NO}_x$$

Where:

- E = Pollutant Emission Rate (lb/10⁶ BTU)
- C_d = Pollutant Concentration, Dry Basis (ppm)
- F_d = Fuel Factor, Dry Basis (dscf/10⁶ BTU)
- %O_{2d} = Oxygen Concentration, Dry Basis (%)



3.2 Description of Recovery and Analytical Procedures

There were no samples to recover during this test program. All testing used real time data from the analyzers.

3.3 Sampling Port Description

Stack figures can be found in the **Figures Tab**.

4 PERFORMANCE LIMITS

The applicable emission limits are outlined below.

Table 4.1: Part 75 RA Requirements – Boilers 1100, 2100 & 3100 and Turbines 1100, 2100 & 3100

Source	Parameter	Semi-Annual RATA Requirement	Annual RATA Requirement
Boiler 1100 Boiler 2100 Boiler 3100	O ₂	10% RA	7.5% RA
	NO _x	10% RA ± 0.020 lb/MMBTU	7.5% RA ± 0.015 lb/MMBTU
Turbine 1100 Turbine 2100 Turbine 3100	O ₂	10% RA	7.5% RA
	NO _x	10% RA ± 0.020 lb/MMBTU	7.5% RA ± 0.015 lb/MMBTU



5 TEST RESULTS AND DISCUSSION

5.1 Detailed Results

Table 5.1.1: Results Summary - Boilers 1100, 2100 & 3100

Parameter	Boiler 1100 Relative Accuracy (RA)	Boiler 2100 Relative Accuracy (RA)	Boiler 3100 Relative Accuracy (RA)	Rata Requirement	
				Annual	Semi-Annual
Oxygen Concentration (RA)	1.3%	3.6%	3.3%	10%	7.5%
Nitrogen Oxide Emission Rate (absolute difference Idl)	0.000002 lb/MMBTU	0.0006 lb/MMBTU	0.0008 lb/MMBTU	0.020 lb/MMBTU	0.15 lb/MMBTU
Nitrogen Oxide Emission Rate (RA)	6.1%	5.6%	6.7%	10%	7.5%
Total Number of Runs	12	12	12	--	--
Number of Runs Used in RA	9	9	9	Minimum of 9	
BF Gas Flow (kscf/hr)	3,636.2	3,663.1	3,244.3	--	--
Nat. Gas Flow (kscf/hr)	30.59	32.64	32.90	--	--

Table ii: Results Summary - Turbines 1100, 2100 & 3100

Parameter	Turbine 1100 Relative Accuracy (RA)	Turbine 2100 Relative Accuracy (RA)	Turbine 3100 Relative Accuracy (RA)	Rata Requirement	
				Annual	Semi-Annual
Oxygen Concentration (RA)	2.3%	1.6%	3.4%	10%	7.5%
Nitrogen Oxide Emission Rate (absolute difference Idl)	0.00019 lb/MMBTU	0.00071 lb/MMBTU	0.00015 lb/MMBTU	0.020 lb/MMBTU	0.15 lb/MMBTU
Nitrogen Oxide Emission Rate (RA)	4.1%	3.0%	1.3%	10%	7.5%
Total Number of Runs	12	12	12	--	--
Number of Runs Used in RA	9	9	9	Minimum of 9	
Power Generated (MW)	181.3	193.0	186.7	--	--



5.2 Discussion of Results

Based on the results of the RATA, all analytes were determined to be within acceptable Relative Accuracy (RA) tolerances as per USEPA Performance Specification 2 and 16.

The CEMS spreadsheets can be found in **Appendix B**.

5.3 Variations in Testing Procedures

No variations.

5.4 Process Upset Conditions During Testing

There were normal process breaks during production.

5.5 Maintenance Performed in Last Three Months

Only routine maintenance has been performed.

5.6 Re-Test

This was not a retest.

5.7 Audit Samples

This test did not require any audit samples.

5.8 Field Data Sheets

Field data sheets can be found in **Appendix C**.

5.9 Calibration Records

Calibration records can be found in **Appendix D**.



5.10 Sample Calculations

Sample calculations can be found in **Appendix E**.

5.11 Laboratory Data

There was no laboratory data from this testing program.

5.12 Source Testing Plan

Source testing plan and EGLE correspondence can be found in **Appendix F**.

TABLES




Table 1 - Boiler 1100 - 2023 RATA Results - Part 75

Date: Thursday, December 07, 2023

Test	RWDI Time		NOx				NOx Emission Rate			O ₂				BF Gas Flow (kscf/hr)	Nat. Gas Flow (kscf/hr)
	Start Time	End Time	RM (dppm)	RM cor	PEMS (ppm)	di (ppm)	RM (lb/MMBTU)	PEMS (lb/MMBTU)	di (lb/min)	RM (d%)	RM (cor%)	PEMS (%)	di (%)		
1	7:12	7:32	10.93	10.68	11.56	-0.88	0.0217	0.0230	-0.0013	3.80	3.81	3.71	0.11	3,734.1	30.59
2	7:45	8:05	10.95	10.72	11.69	-0.97	0.0218	0.0240	-0.0022	3.78	3.83	3.67	0.16	3,767.6	30.57
3	8:21	8:41	12.02	11.80	10.69	1.11	0.0243	0.0220	0.0023	3.99	4.04	3.75	0.30	3,662.1	30.58
4	8:56	9:16	13.95	13.86	10.85	3.00	0.0282	0.0220	0.0062	3.75	3.80	3.72	0.07	3,683.6	30.59
5	9:33	9:53	13.34	13.24	10.59	2.64	0.0268	0.0240	0.0028	3.71	3.76	3.76	0.00	3,630.4	30.60
6	10:06	10:26	12.62	12.33	10.71	1.63	0.0250	0.0220	0.0030	3.71	3.76	3.76	-0.01	3,622.3	30.61
7	10:40	11:00	11.00	10.52	10.33	0.19	0.0214	0.0210	0.0004	3.77	3.82	3.86	-0.04	3,487.5	30.61
8	11:11	11:31	10.73	10.21	11.08	-0.87	0.0208	0.0220	-0.0012	3.76	3.81	3.77	0.05	3,624.1	30.60
9	11:42	12:02	11.10	10.59	11.31	-0.72	0.0214	0.0230	-0.0016	3.65	3.70	3.73	-0.03	3,593.5	30.58
10	12:18	12:38	11.58	11.01	11.44	-0.42	0.0222	0.0230	-0.0008	3.61	3.65	3.72	-0.07	3,704.7	30.57
11	12:51	13:11	12.01	11.42	10.48	0.95	0.0232	0.0210	0.0022	3.73	3.77	3.85	-0.07	3,519.4	30.59
12	13:34	13:54	12.46	11.93	10.89	1.05	0.0243	0.0220	0.0023	3.78	3.82	3.80	0.01	3,604.9	30.58
AVERAGE			--	10.99	11.05	-0.06	0.022	0.022	-0.000002	--	3.76	3.77	-0.010	3,636.2	30.59
STDS			--	0.60	0.49	0.89	0.001	0.001	0.002	--	0.057	0.052	0.049	--	--
n			9				9			9					
Full Scale			102.3				-			21.13					
t_{0.975}			2.306				2.262			2.306					
 d 			0.06				0.000002			0.01					
lcc 			0.69				0.0014			0.04					
Bias present? (d > lcc)			no bias				no bias			no bias					
Bias Factor			0.99				1.00			1.00					
Relative Accuracy (20% limit)			6.8%				6.1%			1.3%					
RATA = RA 7.5% for NOx and O2			6.8% = Pass				6.1% = Pass			1.27% = Pass					
RATA = <0.015 lb/MMBTU for NOx ER			--				0.000002 lb/MMBTU = Pass			--					

Notes:
 RM = Reference Method (RWDI measurements)
 PEMS = Predictive Emission Monitors (DIG data)
 di = Difference between PEMS and RM for each point
 n = number of tests
 |d| = Absolute mean difference between the PEMS and RM results
 For measurements less than 20 ppm the difference must be < 2 ppm for NO_x and < 1 % for O₂

Table 2 - Boiler 2100 - 2023 RATA Results - Part 75

Date: Wednesday, December 06, 2023

Test	RWDI Time		NOx				NOx Emission Rate			O ₂				BF Gas Flow Rate (kscf/hr)	Nat. Gas Flow Rate (kscf/hr)
	Start Time	End Time	RM (dppm)	RM cor	PEMS (ppm)	di (ppm)	RM (lb/MMBTU)	PEMS (lb/MMBTU)	di (lb/min)	RM (d%)	RM (cor%)	PEMS (%)	di (%)		
1	7:48	8:08	12.83	12.38	13.31	-0.94	0.0260	0.0280	-0.0020	4.40	4.41	4.62	-0.21	3,530.9	32.95
2	8:21	8:41	14.85	14.49	13.20	1.30	0.0305	0.0280	0.0025	4.38	4.43	4.63	-0.20	3,493.3	32.95
3	8:55	9:15	15.51	15.25	13.96	1.29	0.0322	0.0280	0.0032	4.48	4.52	4.28	0.24	3,525.8	32.94
4	9:29	9:49	13.95	13.76	14.44	-0.69	0.0289	0.0300	-0.0011	4.36	4.40	4.27	0.13	3,598.0	32.95
5	10:06	10:26	13.65	13.40	14.20	-0.80	0.0282	0.0300	-0.0018	4.37	4.41	4.32	0.09	3,669.8	32.95
6	10:44	11:04	14.75	14.50	13.26	1.25	0.0305	0.0280	0.0025	4.34	4.39	4.33	0.06	3,631.2	32.89
7	11:15	11:35	13.72	13.45	13.05	0.40	0.0282	0.0270	0.0012	4.32	4.37	4.26	0.12	3,642.8	32.30
8	11:45	12:05	13.37	13.09	13.84	-0.75	0.0275	0.0290	-0.0015	4.35	4.40	4.25	0.15	3,676.0	32.27
9	12:19	12:39	13.33	13.00	13.68	-0.68	0.0275	0.0290	-0.0015	4.41	4.47	4.28	0.19	3,695.4	32.33
10	12:55	13:15	13.98	13.69	13.55	0.15	0.0290	0.0280	0.0010	4.44	4.49	4.23	0.26	3,730.2	32.45
11	13:27	13:47	13.15	12.89	12.98	-0.09	0.0270	0.0270	0.0000	4.32	4.37	4.25	0.11	3,689.8	32.34
12	14:23	14:43	13.27	12.95	12.88	0.07	0.0271	0.0270	0.0001	4.30	4.34	4.43	-0.09	3,713.2	32.40
AVERAGE			—	13.18	13.55	-0.37	0.028	0.028	-0.0006	—	4.40	4.33	0.06	3,633.1	32.64
STDS			—	0.44	0.55	0.50	0.0010	0.0012	0.0012	—	0.04	0.12	0.13	—	—
n			9				9			9					
Full Scale			102.3				-			21.13					
t_{0.975}			2.306				2.262			2.306					
l d l			0.37				0.0006			0.06					
l cc l			0.38				0.0009			0.10					
Bias present? (ldl > lcc)			no bias				no bias			no bias					
Bias Factor			0.97				0.98			1.01					
Relative Accuracy (20% limit)			5.7%				5.6%			3.6%					
RATA = RA 7.5% for NOx and O2			5.7 % = Pass				5.6 % = Pass			3.64 % = Pass					
RATA = <0.015 lb/MMBTU for NOx ER			—				0.00062 lb/MMBTU = Pass			—					

Notes: RM = Reference Method (RWDI measurements)
PEMS = Predictive Emission Monitors (DIG data)
di = Difference between PEMS and RM for each point
n = number of tests
l d l = Absolute mean difference between the PEMS and RM results

Table 3 - Boiler 3100 - 2023 RATA Results - Part 75

Date: Tuesday, December 05, 2023

Test	RWDI Time		NOx				NOx Emission Rate			O ₂				BF Gas Flow (kscf/hr)	Nat. Gas Flow (kscf/hr)
	Start Time	End Time	RM (dppm)	RM cor	PEMS (ppm)	di (ppm)	RM (lb/MMBTU)	PEMS (lb/MMBTU)	di (lb/min)	RM (d%)	RM (cor%)	PEMS (%)	di (%)		
1	7:50	8:10	12.70	12.30	11.83	0.47	0.0268	0.0270	-0.0002	5.02	5.04	5.54	-0.48	3,227.9	32.88
2	8:50	9:10	13.18	12.96	13.33	-0.37	0.0306	0.0290	0.0016	6.48	6.26	4.98	1.28	3,253.4	32.99
3	9:30	9:50	15.19	15.19	12.96	2.24	0.0338	0.0280	0.0058	5.30	5.37	4.98	0.40	3,262.5	32.83
4	10:03	10:23	14.28	14.32	12.71	1.61	0.0313	0.0280	0.0033	5.05	5.12	4.98	0.14	3,261.7	32.88
5	10:38	10:58	13.30	13.27	14.25	-0.98	0.0290	0.0310	-0.0020	5.01	5.07	4.94	0.14	3,297.8	32.89
6	11:10	11:30	14.07	14.11	13.41	0.70	0.0309	0.0290	0.0019	5.06	5.12	4.99	0.13	3,245.7	32.88
7	11:42	12:02	14.95	15.14	13.72	1.42	0.0331	0.0300	0.0031	5.06	5.11	4.97	0.14	3,279.3	32.84
8	12:24	12:44	13.00	13.13	13.38	-0.25	0.0290	0.0290	0.0000	5.21	5.27	5.10	0.17	3,110.6	32.89
9	12:54	13:14	13.15	13.31	13.58	-0.27	0.0292	0.0290	0.0002	5.13	5.18	4.98	0.20	3,191.9	32.95
10	13:26	13:46	13.04	13.16	13.41	-0.25	0.0288	0.0290	-0.0002	5.04	5.09	4.96	0.13	3,311.0	32.93
11	13:59	14:19	15.29	15.39	13.33	2.07	0.0338	0.0290	0.0048	5.10	5.16	5.03	0.13	3,203.8	32.93
12	14:32	14:52	15.87	15.82	13.85	1.97	0.0347	0.0300	0.0047	5.07	5.14	4.97	0.18	3,285.5	32.92
AVERAGE			—	13.52	13.29	0.23	0.030	0.029	0.0008	—	5.14	4.99	0.15	3,244.3	32.90
STDS			—	0.85	0.68	0.88	0.002	0.001	0.002	—	0.06	0.05	0.03	—	—
n			9				9			9					
Full Scale			102.3				-			21.13					
t_{0.975}			2.306				2.262			2.306					
 d 			0.23				0.0008			0.15					
 cc 			0.67				0.0013			0.02					
Bias present? (d > cc)			no bias				no bias			bias present					
Bias Factor			1.02				1.03			1.03					
Relative Accuracy (20% limit)			6.7%				7.3%			3.3%					
RATA = RA 7.5% for NOx and O2			6.7 % = Pass				7.3 % = Pass			3.31% = Pass					
RATA = <0.015 lb/MMBTU for NOx ER			--				0.00085 lb/MMBTU = Pass			-					

Notes:
 RM = Reference Method (RWDI measurements)
 PEMS = Predictive Emission Monitors (DIG data)
 di = Difference between PEMS and RM for each point
 n = number of tests
 | d | = Absolute mean difference between the PEMS and RM results

Table 4 - Turbine 1100 - 2023 RATA Results - Part 75

Date: Thursday, December 07, 2023

Test	RWDI Time		NO _x				NO _x Emission Rate			O ₂				Load (MW)
	Start Time	End Time	RM (dppm)	RM cor	PEMS (ppm)	di (ppm)	RM (lb/MMBTU)	PEMS (lb/MMBTU)	di (lb/min)	RM (d%)	RM (cor%)	PEMS (%)	di (%)	
1	7:13	7:33	10.10	10.33	10.15	0.17	0.0288	0.0300	-0.0012	13.05	13.11	13.60	-0.49	182.4
2	7:46	8:06	10.09	10.39	10.13	0.26	0.0292	0.0300	-0.0008	13.06	13.17	13.61	-0.44	182.4
3	8:25	8:45	10.09	10.38	10.22	0.16	0.0292	0.0300	-0.0008	13.06	13.18	13.41	-0.24	182.6
4	8:55	9:15	10.06	10.39	10.11	0.28	0.0292	0.0300	-0.0008	13.06	13.17	13.62	-0.45	182.4
5	9:27	9:47	9.99	10.32	10.09	0.23	0.0291	0.0300	-0.0009	13.07	13.18	13.64	-0.46	181.8
6	10:00	10:20	9.94	10.23	10.07	0.16	0.0288	0.0280	0.0008	13.07	13.18	13.12	0.06	181.3
7	10:31	10:51	9.94	10.25	10.02	0.23	0.0288	0.0270	0.0018	13.08	13.18	12.90	0.28	180.7
8	11:04	11:24	9.91	10.20	10.03	0.17	0.0288	0.0270	0.0018	13.09	13.19	12.86	0.33	180.0
9	11:34	11:54	9.90	10.17	10.03	0.14	0.0287	0.0270	0.0017	13.09	13.20	12.92	0.28	179.7
10	12:05	12:25	9.91	10.19	10.05	0.13	0.0288	0.0270	0.0018	13.09	13.21	12.82	0.39	179.5
AVERAGE			-	10.27	10.09	0.19	0.0290	0.0288	0.00019	-	13.18	13.21	-0.027	181.3
STDS			-	0.084	0.067	0.044	0.00022	0.0015	0.0013	-	0.013	0.36	0.37	-
n			9				9			9				
Full Scale			102.6				-			21.05				
t_{0.975}			2.306				2.262			2.306				
 d 			0.19				0.0002			0.03				
 cc 			0.03				0.0010			0.28				
Bias present? (d > cc)			bias present				no bias			no bias				
Bias Factor			1.02				1.01			1.00				
Relative Accuracy (20% limit)			2.1%				4.1%			2.3%				
RATA = RA 7.5% for NO_x and O₂			2.13 % = Pass				4.1 % = Pass			2.34 % = Pass				
RATA = <0.015 lb/MMBTU for NO_x ER			--				0.00019 lb/MMBTU = Pass			--				

Notes:

RM = Reference Method (RWDI measurements)

PEMS = Predictive Emission Monitors (DIG data)

di = Difference between PEMS and RM for each point

n = number of tests

| d | = Absolute mean difference between the PEMS and RM results

For measurements less than 20 ppm the difference must be < 2 ppm for NO_x and < 1 % for O₂

Table 5 - Turbine 2100 - 2023 RATA Results - Part 75

Date: Wednesday, December 06, 2023

Test	RWDI Time		NOx				NOx Emission Rate			O ₂				Load (MW)
	Start Time	End Time	RM (dppm)	RM cor	PEMS (ppm)	di (ppm)	RM (lb/MMBTU)	PEMS (lb/MMBTU)	di (lb/min)	RM (d%)	RM (cor%)	PEMS (%)	di (%)	
1	7:40	8:00	10.50	10.54	10.64	-0.11	0.0293	0.0290	0.0003	12.97	13.08	12.87	0.21	194.1
2	8:16	8:36	10.51	10.55	10.64	-0.09	0.0294	0.0290	0.0004	12.98	13.10	12.88	0.22	194.0
3	8:44	9:04	10.48	10.65	10.64	0.01	0.0297	0.0290	0.0007	12.98	13.10	12.88	0.22	193.7
4	9:16	9:36	10.54	10.78	10.63	0.14	0.0299	0.0290	0.0009	12.98	13.07	12.88	0.19	193.6
5	9:48	10:08	10.43	10.68	10.63	0.05	0.0297	0.0290	0.0007	12.99	13.08	12.89	0.19	193.4
6	10:20	10:40	10.50	10.72	10.62	0.10	0.0298	0.0290	0.0008	12.98	13.08	12.89	0.19	193.3
7	10:50	11:10	10.60	10.82	10.64	0.24	0.0304	0.0290	0.0014	12.99	13.09	12.90	0.19	192.9
8	11:20	11:40	10.54	10.75	10.57	0.18	0.0300	0.0290	0.0010	12.98	13.11	12.92	0.19	192.3
9	11:49	12:09	10.48	10.68	10.54	0.14	0.0298	0.0290	0.0008	12.99	13.12	12.94	0.18	191.9
10	12:17	12:37	10.49	10.69	10.52	0.17	0.0298	0.0290	0.0008	12.98	13.11	12.95	0.16	191.3
AVERAGE			-	10.67	10.60	0.07	0.030	0.029	0.00071	-	13.09	12.90	0.19	193.0
STDS			-	0.083	0.048	0.110	0.00024	0.000	0.00024	-	0.017	0.028	0.017	-
n			9				9			9				
Full Scale			102.6				-			21.05				
t_{0.975}			2.306				2.262			2.306				
 d 			0.07				0.0007			0.19				
 cc 			0.08				0.0002			0.01				
Bias present? (d > cc)			no bias				bias present			bias present				
Bias Factor			1.01				1.02			1.01				
Relative Accuracy (20% limit)			1.4%				3.0%			1.6%				
RATA = RA 7.5% for NOx and O2			1.42 % = Pass				3.0 % = Pass			1.56 % = Pass				
RATA = <0.015 lb/MMBTU for NOx ER			--				0.00071 lb/MMBTU = Pass			--				

Notes: RM = Reference Method (RWDI measurements)
 PEMS = Predictive Emission Monitors (DIG data)
 di = Difference between PEMS and RM for each point
 n = number of tests
 |d| = Absolute mean difference between the PEMS and RM results

Table 6 - Turbine 3100 - 2023 RATA Results - Part 75

Date: Tuesday, December 05, 2023

Test	RWDI Time		NOx				NOx Emission Rate			O ₂				Load (MW)
	Start Time	End Time	RM (dppm)	RM cor	PEMS (ppm)	di (ppm)	RM (lb/MMBTU)	PEMS (lb/MMBTU)	di (lb/min)	RM (d%)	RM (cor%)	PEMS (%)	di (%)	
1	7:53	8:13	9.21	9.11	9.47	-0.36	0.0253	0.0260	-0.0007	13.07	13.08	13.0	0.1	186.9
2	8:40	9:00	9.32	9.15	9.46	-0.31	0.0256	0.0260	-0.0004	13.06	13.13	13.0	0.1	186.8
3	9:15	9:35	9.24	9.17	9.47	-0.30	0.0258	0.0260	-0.0002	13.07	13.17	13.0	0.2	186.6
4	9:50	10:10	9.28	9.23	9.72	-0.49	0.0259	0.0260	0.0009	13.07	13.16	12.6	0.6	186.5
5	10:25	10:45	9.25	9.27	9.71	-0.44	0.0261	0.0260	0.0001	13.06	13.17	12.6	0.5	186.7
6	11:00	11:20	9.22	9.26	9.69	-0.43	0.0260	0.0260	0.0000	13.06	13.16	12.7	0.4	186.7
7	11:35	11:55	9.25	9.28	9.69	-0.40	0.0260	0.0260	0.0000	13.05	13.14	12.8	0.4	186.8
8	12:10	12:30	9.21	9.21	9.69	-0.47	0.0259	0.0260	-0.0001	13.03	13.16	12.8	0.4	186.9
9	12:47	13:07	9.22	9.23	9.69	-0.46	0.0260	0.0260	0.0000	13.03	13.17	12.7	0.5	186.6
10	13:18	13:38	9.20	9.25	9.68	-0.43	0.0260	0.0260	0.0000	13.03	13.17	12.8	0.4	186.7
AVERAGE			—	9.21	9.62	-0.40	0.0258	0.0260	-0.00015	—	13.15	12.83	0.32	186.7
STDS			—	0.061	0.11	0.06	0.00025	0.0000	0.00025	—	0.030	0.15	0.17	—
n			9				9			9				
Full Scale			102.6				-			21.05				
t_{0.975}			2.306				2.262			2.306				
 d 			0.40				0.00015			0.32				
 cc 			0.05				0.00019			0.13				
Bias present? (d > cc)			bias present				no bias			bias present				
Bias Factor			0.96				0.99			1.03				
Relative Accuracy (20% limit)			4.9%				1.3%			3.4%				
RATA = RA 7.5% for NOx and O2			4.87 % = Pass				1.3 % = Pass			3.44 % = Pass				
RATA = <0.015 lb/MMBTU for NOx ER			--				0.00015 lb/MMBTU = Pass			--				

Notes:


RM = Reference Method (RWDI measurements)
 PEMS = Predictive Emission Monitors (DIG data)
 di = Difference between PEMS and RM for each point
 n = number of tests
 | d | = Absolute mean difference between the PEMS and RM results

FIGURES





Figure No. 1: USEPA Method 3A and 7E Schematic



USEPA Method 3A and 7E
Dearborn Industrial Generation

Dearborn, MI


Project# 2400110

Date: December 5 to 7, 2023





Figure No. 2 Schematic of Traverse Locations Boilers 1100, 2100 and 3100



Boilers 1100, 2100 & 3100
Dearborn Industrial Generation

Dearborn, Michigan


Date:
December 5th to 7th, 2023

RWDI USA LLC
2239 Star Court
Rochester Hills, MI 48309



Diameter: 19' x 22' (228" x 264")
 Effective Diameter: 245 inches

Figure No. 3: Schematic of Traverse Locations for Turbine 1100




Point	Distance from inside Wall						
	Port 1	Port 2	Port 3	Port 4	Port 5	Port 6	Port 7
1	X	X	X	16"	X	X	X
2	X	X	X	47"	X	X	X
3	X	X	X	79"	X	X	X

Not to scale



Figure No. 4 Schematic of Traverse Locations Turbines 2100 and 3100



Turbines 2100 & 3100
Dearborn Industrial Generation

Dearborn, Michigan

Date:
December 5th to 6th, 2023

RWDI USA LLC
2239 Star Court
Rochester Hills, MI 48309