

DEPARTMENT OF ENVIRONMENTAL QUALITY

AIR QUALITY DIVISION

FCE Summary Report

Facility : VECTOR PIPELINE L.P.	SRN : N7624
Location : 12708 30 MILE RD	District : Southeast Michigan
	County : MACOMB
City : WASHINGTON State: MI Zip Code : 48095	Compliance Status : Compliance
Source Class : MAJOR	Staff : Sebastian Kallumkal
FCE Begin Date : 6/1/2015	FCE Completion Date : 8/1/2016
Comments : From the facility inspection, records and reports review, this facility appears to be in compliance with the applicable requirements.	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
07/26/2016	Scheduled Inspection	Compliance	Onsite Inspection
04/18/2016	MAERS	Compliance	MAERS Report Submission. Reviewed and uploaded.
03/21/2016	ROP Other	Compliance	MAERS Certification form.
03/21/2016	ROP Annual Cert	Compliance	No deviations reported
03/21/2016	ROP SEMI 2 CERT	Compliance	no deviations reported
09/17/2015	ROP Semi 1 Cert	Compliance	Timely.
09/17/2015	Stack Test	Compliance	Stack test results for two combustion turbines (EUTURBINE1 and EUTURBINE2). CO and NOx emissions were below the allowed emission limits at both NGP (103 and 93% NGP for both Turbines. Report forwarded to TPU staff Tom Maza for further review.
07/28/2015	Stack Test Observation	Compliance	Testing for Turbine 1 and Turbine 2

Name: S. KallumkalDate: 8/1/2016Supervisor: CJE