## DEPARTMENT OF ENVIRONMENTAL QUALITY AIR QUALITY DIVISION

## **FCE Summary Report**

Facility: VECTOR PIPELINE L.P., Athens Compressor Station	SRN:	N8151			
Location: 4981 2 Mile Rd	District :	Kalamazoo			
	County:	CALHOUN			
City: ATHENS State: MI Zip Code: 49011 Compl Status		Compliance			
Source Class: MAJOR Staff: Amanda Cross					
FCE Begin Date: 1/31/2021 FCE Date	Completion :	1/31/2023			
Comments :					

## **List of Partial Compliance Evaluations:**

Activity Date	Activity Type	Compliance Status	Comments
01/24/2023	On-site Inspection	Compliance	
09/22/2022	ROP Semi 1 Cert	Compliance	The facility submitted an ROP certification form with original signature from responsible official and date. The facility reports that during the entire reporting period, all monitoring and associated recordkeeping requirements in the ROP were met and no deviations from these requirements or any other terms and conditions occurred.
03/21/2022	ROP SEMI 2 CERT	Compliance	The facility submitted an ROP certification form with original signature and date. The facility reported they were in compliance with all terms and conditions contained in the ROP for the reporting period.
03/21/2022	MAERS		The facility submitted an ROP certification form with original signature and date. The facility reports that the 2021 MAERS report was submitted via MAERS.
03/21/2022	ROP Annual Cert	Compliance	The facility submitted an ROP certification form with original signature and date. The facility reported they were in compliance with all terms and conditions contained in the ROP for the reporting period.

Activity Date	Activity Type	Compliance Status	Comments
09/29/2021	Stack Test	Compliance	Corrected Stack Test Emission Report for a natural gas fired turbine, test date May 29, 2019.
			The facility reported a NOx concentration of 9ppm with a permit limit of 25ppm. The test shows compliance with the permit emission limit.
09/29/2021	ROP Semi 1 Cert	Compliance	The facility submitted an ROP form with an original signature and date from the responsible official. During the reporting period, the facility certifies that all monitoring and associated recordkeeping requirements in the ROP were met and no deviations from these requirements or any other terms or conditions occurred.
09/27/2021	Release Reports	Compliance	Vector Athens Compressor Station is planning to complete a mainline blowdown on September 28th to allow for scheduled work on Athens' pipeline traps. It has been estimated that the natural gas vented at Athens Compressor Station will be approximately 2MMSCF.
			The release is at a regulated facility so it is being completed under Rule 285(2)(mm).
04/13/2021	MAERS	Compliance	Facility submitted a signed ROP certification form with original signature and date. Facility certifies their MAERS 2020 reporting.
04/13/2021	ROP Annual Cert	Compliance	Facility submitted a signed ROP certification form with original signature and date. Facility reports that during the entire reporting period, all monitoring and associated recordkeeping requirements in the ROP were met and no deviations from these requirements or other terms or conditions occurred.
04/13/2021	ROP SEMI 2 CERT	Compliance	Facility submitted a signed ROP certification form with original signature and date. Facility reports that during the entire reporting period, all monitoring and associated recordkeeping requirements in the ROP were met and no deviations from these requirements or other terms or conditions occurred.