

DEPARTMENT OF ENVIRONMENTAL QUALITY
 AIR QUALITY DIVISION
 ACTIVITY REPORT: Self Initiated Inspection

N817729916


FACILITY: RIVER'S EDGE PET CREMATORY, LLC		SRN / ID: N8177
LOCATION: N10186 BURT ST, RAMSAY		DISTRICT: Upper Peninsula
CITY: RAMSAY		COUNTY: GOGEBIC
CONTACT: Joy Smith , Owner		ACTIVITY DATE: 06/19/2015
STAFF: Joel Asher	COMPLIANCE STATUS: Compliance	
SUBJECT: Pet crematory		SOURCE CLASS: MINOR
RESOLVED COMPLAINTS:		

On 6/19/2015 I conducted an unannounced inspection of this facility. My contact was the owner. Ms. Joy Smith.

Operations at this pet crematory have increased substantially since it was first permitted in 2008. The crematory is now operated 3 days per week, usually Monday, Wednesday, and Friday.

This unit is permitted under PTI #334-08. The crematory is well maintained and continues to utilize a chart recorder to document the secondary combustion temperature as required in SC IV.1. The unit has been calibrated and consistently operates with a secondary combustion temperature above 1600 degrees F, per SC III.1. Ms. Smith stated the set point for the secondary combustion chamber is 1675 degrees F. A review of old temperature charts shows the unit to consistently maintain an operating temperature above 1600 degrees F. Several cycles are documented on each chart (for a cost savings of not wasting chart space). Each cycle is noted with the start time and poundage of the charge per SC VI.1. All charts are maintained and are available for observation per SC VI.3.

This unit appears to be well maintained and operated. No violations of the Air Pollution Control Rules or PTI #334-08 were observed during this inspection.

NAME 

DATE 6/25/15

SUPERVISOR _____