

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION

FCE Summary Report

Facility : CLOVERLAND ELECTRIC - MANISTIQUE DIESEL PEAKERS	SRN : N8304
Location : 335 CHIPPEWA AVE	District : Upper Peninsula
	County : SCHOOLCRAFT
City : MANISTIQUE State: MI Zip Code : 49854	Compliance Status : Compliance
Source Class : SM OPT OUT	Staff : Ed Lancaster
FCE Begin Date : 10/1/2014	FCE Completion Date : 9/29/2015
Comments : Completed inspection and review of all documents to determine company is in compliance at this time.	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
09/21/2015	Scheduled Inspection	Compliance	Conducted scheduled, unannounced compliance inspection.
02/20/2015	Stack Test	Compliance	Purpose of the December 11, 2014 test was to evaluate compliance of two peaker units with the RICE MACT Subpart ZZZZ. EUPEAKER2 passed the CO limit with an average result of 14.8 ppmvd (limit is 23). EUPEAKER2 had a 90.7% removal efficiency of CO, surpassing the 70% limit.
12/11/2014	Stack Test Observation	Compliance	Compliance testing for RICE MACT for both peaker units.

Name: Ed Lancaster **Date:** 9/29/15 **Supervisor:** _____