

FORTISTAR Methane Group

C&C Energy LLC

19401 15 Mile Road ♦ Marshall, Michigan 49068

Tel. (269) 781-8044 ♦ Fax. (269) 781-8217

January 9, 2015

Mr. Matthew Deskins
Air Quality Division
Michigan Department of Environmental Quality
7953 Adobe Road
Kalamazoo, MI 49009

Subject: Violation Notice Response - Engine #2 Retest, grams/bhp-hr Results
C&C Energy LLC
Marshall, Michigan (MI-ROP-P0222-2012)

Dear Mr. Deskins,

C&C Energy LLC is in receipt of your violation notice dated December 17, 2014. On December 18, 2014 C&C Energy LLC submitted the results for the CO grams/bhp-hr emission rate based on f-factor for Engine #2 calculated during the source test conducted by M3V, LLC on October 30, 2014. As stated in that letter, the results indicate a slightly higher emission rate than the permitted limit (1.07% over permitted number), however the mass emission rates in lb/hr were under the permitted limits.

Also note that this engine was recently maintained by a third part vendor and we were assured of its compliance status. The engine is currently out of service related to maintenance. A retesting has been tentatively scheduled for January 23rd, 2015.

If you have any questions, please contact Suparna Chakladar at your convenience at (951)-833-4153.

Sincerely,



Anthony J. Falbo
Senior Vice President - Operations
FORTISTAR Methane Group
C&C Energy LLC

Enclosures

cc: Suparna Chakladar, FMG

