

P0262

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION
FCE Summary Report

2018
FY2018 FCE
ROP CMS

Facility : BLUE WATER RENEWABLES	SRN : P0262
Location : 6797 SMITHS CREEK ROAD	District : Southeast Michigan
	County : SAINT CLAIR
City : SMITHS CREEK State: MI Zip Code : 48074	Compliance Status : Compliance
Source Class : MAJOR	Staff : Iranna Konanahalli
FCE Begin Date : 9/13/2017	FCE Completion Date : 9/22/2017
Comments : BWR operates its electric power generating engines (Nos. 1-2) in compliance with the permit and incorporated federal regulations (NSPS 4J and SI RICE MACT 4Z).	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
09/20/2017	Other	Compliance	Subject: Jan 25 & 31, 2017, annual, SI RICE NSPS 4J, Stack Test of DTE Engines (NSPS 4J Engines: EU- ICENGINE1 and EU- ICENGINE2) - Compliance Determination
09/14/2017	Scheduled Inspection	Compliance	FY2017 ROP CMS scheduled inspection of Blue Water Renewables, LLC
09/13/2017	Other	Compliance	PTI No. 163-09D Weekly Sulfur Sampling Plan

P0262 - FCE - 2017 09 22

Name: Iranna Konanahalli Date: 09/22/2017

Supervisor: Joyce B
Page 1 of 1