



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
GRAND RAPIDS DISTRICT OFFICE



LIESL EICHLER CLARK
DIRECTOR

December 29, 2020

Mr. Joel Davenport
Holland Board of Public Works
625 Hastings Avenue
Holland, Michigan 49423

SRN: P0465, Ottawa County

Dear Mr. Davenport:

VIOLATION NOTICE

In a report received on November 16, 2020, Holland Board of Public works reported to the Department of Environment, Great Lakes, and Energy (EGLE), Air Quality Division (AQD), an emissions exceedance from one of the turbines at Holland Board of Public Works – Holland Energy Park located at 1 Energy Park Way, Holland, Michigan. The information was reviewed to determine Holland Board of Public Works – Holland Energy Parks compliance with the requirements of the federal Clean Air Act; Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (Act 451); the Air Pollution Control Rules; and the conditions of Renewable Operating Permit (ROP) number MI-ROP-P0465-2018.

During the review of the report, staff verified the following:

Process Description	Rule/Permit Condition Violated	Comments
EUCTGHRSG11	MI-ROP-P0465-2018, FGCTGHRSG, Special Condition 1.7	Exceedance of the 247.3 pph CO emission limit for startup.

The report demonstrated that actual emissions of Carbon Monoxide (CO) during startup from EUCTGHRSG11 was 263.4 pounds per hour (pph). The conditions of MI-ROP-P0465 limit the emissions of EUCTGHRSG11 to 247.3 pounds per operating hour during startup.

Please initiate actions necessary to correct the cited violation and submit a written response to this Violation Notice by January 19, 2021 (which coincides with 21 calendar days from the date of this letter). The written response should include: the dates the violation occurred; an explanation of the causes and duration of the violation; whether the violation is ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violation and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

Please submit the written response to EGLE, AQD, Grand Rapids District Office at 350 Ottawa Avenue, N.W., Unit 10, Grand Rapids, Michigan 49503 and submit a copy to Ms. Jenine Camilleri, Enforcement Unit Supervisor at EGLE, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760.

Mr. Joel Davenport
Holland Board of Public Works
Page 2
December 29, 2020

If Holland Board of Public Works – Holland Energy Park believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position. Thank you for your attention to resolving the violation cited above and for the cooperation. If you have any questions regarding the violation or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,

Kaitlyn DeVries

Kaitlyn DeVries
Senior Environmental Quality Analyst
Air Quality Division
616-558-0552

cc/via email: Ms. Mary Ann Dolehanty, EGLE
Dr. Eduardo Olaguer, EGLE
Ms. Jenine Camilleri, EGLE
Mr. Christopher Ethridge, EGLE
Ms. Heidi Hollenbach, EGLE