

DEPARTMENT OF ENVIRONMENTAL QUALITY

AIR QUALITY DIVISION

FCE Summary Report

Facility : Upper Michigan Energy Resources -F.D. Kuester G.S.	SRN : P0797
Location : 80 Eagle Mills Road	District : Marquette
	County : MARQUETTE
City : NEGAUNEE State: MI Zip Code : 49849	Compliance Status : Compliance
Source Class : MAJOR	Staff : Sydney Hewson
FCE Begin Date : 1/1/2020	FCE Completion Date : 2/18/2021
Comments : FCE to verify compliance with MI-ROP-P0797-2020 and all other applicable state and federal air quality regulations	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
01/20/2021	On-site Inspection	Compliance	Onsite Inspection to verify compliance with MI-ROP-P0797-2020 and all other applicable state and federal air quality regulations.
10/08/2020	ROP Semi 1 Cert	Compliance	semi-Annual Report Certification and Deviation Report from March 6, 2020 to June 30, 2020. Urea system tripped, this was repaired as soon as discovered
07/27/2020	NSPS (Part 60)	Compliance	Compliance Emissions Test report (40 CFR Part 60, Subpart JJJJ Performance Test) numbers: M201702A (EURICE1), M201702B (EURICE2), M201702C (EURICE3), M201702D (EURICE4), M201702E (EURICE5), M201702F (EURICE6), M201702G (EURICE7)
07/27/2020	MACT (Part 63)	Compliance	MACT (Suppart ZZZZ) Performance Stack Test Report #M201702H (EURICE1 to EURICE7) from 5/12/2020 to 5/15/2020
05/14/2020	Stack Test Observation	Compliance	Stack test observation onsite to verify compliance with emissions testing required Part 60, Subpart JJJJ, Permit No. MI-ROP-P0797-2020, and PTI No. 35-17B
05/12/2020	Stack Test Observation	Compliance	Stack test observation onsite to verify compliance with emissions testing required Part 60, Subpart JJJJ, Permit No. MI-ROP-P0797-2020, and PTI No. 35-17B

Activity Date	Activity Type	Compliance Status	Comments
04/03/2020	MAERS	Compliance	2019 MAERS - Refer to MAERS for any comments
03/18/2020	MACT (Part 63)	Compliance	40 CFR Part 63, Subpart ZZZZ Semiannual Compliance Report. There were no Malfunctions or Deviations reported for the engines
01/03/2020	ROP Other	Compliance	Acid Rain Program New Unit Exemption 40 CFR 72.7

Name:

S. A. Tolson

Date:

2/23/21

Supervisor:

E. J. [Signature]