



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
LANSING



LIESL EICHLER CLARK
DIRECTOR

June 9, 2022

UPS NEXT DAY DELIVERY

Haidar Bad
Bazo Construction
12645 Delta Street
Taylor, Michigan 48180

SRN/ID: U252202835; Genesee County

Dear Haider Bad:

VIOLATION NOTICE

On June 2, 2022, the Department of Environment, Great Lakes, and Energy (EGLE), Air Quality Division (AQD) conducted a complaint investigation at 3509 Corunna Road, Flint Township, Genesee County. The purpose of this inspection was to determine compliance with the requirements of Title 40 of the Code of Federal Regulations (40 CFR), Part 61, Subpart M (National Emission Standard for Asbestos), and Rule 942 of Part 55, Air Pollution Control of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended.

According to my investigation, Bazo Construction, owns the facility being demolished and was also the contractor performing the demolition activities. The National Emission Standard for Asbestos (NESHAP) holds the *owner and operator* liable for all violations.

During the inspection, EGLE staff observed the following:

The former commercial gas station and single residential home were demolished, and the demolition debris was left staged on-site. No thorough asbestos inspection was completed and no Notice of Intent to Renovate/Demolish was submitted to the administrator prior to the demolition activities.

Process Description	Section Violated	Comments
On 6/1/2022, complaints were received regarding the demolition of 3509 Corunna Road, Flint Township. The complainants were concerned that the demolition was not being properly done. On 6/2/2022, a site investigation was performed and found that the demolition had occurred, was not complete, and was stopped.	40 CFR §61.145(a)(1)	Failure to thoroughly inspect prior to the commencement of activities.
	40 CFR §61.145(b)(1)	Failure to notify the administrator prior to the demolition.

VIOLATION NOTICE

Haidar Bad

Page 2


June 9, 2022

Please initiate actions necessary to correct the cited violations and submit a written response to this violation notice by June 30, 2022, (which coincides with 21 calendar days from the date of this letter). The written response should include: the date(s) the violations occurred; an explanation of the causes and duration of the violations; whether the violations are ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violations, and the date(s) by which these actions will take place; and what steps are being taken to prevent a reoccurrence. The *signed* written response from the *owner and operator* to this violation notice, may be submitted by mail and directed to my attention at EGLE, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760. You must also include a copy to Jason Wolf, Enforcement Unit at EGLE, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760. The response may be scanned and emailed to DechyC@Michigan.gov and WolfJ2@Michigan.gov.

If you believe the above observations or statements are inaccurate or do not constitute a violation of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violations cited above and for the cooperation extended to me during our phone conversation. If you have any questions regarding the violation notice or the actions necessary to bring this facility into compliance, please contact me at 517-749-2891; DechyC@Michigan.gov; or the post office box address provided in the paragraph above.

Sincerely,



Craig W. Dechy

Senior Environmental Quality Analyst
Air Quality Division

cc: Mary Ann Dolehanty, EGLE
Eduardo Olaguer, EGLE
Christopher Ethridge, EGLE
Tammy Bell, EGLE
Brad Myott, EGLE
Jason Wolf, EGLE