



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
LANSING



LIESL EICHLER CLARK
DIRECTOR

February 6, 2020

UPS NEXT DAY DELIVERY

Mr. John Graham
Isabella County Road Commission
2261 East Remus Road
Mt. Pleasant, Michigan 48858

ID: U372000444; Isabella County

Dear Mr. Graham:

VIOLATION NOTICE

On January 30, 2020, the Department of Environment, Great Lakes, and Energy (EGLE), Air Quality Division (AQD) conducted an inspection of the commercial building located at 2261 East Remus Road, Mt. Pleasant, Isabella County, Michigan.

The purpose of this inspection was to determine compliance with the requirements of Title 40 of the Code of Federal Regulations (40 CFR), Part 61, Subpart M (National Emission Standard for Asbestos), and Rule 942 of Part 55, Air Pollution Control of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (Act 451).

According to our investigation, Isabella County Road Commission was the demolition contractor who demolished the structure and owns the structure. The National Emission Standard for Asbestos (NESHAP) holds the *owner and operator* liable for all violations.

During the investigation staff observed the following:

The subject structure was demolished, and the debris was removed from the site. There was no 10-working day Scheduled Demolition Notification submitted prior to demolition.

Process Description	Section Violated	Comments
Failure to submit a 10-working day Notification and have an asbestos survey done prior to demolition.	40 CFR §61.145(b)(1)	Failure to provide 10-working day notification.

Please initiate actions necessary to correct the cited violation and submit a written response to this violation notice by February 27, 2020, (which coincides with 21 calendar days from the date of this letter). The written response should include: the date(s) the violation occurred; an explanation of the causes and duration of the


Mr. John Graham
Page 2
February 6, 2020

violation; whether the violation is ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violation, and the date(s) by which these actions will take place; and what steps are being taken to prevent a reoccurrence. The *signed* written response from the *owner and operator* to this violation notice, may be submitted by mail and directed to my attention at: EGLE, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760. You must also include a copy to Mr. Jason Wolf, Enforcement Unit at: EGLE, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760. The response may be scanned and emailed to BrownJ9@Michigan.gov and WolfJ2@Michigan.gov.

If you believe the above observations or statements are inaccurate or do not constitute a violation of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violation cited above and for the cooperation extended to me during our conversation. If you have any questions regarding the violation notice or the actions necessary to bring this facility into compliance, please contact me at 517-599-7825; BrownJ9@Michigan.gov; or the post office box address provided in the paragraph above.

Sincerely,

A handwritten signature in black ink, appearing to read 'Jeremiah Brown', with a long horizontal line extending to the left.

Jeremiah Brown
Environmental Quality Analyst
Air Quality Division

cc: Ms. Mary Ann Dolehanty, EGLE
Dr. Eduardo Olaguer, EGLE
Mr. Christopher Ethridge, EGLE
Mr. Chris Hare, EGLE
Ms. Karen Kajiya-Mills, EGLE
Mr. Jason Wolf, EGLE