



RICK SNYDER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF ENVIRONMENTAL QUALITY
SAGINAW BAY DISTRICT OFFICE



C. HEIDI GREYER
DIRECTOR

February 12, 2018

Mr. Matt Mead
Mead and Sons Contracting Inc
3330 Schust Road
Saginaw, Michigan 48603

Mr. Tom Miller
Saginaw County Land Bank
111 South Michigan
Saginaw, Michigan 48602

SRN / ID: U731709334; Saginaw County

Dear Mr. Mead and Mr. Miller

VIOLATION NOTICE

On January 31, 2018, the Michigan Department of Environmental Quality (MDEQ), Air Quality Division (AQD), performed an asbestos inspection at 3409 Roberts Street, Saginaw, Saginaw County, Michigan. The purpose of this inspection was to determine compliance with the requirements of Title 40 of the Code of Federal Regulations, Part 61, Subpart M (National Emission Standard for Asbestos), and Rule 942 of Part 55, Air Pollution Control of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (Act 451).

According to my inspection, Saginaw County Land Bank owns the property and Mead and Sons Contracting Inc performed the demolition activities. The National Emission Standard for Asbestos holds both the owner and the operator liable for all violations.

During the inspection, staff observed the following:

The asbestos in the structure was abated and the notification for the abatement indicated the abatement was finished; however, asbestos containing floor tile and mastic from the residence was made friable from action between the excavator and the cement slab.

Process Description	Section Violated	Comments
Nonfriable ACM was left in the structure after abatement was finished and was made friable during demolition activities.	§61.145(a)	Failure to thoroughly inspect.
	§61.145(c)(1)	Failure to remove RACM

Please initiate actions necessary to correct the cited violations and submit a written response to this violation notice by March 5, 2018 (which coincides with 21 calendar days from the date of this letter).

Mr. Matt Mead and Mr. Tom Miller
Page 2
February 12, 2018

The written response should include: the date(s) the violations occurred; an explanation of the causes and duration of the violations; whether the violations are ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violations, and the date(s) by which these actions will take place; and what steps are being taken to prevent a reoccurrence. The signed written response from the owner (Saginaw County Land Bank) and operator (Mead and Sons Contracting Inc) to this violation notice may be submitted by mail and directed to my attention at; DEQ AQD, 401 Ketchum Street, Suite B, Bay City, Michigan 48708, or scanned and sent as an email attachment to karlm@michigan.gov.

If you believe the above observations or statements are inaccurate or do not constitute a violation of the applicable legal requirements cited, please provide the appropriate factual information to explain your position.

Thank you for your attention to resolving the violations cited above and for the cooperation extended to me during our meeting and emails. If you have any questions regarding the violation notice or the actions necessary to bring this facility into compliance, please contact me at 989-439-3779; karlm@michigan.gov; or DEQ AQD, 401 Ketchum Street, Suite B, Bay City, Michigan 48708.

Sincerely,



Matthew R. Karl
Environmental Quality Analyst
Air Quality Division

cc/via email: Ms. Lynn Fiedler, MDEQ
Ms. Mary Ann Dolehanty, MDEQ
Mr. Christopher Ethridge, MDEQ
Mr. Thomas Hess, MDEQ
Ms. Karen Kajiya-Mills, MDEQ
Mr. Chris Hare, MDEQ