



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF ENVIRONMENTAL QUALITY
DETROIT FIELD OFFICE



LIESL EICHLER CLARK
DIRECTOR

March 7, 2019

Wayne County Department of Public Services
Attn: Mr. Michael Gorman
400 Monroe Street
Detroit, MI 48226

Toebe Construction, LLC
Attn: Mr. Josh Goldsworthy
28900 Wixom Road
Wixom, MI 48393

SRN: U821808210, Wayne County

Dear Mr. Gorman and Mr. Goldsworthy:

VIOLATION NOTICE

On February 1, 2019, the Department of Environmental Quality (DEQ), Air Quality Division, conducted an inspection of a bridge located at 19600 Waltz Road, Huron Township. The purpose of this inspection was to determine compliance with the requirements of Title 40 of the Code of Federal Regulations, Part 61, National Emission Standards for Hazardous Air Pollutants, Subpart M and Rule 942 of the administrative rules promulgated under Part 55, Air Pollution Control of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended.

According to our investigation, Wayne County Department of Public Service owns the facility and Toebe Construction, LLC performed the demolition activities at the facility. The National Emission Standard for Asbestos holds both the owner and operator equally liable for violations.

During the inspection, staff observed the following:

Process Description	Section Violated	Comments
Bridge Demolition at 19600 Waltz Road	40 CFR 61.145(a)	Failure to thoroughly inspect the bridge for Asbestos Containing Material (ACM) before demolition took place.

Please initiate actions necessary to correct the cited violation and submit a signed written response to this Violation Notice by March 26, 2019 (which coincides with 21 calendar days from the date of this letter). The response should include: the dates the


violation occurred; an explanation of the causes and duration of the violation; a summary of the actions that have been taken and are proposed to be taken to correct the violation and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

Please submit the written response to Mr. Joseph Goeddeke at DEQ, AQD 3058 West Grand Boulevard, Suite 2-300, Detroit, Michigan 48202 or GoeddekeJ@michigan.gov and submit a copy to Ms. Jenine Camilleri, Enforcement Unit Supervisor at DEQ, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760 or CamilleriJ@michigan.gov.

If Wayne County Department of Public Services or Toebe Construction LLC believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide factual information to explain your position.

Thank you for your attention to resolving the violation cited above and for the cooperation that was extended to me during my investigation of this site. If you have any questions regarding the violation or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,



Joseph Goeddeke
Environmental Quality Analyst
Air Quality Division
517-331-7906

cc/via e-mail: Ms. Mary Ann Dolehanty, DEQ
Dr. Eduardo Olaguer, DEQ
Mr. Christopher Ethridge, DEQ
Ms. Jenine Camilleri, DEQ
Ms. Karen Kajiya-Mills, DEQ
Ms. Wilhemina McLemore, DEQ