

**FG{ID}**  
**FLEXIBLE GROUP CONDITIONS**  
**Major Source – New or Reconstructed Emergency CI > 500 bhp**

Red text identifies options. Select the option that applies to the source and change the text to black. Delete red text that does not apply and renumber conditions if necessary.

Blue text is guidance or notes on the use of the template. Delete all blue text prior to issuing the final permit or submitting it with a permit application.

This template is for new or reconstructed emergency CI RICE greater than 500 bhp at a major source as applicable. The RICE is new or reconstructed if the date of installation or modification is after December 19, 2002.

If this template is being used for an ROP Reopening or Renewal, and the MACT conditions were established in a PTI, the appropriate footnotes which reference enforceability must be added to each applicable condition in the template.

Permit staff, if using in a PTI, change the UARs for R 336.1213(3) to R 336.1205(1)(a) in SC IV.1 and SC VI.2.

### **DESCRIPTION**

**40 CFR Part 63, Subpart ZZZZ** - National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE), located at a major source of HAP emissions, new or reconstructed emergency, compression ignition (CI) RICE greater than 500 brake hp that does not operate or is not contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in 40 CFR 63.6640(f)(2)(ii) and (iii) or is limited use.. A RICE is new or reconstructed if the date of installation or modification is after December 19, 2002. {May add specifics for the affected EU(s).}

**Emission Unit:** {Site Specific List of Emission Units}

### **POLLUTION CONTROL EQUIPMENT**

{Enter site specific pollution control equipment or NA}

#### **I. EMISSION LIMIT(S)**

NA

#### **II. MATERIAL LIMIT(S)**

1. The permittee shall burn only diesel fuel in each engine with a maximum sulfur content of 15 ppm (0.0015 percent) by weight and a minimum Cetane index of 40 or a maximum aromatic content of 35 volume percent. **(40 CFR 1090.305)**

#### **III. PROCESS/OPERATIONAL RESTRICTION(S)**

NA

#### **IV. DESIGN/EQUIPMENT PARAMETER(S)**

NA

#### **V. TESTING/SAMPLING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**  
Permit staff – Change above UAR to Rule 201(3) if using in a PTI.

NA

## **VI. MONITORING/RECORDKEEPING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

**Permit staff – Change above UAR to Rule 201(3) if using in a PTI.**

1. The permittee shall keep, in a satisfactory manner, fuel supplier certification records or fuel sample test data, for each delivery of diesel fuel oil used in FG{ID}, demonstrating that the fuel meets the requirement of SC II.1. The certification or test data shall include the name of the oil supplier or laboratory, the sulfur content, and cetane index or aromatic content of the fuel oil. The permittee shall keep all records on file and make them available to the department upon request. **(R 336.1213(3), 40 CFR 1090.305)**

## **VII. REPORTING**

**Permit Staff – SC VII.1, 2, and 3 references to Rule 213 are ROP only. Remove before putting into a PTI. Renumber as appropriate.**

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be received by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be received by March 15 for the previous calendar year. **(R 336.1213(4)(c))**
4. The permittee shall submit an Initial Notification that includes the information in 40 CFR 63.9(b)(2)(i) through (v), and a statement that FG{ID} has no additional requirements and the basis of the exclusion. **(40 CFR 63.6645(f))**

**See Appendix 8 - Permit Staff: Remove if PTI, since this is ROP only.**

## **VIII. STACK/VENT RESTRICTION(S)**

NA

## **IX. OTHER REQUIREMENT(S)**

1. The permittee shall comply with all applicable requirements of the National Emission Standards for Hazardous Air Pollutants, as specified in 40 CFR Part 63, Subparts A and ZZZZ for Stationary Reciprocating Internal Combustion Engines. **(40 CFR 63.6590(b)(1), 40 CFR Part 63, Subparts A and ZZZZ)**

**Remove these footnotes if no PTIs are associated with the emission unit or flexible group.**

### **Footnotes:**

<sup>1</sup> This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

<sup>2</sup> This condition is federally enforceable and was established pursuant to Rule 201(1)(a).