

DEPARTMENT OF ENVIRONMENTAL QUALITY

AIR QUALITY DIVISION

FCE Summary Report

Facility : OTSEGO PAPER INC	SRN : A0023
Location : 320 N Farmer St.	District : Kalamazoo
	County : ALLEGAN
City : OTSEGO State: MI Zip Code : 49078	Compliance Status : Compliance
Source Class : MAJOR	Staff : Dale Turton
FCE Begin Date : 6/17/2015	FCE Completion Date : 1/5/2016
Comments :	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
01/05/2016	Scheduled Inspection	Compliance	
11/16/2015	Excess Emissions (CEM)	Compliance	There were no excess emissions during the period. The monitor downtimes for both turbines was 1% or less, which is acceptable. The package boiler (backup boiler) did not operate during this quarter.
11/16/2015	NSPS (Part 60)	Compliance	Quarterly SO2 report for BUB. No fuel oil burned. Operating data report for package boiler (backup boiler) - They did not exceed the allowed annual capacity factor for the period while burning either natural gas or fuel oil.
08/27/2015	NSPS (Part 60)	Compliance	Quarterly SO2 report for BUB. No fuel oil burned. Operating data report for backup boiler (BUB) - They did not exceed the allowed annual capacity factor for the period while burning either natural gas or fuel oil.
08/27/2015	Excess Emissions (CEM)	Compliance	There were no excess emissions during the period. The monitor downtimes for both turbines was 1% or less, which is acceptable.
08/27/2015	ROP Semi 1 Cert	Compliance	

Name: Dale Turton Date: Jan 14, 2016 Supervisor: MD 1/15/2016