



# US Steel No. 1 Argon Stir Station Emissions Test Summary Report

**RECEIVED**  
JAN 20 2017  
AIR QUALITY DIV.

*Prepared for:*

**United States Steel Corporation**

Ecorse, Michigan

United States Steel Corporation  
Great Lakes Works  
No. 1 Quality Drive  
Ecorse, Michigan 48229

Project No. 16-4814.00  
January 13, 2017

BT Environmental Consulting, Inc.  
4949 Fernlee Avenue  
Royal Oak, Michigan 48073  
(248) 548-8070



MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY  
AIR QUALITY DIVISION

RECEIVED  
JAN 20 2018  
AIR QUALITY DIV.

### RENEWABLE OPERATING PERMIT REPORT CERTIFICATION

Authorized by 1994 P.A. 451, as amended. Failure to provide this information may result in civil and/or criminal penalties.

Reports submitted pursuant to R 336.1213 (Rule 213), subrules (3)(c) and/or (4)(c), of Michigan's Renewable Operating (RO) Permit program must be certified by a responsible official. Additional information regarding the reports and documentation listed below must be kept on file for at least 5 years, as described in General Condition No. 22 in the RO Permit and be made available to the Department of Environmental Quality, Air Quality Division upon request.

Source Name United States Steel Corporation Great Lakes Works County Wayne  
Source Address #1 Quality Drive City Ecorse  
AQD Source ID (SRN) A7809 RO Permit No. 199600132d RO Permit Section No. 1 & 5

Please check the appropriate box(es):

**Annual Compliance Certification (General Condition No. 28 and No. 29 of the RO Permit)**

Reporting period (provide inclusive dates): From \_\_\_\_\_ To \_\_\_\_\_

1. During the entire reporting period, this source was in compliance with ALL terms and conditions contained in the RO Permit, each term and condition of which is identified and included by this reference. The method(s) used to determine compliance is/are the method(s) specified in the RO Permit.

2. During the entire reporting period this source was in compliance with all terms and conditions contained in the RO Permit, each term and condition of which is identified and included by this reference, EXCEPT for the deviations identified on the enclosed deviation report(s). The method used to determine compliance for each term and condition is the method specified in the RO Permit, unless otherwise indicated and described on the enclosed deviation report(s).

**Semi-Annual (or More Frequent) Report Certification (General Condition No. 23 of the RO Permit)**

Reporting period (provide inclusive dates): From \_\_\_\_\_ To \_\_\_\_\_

1. During the entire reporting period, ALL monitoring and associated recordkeeping requirements in the RO Permit were met and no deviations from these requirements or any other terms or conditions occurred.

2. During the entire reporting period, all monitoring and associated recordkeeping requirements in the RO Permit were met and no deviations from these requirements or any other terms or conditions occurred, EXCEPT for the deviations identified on the enclosed deviation report(s).

**Other Report Certification**

Reporting period (provide inclusive dates): From Dec. 16, 2016 To Dec. 16, 2016

Additional monitoring reports or other applicable documents required by the RO Permit are attached as described:  
Submittal of No. 1 Argon Baghouse Stack Test Results from the December 18, 2016 Test.  
 \_\_\_\_\_  
 \_\_\_\_\_

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this report and the supporting enclosures are true, accurate and complete.

<u>Ronald Kostyo</u>	<u>General Manager</u>	<u>313-749-2210</u>
Name of Responsible Official (print or type)	Title	Phone Number
<u>Ronald Kostyo</u>		<u>1/19/2018</u>
Signature of Responsible Official		Date



**EXECUTIVE SUMMARY**

BT Environmental Consulting, Inc. (BTEC) was retained by United States Steel Corporation (U. S. Steel) to evaluate Particulate Matter (PM) emission rates from the EGARGON-STIR baghouse serving the No. 1 Argon Stir Station operations located at the U. S. Steel Great Lakes Works facility in Ecorse, Michigan. The testing is being performed as a compliance demonstration for permit No. 199600132d. The compliance test program was conducted on December 16, 2016. The purpose of this report is to document the results of the test program.

The results of the emission test program are summarized by Table I.

**RECEIVED**  
JAN 20 2017  
AIR QUALITY DIV.

**Table I**

**Executive Summary Table PM Emission Rate Summary**

<b>Source</b>	<b>Pollutant</b>	<b>Permit Limit</b>	<b>Result</b>
No. 1 Argon Stir Station	PM	0.02 gr/dscf	0.0002 gr/dscf
		1.4 lb/hr	0.04 lb/hr
		0.543 lb/heat	0.036 lb/heat

**Introduction**

BT Environmental Consulting, Inc. (BTEC) was retained by United States Steel Corporation (U. S. Steel) to evaluate Particulate Matter (PM) emission rates from the EGARGON-STIR baghouse serving the No. 1 Argon Stir Station operations located at the U. S. Steel Great Lakes Works facility in Ecorse, Michigan. The testing is being performed as a compliance demonstration for permit No. 199600132d. The compliance test program was conducted on December 16, 2016. The purpose of this report is to document the results of the test program.

AQD has published a guidance document entitled “Format for Submittal of Source Emission Test Plans and Reports” (December 2013). The following is a summary of the emissions test report in the format suggested by the AQD test plan format guide.

**1.a Identification, Location, and Dates of Test**

Sampling and analysis for the emission test program was conducted on December 16, 2016 at the U.S. Steel facility in Ecorse, Michigan. The test program included evaluation of particulate matter (PM) from the EGARGON-STIR baghouse serving the No. 1 Argon Stir Station operations.

**1.b Purpose of Testing**

The testing was performed as a compliance demonstration for permit No. 199600132d. Table 1 summarizes the limitations included in this permit.

**Table 1  
AQD Permit No. 199600132d Emission Limitations Summary**

<b>Source</b>	<b>Pollutant</b>	<b>Permit Limit</b>
No. 1 Argon Stir Station	PM	0.02 gr/dscf
		1.4 lb/hr
		3.04 ton/yr
		0.543 lb/heat

**1.c Source Description**

The No.2 Basic Oxygen Processing (BOP) is a facility that converts liquid iron to liquid steel. The No.2 BOP has two top-blown conversion vessels along with other ancillary equipment. The liquid iron and steel scrap is charged in the vessels and oxygen is blown into the mixture for mixing, removal of carbon and other impurities. The now liquid steel is sometimes further process in the No.2 BOP, which may include argon stirring. After any further process is completed, steel is conveyed to the Casters where the liquid steel is cast into a continuous solid steel slab.



Argon stirring occurs after the conversion process, when it is necessary to distribute heat evenly in the liquid steel or alloy addition to the liquid steel prior to Casting. The argon stirring produces a higher quality liquid steel product. Argon stirring is also necessary when the Caster is not ready to receive liquid steel.

The ladle is placed into the Argon Stirring Station by overhead crane, and an exhaust capture hood is moved into place over the ladle. An argon-stirring lance is then lowered, and argon is injected as required.

#### 1.d Test Program Contact

The contact for the source and test plan is:

Mr. Todd Wessel  
Senior Project Manager  
BT Environmental Consulting, Inc.  
4949 Fernlee Avenue  
Royal Oak, Michigan 48073  
Phone (616) 885-4013

Mr. Nathan Ganhs  
U. S. Steel Environmental  
United States Steel Corporation  
No. 1 Quality Drive  
Ecorse, Michigan 48192  
Phone (313) 749 3857

#### 1.e Testing Personnel

Names and affiliations for personnel who were present during the testing program are summarized by Table 2.

**Table 2**  
**Test Personnel**

Name and Title	Affiliation	Telephone
Mr. Nathan Ganhs U. S. Steel Environmental	U.S. Steel No. 1 Quality Drive Ecorse, Michigan 48229	(313) 749-3857
Mr. Paul Diven Project Manager	BTEC 4949 Fernlee Avenue Royal Oak, MI 48073	(248) 548-8072
Mr. Mason Sakshaug Environmental Technician	BTEC 4949 Fernlee Avenue Royal Oak, MI 48073	(248) 548-8072



## **2. Summary of Results**

Sections 2.a through 2.d summarize the results of the emissions compliance test program.

### **2.a Operating Data**

Relevant operating data is available in Appendix E.

### **2.b Applicable Permit**

Michigan Renewable Operating Permit Number 199600132d.

### **2.c Results**

The overall results of the emission test program are summarized by Table 3 (see Section 5.a). Detailed results for each run can be found in table 4.

### **2.d Emission Regulation Comparison**

The results are summarized by Table 3 (section 5.a). Emission limits are summarized by Table 1 (section 1.b) and also in Table 3 (section 5.a).

## **3. Source Description**

Sections 3.a through 3.e provide a detailed description of the process.

### **3.a Process Description**

See section 1.c.

### **3.b Raw and Finished Materials**

Typical batches consist of 240-250 tons of liquid steel. Additional alloys and flux is added as needed.

### **3.c Process Capacity**

The No.1 Argon Stir Station can process a maximum of 13,505 heats per year of operation.

### **3.d Process Instrumentation**

The process stack data will consist of the sequence number and the timing of process.

#### 4. Sampling and Analytical Procedures

Sections 4.a through 4.d provide a summary of the sampling and analytical procedures used.

##### 4.a Sampling Train and Field Procedures

Measurement of exhaust gas velocity, molecular weight, and moisture content was conducted using the following reference test methods codified at Title 40, Part 60, Appendix A of the Code of Federal Regulations (40 CFR 60, Appendix A):

- Method 1 - *“Sample and Velocity Traverses for Stationary Sources”*
- Method 2 - *“Determination of Stack Gas Velocity and Volumetric Flowrate”*
- Method 3 - *“Gas Analysis for the Determination of Dry Molecular Weight” (Fyrite Analysis)*
- Method 4 - *“Determination of Moisture Content in Stack Gases”*
- Method 17 - *“Determination of Particulate Emissions from Stationary Sources”*

Stack gas velocity traverses were conducted in accordance with the procedures outlined in Methods 1 and 2. Figure 1 presents the test port and traverse/sampling point locations used. An S-type pitot tube and thermocouple assembly calibrated in accordance with Method 2, Section 4.1.1 was used to measure exhaust gas velocity pressures and temperatures during testing. Because the pitot tube dimensions outlined in Sections 2-6 through 2-8 were within the specified limits, the baseline pitot tube coefficient of 0.84 (dimensionless) was assigned for this testing.

Cyclonic flow checks were performed at the sampling location. The existence of cyclonic flow is determined by measuring the flow angle at each sample point. The flow angle is the angle between the direction of flow and the axis of the stack. If the average of the absolute values of the flow angles is greater than 20 degrees, cyclonic flow exists. The null angle was determined to be less than 10 degrees at each sampling point.

Molecular weight determinations were evaluated according to USEPA Method 3, “Gas Analysis for the Determination of Dry Molecular Weight.” The equipment used for this evaluation consisted of a one-way squeeze bulb with connecting tubing and a set of Fyrite<sup>®</sup> combustion gas analyzers. Carbon dioxide and oxygen content were analyzed using the Fyrite<sup>®</sup> procedure.

Exhaust gas moisture content was evaluated using Method 4. Exhaust gas was extracted as part of the PM sampling train and passed through (i) two impingers, each with 100 ml deionized water, (ii) an empty impinger, and (iii) an impinger filled with silica gel. Exhaust gas moisture content is then determined gravimetrically. The sampling train for Runs 2-4 was modified by removing impingers 1-3.

40 CFR 60, Appendix A, Method 17, *“Determination of Particulate Emissions from Stationary Sources”* was used to measure PM concentrations and calculate PM emission

rates (see Figure 2 for a schematic of the sampling train). Triplicate 60-minute test runs were conducted on the No. 1 Argon Stir Station Stack.

BTEC's Nutech<sup>®</sup> Model 2010 modular isokinetic stack sampling system consisted of (1) a stainless-steel nozzle, (2) an in stack stainless-steel filter housing, (3) a steel probe, (4) a set of four Greenburg-Smith (GS) impingers with the first modified and second standard GS impingers each containing 100 ml of deionized water, and with a third dry modified GS impinger and a fourth modified GS impinger containing approximately 300 g of silica gel desiccant, (5) a length of sample line, and (6) a Nutech<sup>®</sup> control case equipped with a pump, dry gas meter, and calibrated orifice. The sampling train for Runs 2-4 was modified by removing impingers 1-3.

A sampling train leak test was conducted before and after each test run. After completion of the final leak test for each test run, the filter was recovered, and the nozzle and the front half of the filter holder assembly were brushed and triple rinsed with acetone. The acetone rinses were collected in a pre-cleaned sample container.

BTEC labeled each container with the test number, test location, and test date, and marked the level of liquid on the outside of the container. In addition blank samples of the acetone and filter were collected. BTEC personnel carried all samples to BTEC's laboratory (for filter and acetone gravimetric analysis) in Royal Oak, Michigan.

#### 4.b Recovery and Analytical Procedures

Recovery and analytical procedures were described in Section 4.a.

#### 4.c Sampling Ports

Sampling ports are located on the No. 1 Argon Stir Station exhaust duct and meet method 1 criteria.

#### 4.d Traverse Points

Sampling port and traverse point locations for the No. 1 Argon Stir Station exhaust stack is illustrated by Figure 1.

### 5. Test Results and Discussion

Sections 5.a through 5.k provide a summary of the test results.

RECEIVED  
JAN 20 2017  
AIR QUALITY DIV

### 5.a Results Tabulation

The results of the emissions test program are summarized by Table 3.

**Table 3**  
**Test Program PM Emission Rate Summary**

Source	Pollutant	Permit Limit	Result
No. 1 Argon Stir Station	PM	0.02 gr/dscf	0.0002 gr/dscf
		1.4 lb/hr	0.04 lb/hr
		0.543 lb/heat	0.036 lb/heat

Detailed data for each test run can be found in Table 4.

### 5.b Discussion of Results

Emission limitations for Permit No. 199600132d are summarized by Table 1 (see section 1.b) and Table 3 (see section 5.a). The results of the emissions test program are summarized by Table 3 (see section 5.a).

### 5.c Sampling Procedure Variations

Run 1 failed the post test leak check and was voided, and an additional test run was performed.

The sampling train for Runs 2-4 was modified by removing impingers 1-3. This was due to the low ambient temperature and the lack of moisture in the exhaust gas. Tom Gasloli was on site and approved the modification.

### 5.d Process or Control Device Upsets

No upset conditions occurred during testing.

### 5.e Control Device Maintenance

No maintenance was performed during the test program.

### 5.f Audit Sample Analyses

No audit samples were collected as part of the test program.

### 5.g Calibration Sheets

Relevant equipment calibration documents are provided as Appendix B.



**RECEIVED**

JAN 20 2017

**AIR QUALITY DIV.**

**5.h Sample Calculations**

Sample calculations are provided in Appendix C.

**5.i Field Data Sheets**

Field documents relevant to the emissions test program are presented in Appendix A.

**5.j Laboratory Data**

Laboratory results for this test program are provided in Appendix D.

**Table 4**  
**No. 1 Argon Stir Station Particulate Matter Emission Rates**

Company Source Designation Test Date	US Steel #1 Argon			Average
	12/16/2016	12/16/2016	12/16/2016	
<b>Meter/Nozzle Information</b>				
Meter Temperature Tm (F)	33.1	35.8	37.4	35.4
Meter Pressure - Pm (in. Hg)	29.8	29.8	29.8	29.8
Measured Sample Volume (Vm)	44.5	43.7	43.3	43.8
Sample Volume (Vm-Std ft3)	47.7	46.7	46.0	46.8
Sample Volume (Vm-Std m3)	1.35	1.32	1.30	1.33
Condensate Volume (Vw-std)	0.283	0.141	0.141	0.189
Gas Density (Ps(std) lbs/ft3) (wet)	0.0744	0.0744	0.0744	0.0744
Gas Density (Ps(std) lbs/ft3) (dry)	0.0745	0.0745	0.0745	0.0745
Total weight of sampled gas (m g lbs) (wet)	3.57	3.48	3.44	3.50
Total weight of sampled gas (m g lbs) (dry)	3.56	3.48	3.43	3.49
Nozzle Size - An (sq. ft.)	0.000327	0.000327	0.000327	0.000327
Isokinetic Variation - I	99.3	98.8	98.8	99.0
Total Test Time(minutes) <sup>1</sup>	60	60	60	60.0
<b>Production Data</b>				
Heats / Run <sup>2</sup>	1.0	2.0	2.0	1.7
<b>Stack Data</b>				
Average Stack Temperature - Ts (F)	70.6	84.4	96.3	83.8
Molecular Weight Stack Gas- dry (Md)	28.8	28.8	28.8	28.8
Molecular Weight Stack Gas-wet (Ms)	28.8	28.8	28.8	28.8
Stack Gas Specific Gravity (Gs)	0.995	0.995	0.995	0.995
Percent Moisture (Bws)	0.59	0.30	0.31	0.40
Water Vapor Volume (fraction)	0.0059	0.0030	0.0031	0.0040
Pressure - Ps ("Hg)	29.7	29.7	29.7	29.7
Average Stack Velocity -Vs (ft/sec)	41.5	41.8	42.1	41.8
Area of Stack (ft2)	9.3	9.3	9.3	9.3
<b>Exhaust Gas Flowrate</b>				
Flowrate ft <sup>3</sup> (Actual)	23,114	23,254	23,434	23,267
Flowrate ft <sup>3</sup> (Standard Wet)	22,816	22,372	22,062	22,416
Flowrate ft <sup>3</sup> (Standard Dry)	22,681	22,304	21,994	22,327
Flowrate m <sup>3</sup> (standard dry)	642	632	623	632
<b>Total Particulate Weights (mg)</b>				
Nozzle/Probe/Filter	1.4	0.6	0.0	0.7
<b>Total Particulate Concentration</b>				
lb/1000 lb (wet)	0.001	0.000	0.000	0.000
lb/1000 lb (dry)	0.001	0.000	0.000	0.000
mg/dscm (dry)	1.0	0.5	0.0	0.5
lb/dscf (dry)	6.47E-08	2.83E-08	0.00E+00	3.10E-08
gr/dscf	0.0005	0.0002	0.0000	0.0002
<b>Total Particulate Emission Rate</b>				
lb/ hr	0.09	0.04	0.00	0.04
lb/ heat <sup>2</sup>	0.088	0.019	0.000	0.036

1: Total Test Time = Total sampling time of test (minutes)



2: Please see Production data in Appendix E for a summary of Heats/Run

3: lb/ heat calculated using "lb / hr"

$$(\text{lb/hr}) * (1 \text{ hr} / 60 \text{ minutes}) * (\text{Total Test Time}) / (\text{Heats/Run}) = \text{lb/heat}$$



diameter = 41.25 inches



Not to Scale

Points	Distance "
1	1.8
2	6.0
3	12.2
4	29.0
5	35.2
6	39.4

Figure No. 1

Site:  
No. 1 Argon  
US Steel  
Ecorse, Michigan

Sampling Date:  
December 16, 2016

**BT Environmental Consulting, Inc.**  
4949 Fernlee Avenue  
Royal Oak, Michigan 48073

**BTEC Inc.**




Figure No. 1

Site:  
USEPA Method 17  
US Steel  
Ecorse, Michigan

Sampling Date:  
December 16, 2016

BT Environmental Consulting, Inc.  
4949 Fernlee Avenue  
Royal Oak, Michigan 48073

AIR QUALITY DIV

JAN 20 2017

RECEIVED