



Marathon Petroleum Company LP
1300 South Fort Street
Detroit, Michigan 48217

RECEIVED

JUN 10 2016

AIR QUALITY DIV.

REPORT ON RATA & COMPLIANCE TESTING

Performed for:
**MARATHON PETROLEUM COMPANY LP
DETROIT REFINERY**

B&W BOILER STACK (SV-B&WBOILER1)

Client Reference No: 4100665755
CleanAir Project No: 12964-1
Revision 0: June 2, 2016

To the best of our knowledge, the data presented in this report are accurate, complete, error free and representative of the actual emissions during the test program. Clean Air Engineering operates in conformance with the requirements of ASTM D7036-04 Standard Practice for Competence of Air Emission Testing Bodies.

Submitted by,

Andy Obuchowski
Midwest Engineering Group Leader
aobuchowski@cleanair.com
(800) 627-0033 ext. 4537

Reviewed by,

Dan Pearson
Project Engineer
dpearson@cleanair.com
(800) 627-0033 ext. 4674

REVISION HISTORY

REPORT ON RATA & COMPLIANCE TESTING

DRAFT REPORT REVISION HISTORY

Revision:	Date	Pages	Comments
D0a	05/26/16	All	Draft version of original document.

FINAL REPORT REVISION HISTORY

Revision:	Date	Pages	Comments
0	06/02/16	All	Final version of original document.

PROJECT OVERVIEW

1-1

INTRODUCTION

Marathon Petroleum Company LP (MPC) contracted Clean Air Engineering (CleanAir) to perform emissions measurements at the Detroit Refinery as part of a relative accuracy test audit (RATA) and for compliance purposes.

All testing was conducted in accordance with the regulations set-forth by the United States Environmental Protection Agency (USEPA) and the Michigan Department of Environmental Quality (DEQ). The permit limits are referenced in the DEQ, Air Quality Division Permit to Install No. 63-08D, issued May 12, 2014.

Key Project Participants

Individuals responsible for coordinating and conducting the test program were:

Crystal Davis – MPC
Joe Reidy – MPC
Andy Obuchowski – CleanAir
Medel Cendana – CleanAir

Test Program Parameters

The testing was performed at the B&W Boiler Stack (Emission Unit ID No. EU27-B&WBOILER1-S1; Stack ID No. SV-B&WBoiler1) on April 11 and 12, 2016, and included the following emissions measurements:

- particulate matter (PM), assumed equivalent to filterable particulate matter (FPM) only
- sulfuric acid (H₂SO₄)
- volatile organic compounds (VOC), assumed equivalent to total hydrocarbons (THC) minus the following constituents:
 - methane (CH₄)
 - ethane (C₂H₆)
- nitrogen oxide (NO_x)
- carbon monoxide (CO)
- flue gas composition (e.g., O₂, CO₂, H₂O)
- flue gas flow rate

RECEIVED
JUN 1 0 2016
AIR QUALITY DIV.

PROJECT OVERVIEW

1-2

TEST PROGRAM SYNOPSIS**Test Schedule**

The on-site schedule followed during the test program is outlined in Table 1-1.

**Table 1-1:
Schedule of Activities**

Run Number	Location	Method	Analyte	Date	Start Time	End Time
1	B&W Boiler Stack	USEPA Method 5	FPM	04/11/16	13:48	15:56
2	B&W Boiler Stack	USEPA Method 5	FPM	04/11/16	17:06	19:11
3	B&W Boiler Stack	USEPA Method 5	FPM	04/12/16	08:15	10:24
1	B&W Boiler Stack	USEPA Methods 3A/7E/10	O ₂ /CO ₂ /NO _x /CO	04/11/16	12:40	13:01
2	B&W Boiler Stack	USEPA Methods 3A/7E/10	O ₂ /CO ₂ /NO _x /CO	04/11/16	13:15	13:36
3	B&W Boiler Stack	USEPA Methods 3A/7E/10	O ₂ /CO ₂ /NO _x /CO	04/11/16	13:45	14:06
4	B&W Boiler Stack	USEPA Methods 3A/7E/10	O ₂ /CO ₂ /NO _x /CO	04/11/16	14:16	14:37
5	B&W Boiler Stack	USEPA Methods 3A/7E/10	O ₂ /CO ₂ /NO _x /CO	04/11/16	14:49	15:10
6	B&W Boiler Stack	USEPA Methods 3A/7E/10	O ₂ /CO ₂ /NO _x /CO	04/11/16	15:19	15:40
7	B&W Boiler Stack	USEPA Methods 3A/7E/10	O ₂ /CO ₂ /NO _x /CO	04/11/16	15:50	16:11
8	B&W Boiler Stack	USEPA Methods 3A/7E/10	O ₂ /CO ₂ /NO _x /CO	04/11/16	16:20	16:41
9	B&W Boiler Stack	USEPA Methods 3A/7E/10	O ₂ /CO ₂ /NO _x /CO	04/11/16	16:56	17:17
10	B&W Boiler Stack	USEPA Methods 3A/7E/10	O ₂ /CO ₂ /NO _x /CO	04/11/16	17:29	17:50
1	B&W Boiler Stack	USEPA Methods 3A/18/25A	O ₂ /CO ₂ /CH ₄ /C ₂ H ₆ /THC	04/12/16	09:44	10:20
2	B&W Boiler Stack	USEPA Methods 3A/18/25A	O ₂ /CO ₂ /CH ₄ /C ₂ H ₆ /THC	04/12/16	12:06	13:09
3	B&W Boiler Stack	USEPA Methods 3A/18/25A	O ₂ /CO ₂ /CH ₄ /C ₂ H ₆ /THC	04/12/16	14:09	15:12
4	B&W Boiler Stack	USEPA Methods 3A/18/25A	O ₂ /CO ₂ /CH ₄ /C ₂ H ₆ /THC	04/12/16	16:20	17:23
0	B&W Boiler Stack	Draft ASTM CCM	Sulfuric Acid	04/12/16	12:20	13:20
1	B&W Boiler Stack	Draft ASTM CCM	Sulfuric Acid	04/12/16	14:21	15:21
2	B&W Boiler Stack	Draft ASTM CCM	Sulfuric Acid	04/12/16	16:20	17:20
3	B&W Boiler Stack	Draft ASTM CCM	Sulfuric Acid	04/12/16	18:04	19:04

0524 16 113411

PROJECT OVERVIEW

1-3

Results Summary

Tables 1-2 and 1-3 summarize the results of the test program. A more detailed presentation of the test conditions and results of analysis are shown on pages 2-1 through 2-11.

**Table 1-2:
Summary of Emission Compliance Test Results**

Source	Constituent	(Units)	Sampling Method	Average Emission	Permit Limit ¹
<i>B&W Boiler Stack</i>					
	PM	(lb/MMBtu)	USEPA 5	0.0011	0.0019
	H ₂ SO ₄	(ppm dv)	Draft ASTM CCM	0.14	N/A
	H ₂ SO ₄	(lb/MMBtu)	Draft ASTM CCM	0.00047	N/A
	VOC	(lb/MMBtu)	USEPA 25A / 18	<0.00064	0.0055
	NO _x	(lb/MMBtu)	USEPA 7E	0.06	0.20
	CO	(lb/MMBtu)	USEPA 10	0.04	0.04

¹ Permit limits obtained from MDEQ Permit to Install No. 63-08D.

052416 144915

**Table 1-3:
Summary of RATA Results**

Source	Constituent (Units)	Reference Method	Relative Accuracy (%) ¹	Applicable Specification	Standard Used	Specification Limit
<i>B&W Boiler Stack</i>						
	O ₂ (% dv)	USEPA 3A	0.1	40 CFR 75, APP. A	abs. diff.	± 1.0%
	NO _x (lb/MMBtu)	USEPA 7E	6.5	40 CFR 75, APP. A	% of RM	10%
	CO (lb/MMBtu)	USEPA 10	6.0	40 CFR 60, APP. B PS4A	% of RM	10%

¹ Relative Accuracy is expressed in terms of comparison to the reference method (% RM) or avg. absolute difference. The specific expression used depends on the specification limit cited.

052416 146259

PROJECT OVERVIEW

1-4

Discussion of Test Program***FPM Testing - USEPA Method 5***

For this test program, PM emission rate is assumed equivalent to FPM emission rate. Three 120-minute Method 5 test runs were performed on April 11 and 12, 2016. The final result was expressed as the average of three valid runs.

H₂SO₄ Testing - Draft ASTM Controlled Condensation Method

Three 60-minute test runs were performed on April 12, 2016. The final result was expressed as the average of three valid runs.

VOC Testing – USEPA Methods 25A and 18

During Method 25A/18 Run 1 the flame on the analyzer switched off causing the run to be aborted. Run 1 was not used in the final result calculations.

Subsequently three 63-minute Method 25A test runs for THC were performed concurrently with three 63-minute Method 18 bag collections for CH₄ and C₂H₆. The final results for each parameter were expressed as the average of three valid runs.

The VOC emission rate is normally equivalent to THC emission rate, minus CH₄ and C₂H₆ emission rate. The calculated emission rate of CH₄ and C₂H₆ detected through analysis of each Method 18 sample bag exceeded the amount of THC measured by the on-line THC analyzer.

This is likely due to variations in the calibration standards, measurement and analytical technique. Therefore, VOC emissions are reported as a value “less than” 1% of the calibration span of THC instrument. The final results were calculated using the average of three valid test runs, all using a concentration of 1% of the instrument span and reported as “less than” the amount.

CEMS RATA System Overview

The B&W Boiler is capable of operating at a maximum heat input capacity greater than 250 MMBtu/hour. Boilers with a heat input capacity greater than 250 MMBtu/hour are required to operate in compliance with the Clean Air Interstate Rule (CAIR). CAIR requires monitoring and reporting of NO_x emissions using continuous emissions monitoring systems (CEMS) operated in accordance with the requirements of 40 CFR Part 75.

PROJECT OVERVIEW

1-5

The RATA for NO_x and O₂ was conducted per 40 CFR, Part 75.

The RATA for CO was conducted per 40 CFR 60, Appendix B Performance Specification 4A.

Pre-RATA QA/QC

Prior to conducting the RATA, MPC performed a linearity test which will be reported separately.

RATA Testing – USEPA Methods 3A, 7E and 10

All tests were completed while the facility CEMS was operated in a ‘hands off’ manner. The boiler was operated at its normal steam load, as that term is defined in 40 CFR part 75 Appendix A. The ‘normal’ load is the mid-range of operation, or a steam production rate between 50,000 and 152,000 pounds per hour.

Minute-average data points for O₂, NO_x and CO (dry basis) were collected over a period of 21 minutes for each RATA reference method (RM) run. The average CO result for each RM run was calculated and compared to the average CO result from the facility CEMS over identical intervals in order to calculate relative accuracy (RA).

The facility CEMS data acquisition system used for NO_x (Cirrus System) is different than the “normal” data acquisition system used for CO. Following testing, CleanAir was notified that the Cirrus system is restricted to taking a reading every hour on the hour. This disallowed comparing the facility and RM NO_x results over identical intervals. As advised by MPC, CleanAir compared the respective 21-minute RM runs to the most concurrent facility hour data set.

In addition, the facility Cirrus System does not use daylight savings time while all other times referenced in the report do use daylight savings time. This was taken into consideration when comparing RM results and facility results.

A total of 10 RATA runs were performed. In lieu of performing a stratification test, sampling was performed at the three points along the “long measurement line” described in 40 CFR 60, Appendix B, PS2, §8.1.3 (16.7, 50.0 and 83.3% of the way across the stack) for each test run.

PROJECT OVERVIEW

1-6

Bias tests were performed on all of the NO_x RATA data sets. The CEMS data was found to be biased high in comparison to the RM data in all instances. Since the mean difference between the RM and CEMS data was less than or equal to the absolute value of the confidence coefficient for all runs, the CEMS passed the bias test and a bias adjustment factor (BAF) was not applied to any of the emissions results. Per 40 CFR Part 75, bias is only applicable when the CEMS data is biased low in relation to the RM data.

RM NO_x and CO RATA results were also presented to demonstrate compliance with permit limits. The final result was expressed as the average of all 10 RATA runs.

Calculation of Final Results

Emission results in units of dry volume-based concentration (lb/dscf, ppm_{dv}) were converted to units of pounds per million Btu (lb/MMBtu) by calculating a combination oxygen-based fuel factor (F_d) for natural gas and refinery gas per USEPA Method 19 specifications.

- For natural gas, the volume-based gross heat content (GCV_v) was obtained from a gas analysis report provided by MPC. The natural gas F_d factor was obtained from 40 CFR Part 75, Appendix F, Table 1. This approach should yield worst-case calculated emission results.
- For refinery gas, the heat content and F_d factor were calculated from percent volume composition analytical data provided by MPC and tabulated heating values for each of the measured constituents.

End of Section 1 – Project Overview

RESULTS**Table 2-1:
B&W Boiler Stack – FPM Emissions (USEPA 5)**

Run No.		1	2	3	Average
Date (2016)		Apr 11	Apr 11	Apr 12	
Start Time (approx.)		13:48	17:06	08:15	
Stop Time (approx.)		15:56	19:11	10:24	
Process Conditions					
R _p	Steam production (Mlb/hr)	117	117	116	117
P ₁	Fuel gas flow rate (Mscf/day)	3,357	3,401	3,578	3,445
P ₂	Natural gas flow rate (Mscf/day)	289	302	391	327
F _d	Oxygen-based F-factor (dscf/MMBtu)	8,380	8,380	8,376	8,379
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760
Gas Conditions					
O ₂	Oxygen (dry volume %)	8.6	8.7	8.7	8.7
CO ₂	Carbon dioxide (dry volume %)	7.1	7.0	7.0	7.0
T _s	Sample temperature (°F)	335	337	338	337
B _w	Actual water vapor in gas (% by volume)	14.3	14.1	14.1	14.2
Gas Flow Rate					
Q _a	Volumetric flow rate, actual (acfm)	71,800	70,500	70,100	70,800
Q _s	Volumetric flow rate, standard (scfm)	46,100	45,100	45,600	45,600
Q _{std}	Volumetric flow rate, dry standard (dscfm)	39,500	38,800	39,200	39,100
Q _a	Volumetric flow rate, actual (acf/hr)	4,310,000	4,230,000	4,210,000	4,250,000
Q _s	Volumetric flow rate, standard (scf/hr)	2,760,000	2,710,000	2,730,000	2,740,000
Q _{std}	Volumetric flow rate, dry standard (dscf/hr)	2,370,000	2,330,000	2,350,000	2,350,000
Sampling Data					
V _{std}	Volume metered, standard (dscf)	65.97	64.95	67.12	66.02
%I	Isokinetic sampling (%)	99.5	99.7	102.1	100.4
Laboratory Data					
m _{filter}	Matter collected on filter(s) (g)	0.00104	0.00078	0.00118	
m _s	Matter collected in solvent rinse(s) (g)	0.00132	0.00126	0.00118	
m _n	Total FPM (g)	0.00236	0.00204	0.00236	
n _{MDL}	Number of non-detectable fractions	N/A	N/A	N/A	
DLC	Detection level classification	ADL	ADL	ADL	
FPM Results					
C _{sd}	Particulate Concentration (lb/dscf)	7.89E-08	6.93E-08	7.75E-08	7.52E-08
E _{lb/hr}	Particulate Rate (lb/hr)	0.187	0.161	0.182	0.177
E _{T/yr}	Particulate Rate (Ton/yr)	0.818	0.706	0.798	0.774
E _{Fd}	Particulate Rate - F _d -based (lb/MMBtu)	1.12E-03	9.94E-04	1.11E-03	1.08E-03

Average includes 3 runs.

052418 155352

Detection level classifications are defined as follows:

ADL = Above Detection Level - all fractions are above detection limit

DLL = Detection Level Limited - some fractions are below detection limit

BDL = Below Detection Limit - all fractions are below detection limit

RESULTS**Table 2-2:
Uncertainty Analysis – FPM (USEPA 5)**

	FPM Results (lb/MMBtu)		FPM Results (lb/hr)		FPM Results (Ton/yr)	
Method	5		5		5	
Run No.	1	1.12E-03	1	0.187	1	0.818
	2	9.94E-04	2	0.161	2	0.706
	3	1.11E-03	3	0.182	3	0.798
SD	7.15E-05		0.0137		0.0599	
AVG	1.08E-03		0.1767		0.7740	
RSD	6.6%		7.7%		7.7%	
N	3		3		3	
SE	4.13E-05		0.0079		0.0346	
RSE	3.8%		4.5%		4.5%	
P	95.0%		95.0%		95.0%	
TINV	4.303		4.303		4.303	
CI +	1.25E-03		0.2107		0.9227	
AVG	1.08E-03		0.1767		0.7740	
CI -	8.99E-04		0.1428		0.6253	
TB +	1.62E-03		0.2814		1.2323	

AVG (average) is the mean value of the runs; N is the number of individual runs.

SD (standard deviation) and RSD (relative standard deviation) are measures of the variability of individual runs.

SE (standard error) and RSE (relative standard error) are measures of the variability of the average of the runs.

P (probability) is the confidence level associated with the two-tailed Student's t-distribution.

TINV (t-value) is the value of the Student's t-distribution as a function of P (probability) and N-1 (degrees of freedom).

CI (confidence interval) indicates that if the test is conducted again under the same conditions, the average would be expected to fall within the interval (CI- to CI+) about 95% of the time.

TB+ (upper tolerance bound) is the value below which 95% of future runs are expected to fall (assuming testing at the same conditions).

RESULTS**Table 2-3:
B&W Boiler Stack – H₂SO₄ Emissions (Draft ASTM CCM)**

Run No.		1	2	3	Average
Date (2016)		Apr 12	Apr 12	Apr 12	
Start Time (approx.)		14:21	16:20	18:04	
Stop Time (approx.)		15:21	17:20	19:04	
Process Conditions					
R _p	Steam Production (Mlb/hr)	117	123	126	122
P ₁	Fuel gas flow rate (Mscf/day)	3,548	3,530	3,528	3,535
P ₂	Natural gas flow rate (Mscf/day)	365	358	352	359
F _d	Oxygen-based F-factor (dscf/MMBtu)	8,374	8,373	8,373	8,373
Gas Conditions					
O ₂	Oxygen (dry volume %)	7.9	7.9	7.7	7.8
CO ₂	Carbon dioxide (dry volume %)	7.6	7.6	7.7	7.6
T _s	Sample temperature (°F)	315	320	322	319
B _w	Actual water vapor in gas (% by volume)	14.8	14.1	15.0	14.6
Sampling Data					
V _{mstd}	Volume metered, standard (dscf)	26.00	27.53	25.06	26.19
Laboratory Data (Ion Chromatography)					
m _n	Total H ₂ SO ₄ collected (mg)	0.3675	0.5490	0.3317	
Sulfuric Acid Vapor (H₂SO₄) Results					
C _{sd}	H ₂ SO ₄ Concentration (lb/dscf)	3.12E-08	4.40E-08	2.92E-08	3.48E-08
C _{sd}	H ₂ SO ₄ Concentration (ppmdv)	0.123	0.173	0.115	0.137
E _{Fd}	H ₂ SO ₄ Rate - Fd-based (lb/MMBtu)	4.20E-04	5.92E-04	3.87E-04	4.66E-04

Average includes 3 runs.

05116 124923

RESULTS**Table 2-4:
Uncertainty Analysis – H₂SO₄ (Draft ASTM CCM)**

Method Run No.	H2SO4 Results (ppmdv)		H2SO4 Results (lb/MMBtu)	
		CCM		CCM
1		0.1225	1	4.20E-04
2		0.1728	2	5.92E-04
3		0.1147	3	3.87E-04
SD		3.15E-02		1.10E-04
AVG		0.1367		4.66E-04
RSD		23.1%		23.6%
N		3		3
SE		1.82E-02		6.36E-05
RSE		13.3%		13.6%
P		95.0%		95.0%
TINV		4.303		4.303
CI +		0.2150		7.40E-04
AVG		0.1367		4.66E-04
CI -		0.0584		1.93E-04
TB +		0.378		1.31E-03

AVG (average) is the mean value of the runs; N is the number of individual runs.

SD (standard deviation) and RSD (relative standard deviation) are measures of the variability of individual runs.

SE (standard error) and RSE (relative standard error) are measures of the variability of the average of the runs.

P (probability) is the confidence level associated with the two-tailed Student's t-distribution.

TINV (t-value) is the value of the Student's t-distribution as a function of P (probability) and N-1 (degrees of freedom).

CI (confidence interval) indicates that if the test is conducted again under the same conditions, the average would be expected to fall within the interval (CI- to CI+) about 95% of

TB+ (upper tolerance bound) is the value below which 95% of future runs are expected to fall (assuming testing at the same conditions).

RESULTS**Table 2-5:
B&W Boiler Stack – THC, CH₄, C₂H₆ and VOC Emissions (USEPA 25A / 18)**

Run No. ¹		2	3	4	Average
Date (2016)		Apr 12	Apr 12	Apr 12	
Start Time (approx.)		12:06	14:09	16:20	
Stop Time (approx.)		13:09	15:12	17:23	
Process Conditions					
R _p	Steam Production (Mlb/hr)	118	118	123	120
P ₁	Fuel gas flow rate (Mscf/day)	3,545	3,553	3,529	3,542
P ₂	Natural gas flow rate (Mscf/day)	372	365	358	365
F _a	Oxygen-based F-factor (dscf/MMBtu)	8,374	8,374	8,373	8,374
Gas Conditions					
O ₂	Oxygen (dry volume %)	8.0	7.9	7.8	7.9
CO ₂	Carbon dioxide (dry volume %)	7.5	7.6	7.8	7.6
B _w	Actual water vapor in gas (% by volume) ²	13.8	14.8	14.1	14.2
THC Results					
C _{sd}	Concentration (ppm dv as C ₃ H ₈)	2.71	2.43	2.21	2.45
C _{sd}	Concentration (lb/dscf)	3.11E-07	2.78E-07	2.53E-07	2.80E-07
E _{Fd}	Emission Rate - F _d -based (lb/MMBtu)	4.21E-03	3.74E-03	3.38E-03	3.78E-03
Methane Results					
C _{sd}	Concentration (ppm dv)	6.05	5.37	4.66	5.36
C _{sd}	Concentration (lb/dscf)	2.52E-07	2.24E-07	1.94E-07	2.23E-07
E _{Fd}	Emission Rate - F _d -based (lb/MMBtu)	3.41E-03	3.01E-03	2.59E-03	3.00E-03
Ethane Results					
C _{sd}	Concentration (ppm dv)	<0.0875	<0.0875	<0.0875	<0.0875
C _{sd}	Concentration (lb/dscf)	<6.83E-09	<6.83E-09	<6.83E-09	<6.83E-09
E _{Fd}	Emission Rate - F _d -based (lb/MMBtu)	<9.25E-05	<9.20E-05	<9.12E-05	<9.19E-05
VOC Results					
E _{Fd}	Emission Rate - F _d -based (lb/MMBtu)	<6.46E-04	<6.43E-04	<6.38E-04	<6.42E-04

Average includes 3 runs.

0804 10 15452B

¹ Run 1 was invalidated 20 minutes into the test run when the flame went out in the JUM 3-500 FID analyzer.² Moisture data used for ppm_{wv} to ppm_{dv} correction obtained from nearly-concurrent CCM runs.

For methane and ethane, '<' indicates a measured response below the analytical detection limit determined by the laboratory. For VOCs, '<' indicates a measured/calculated response below the detection limit (assumed to be 1% of the instrument calibration span).

RESULTS**Table 2-6:
B&W Boiler Stack – NO_x and CO Emissions (USEPA 7E, 10)**

Run No.		1	2	3	4	5	6
Date (2016)		Apr 11					
Start Time (approx.)		12:40	13:15	13:45	14:16	14:49	15:19
Stop Time (approx.)		13:01	13:36	14:06	14:37	15:10	15:40
Process Conditions							
R _P	Steam Production (Kib/hr)	115	117	117	116	116	117
P ₁	Fuel gas flow rate (kscf/hr)	140	140	140	140	140	140
P ₂	Natural gas flow rate (kscf/hr)	11.8	11.8	11.8	11.8	11.8	11.8
F _d	Oxygen-based F-factor (dscf/MMBtu)	8,379	8,379	8,379	8,379	8,379	8,379
Gas Conditions							
O ₂	Oxygen (dry volume %)	8.5	8.6	8.6	8.6	8.6	8.6
CO ₂	Carbon dioxide (dry volume %)	7.4	7.3	7.3	7.2	7.2	7.3
Nitrogen Oxides Results							
C _{sd}	Concentration (ppmdv)	33.9	33.2	33.3	33.5	33.6	34.1
C _{sd}	Concentration (lb/dscf)	4.05E-06	3.96E-06	3.97E-06	4.00E-06	4.01E-06	4.07E-06
E _{Fd}	Emission Rate - F _d -based (lb/MMBtu)	0.0571	0.0564	0.0565	0.0570	0.0572	0.0580
Carbon Monoxide Results							
C _{sd}	Concentration (ppmdv)	33.2	35.0	33.7	34.4	34.0	31.8
C _{sd}	Concentration (lb/dscf)	2.41E-06	2.55E-06	2.45E-06	2.50E-06	2.47E-06	2.31E-06
E _{Fd}	Emission Rate - F _d -based (lb/MMBtu)	0.0340	0.0362	0.0349	0.0356	0.0352	0.0330

080410 154528

Run No.		7	8	9	10	Average
Date (2016)		Apr 11	Apr 11	Apr 11	Apr 11	
Start Time (approx.)		15:50	16:20	16:56	17:29	
Stop Time (approx.)		16:11	16:41	17:17	17:50	
Process Conditions						
R _P	Steam Production (Kib/hr)	117	116	115	115	116
P ₁	Fuel gas flow rate (kscf/hr)	140	140	141	141	140
P ₂	Natural gas flow rate (kscf/hr)	11.8	11.8	11.9	11.9	11.8
F _d	Oxygen-based F-factor (dscf/MMBtu)	8,379	8,379	8,379	8,379	8,379
Gas Conditions						
O ₂	Oxygen (dry volume %)	8.7	8.7	8.9	8.7	8.7
CO ₂	Carbon dioxide (dry volume %)	7.2	7.2	7.1	7.2	7.2
Nitrogen Oxides Results						
C _{sd}	Concentration (ppmdv)	33.7	34.1	33.9	34.2	33.7
C _{sd}	Concentration (lb/dscf)	4.03E-06	4.07E-06	4.04E-06	4.08E-06	4.03E-06
E _{Fd}	Emission Rate - F _d -based (lb/MMBtu)	0.0579	0.0586	0.0588	0.0585	0.0576
Carbon Monoxide Results						
C _{sd}	Concentration (ppmdv)	32.1	35.0	35.1	35.6	34.0
C _{sd}	Concentration (lb/dscf)	2.33E-06	2.54E-06	2.55E-06	2.59E-06	2.47E-06
E _{Fd}	Emission Rate - F _d -based (lb/MMBtu)	0.0335	0.0366	0.0370	0.0372	0.0353

Average includes 10 runs.

080410 154528

RESULTS

**Table 2-7:
B&W Boiler Stack – O₂ Relative Accuracy (USEPA 3A)**

Run No.	Start Time	Date (2016)	RM Data (%dv)	CEMS Data (%dv)	Difference (%dv)	Difference Percent
1	12:40	Apr 11	8.5	8.4	0.1	1.1%
2	13:15	Apr 11	8.6	8.5	0.1	1.0%
3	13:45	Apr 11	8.6	8.5	0.1	1.2%
4	14:16	Apr 11	8.6	8.5	0.1	0.8%
5	14:49	Apr 11	8.6	8.5	0.1	0.7%
6	15:19	Apr 11	8.6	8.5	0.1	1.3%
7	15:50	Apr 11	8.7	8.5	0.2	2.4%
8	16:20	Apr 11	8.7	8.6	0.1	1.1%
9 *	16:56	Apr 11	8.9	8.6	0.3	3.3%
10	17:29	Apr 11	8.7	8.6	0.1	1.3%
Average			8.6	8.5	0.1	1.2%

Relative Accuracy Test Audit Results


Standard Deviation of Differences	0.043	
Confidence Coefficient (CC)	0.033	
t-Value for 9 Data Sets	2.306	
Avg. Abs. Diff. (%dv)	0.104	Limit 1.0

RM = Reference Method (CleanAir Data)

051816 083851

CEMS = Continuous Emissions Monitoring System (Marathon Petroleum Corporation Data)

RATA calculations are based on 9 of 10 runs. * indicates the excluded run.



RESULTS

**Table 2-8:
B&W Boiler Stack – NO_x (lb/MMBtu) Relative Accuracy (USEPA 7E)**

Run No.	Start Time ¹	Date (2016)	RM Data (lb/MMBtu)	CEMS Data (lb/MMBtu)	Difference (lb/MMBtu)	Difference Percent
1 *	12:40	Apr 11	0.057	0.058	-0.001	-1.8%
2	13:15	Apr 11	0.056	0.060	-0.004	-7.1%
3	13:45	Apr 11	0.056	0.060	-0.004	-7.1%
4	14:16	Apr 11	0.057	0.060	-0.003	-5.3%
5	14:49	Apr 11	0.057	0.061	-0.004	-7.0%
6	15:19	Apr 11	0.058	0.061	-0.003	-5.2%
7	15:50	Apr 11	0.058	0.061	-0.003	-5.2%
8	16:20	Apr 11	0.059	0.061	-0.002	-3.4%
9	16:56	Apr 11	0.059	0.062	-0.003	-5.1%
10	17:29	Apr 11	0.059	0.062	-0.003	-5.1%
Average			0.058	0.061	-0.003	-5.6%

Relative Accuracy Test Audit Results

Standard Deviation of Differences	0.001	
Confidence Coefficient (CC)	0.001	
t-Value for 9 Data Sets	2.306	
Relative Accuracy (as % of RM)	6.5%	Limit 10.0%
Avg. Abs. Diff. (lb/MMBtu)	0.003	0.020
Bias Test	-0.003 ≤ 0.001	
Bias Test Status	Pass	


¹ Start time applicable to reference method only

RM = Reference Method (CleanAir Data)

052016 14536

CEMS = Continuous Emissions Monitoring System (Marathon Petroleum Corporation Data)

RATA calculations are based on 9 of 10 runs. * indicates the excluded run.



RESULTS


**Table 2-9:
B&W Boiler Stack – CO (lb/MMBtu) Relative Accuracy (USEPA 10)**

Run No.	Start Time	Date (2016)	RM Data (lb/MMBtu)	CEMS Data (lb/MMBtu)	Difference (lb/MMBtu)	Difference Percent
1	12:40	Apr 11	0.034	0.032	0.002	5.9%
2 *	13:15	Apr 11	0.036	0.033	0.003	8.3%
3	13:45	Apr 11	0.035	0.033	0.002	5.7%
4	14:16	Apr 11	0.036	0.034	0.002	5.6%
5	14:49	Apr 11	0.035	0.034	0.001	2.9%
6	15:19	Apr 11	0.033	0.032	0.001	3.0%
7	15:50	Apr 11	0.034	0.032	0.002	5.9%
8	16:20	Apr 11	0.037	0.035	0.002	5.4%
9	16:56	Apr 11	0.037	0.035	0.002	5.4%
10	17:29	Apr 11	0.037	0.035	0.002	5.4%
Average			0.035	0.034	0.002	5.0%

Relative Accuracy Test Audit Results

Standard Deviation of Differences	0.000	
Confidence Coefficient (CC)	0.000	
t-Value for 9 Data Sets	2.306	
		Limit
Relative Accuracy (as % of RM)	6.0%	10.0%
Avg. Abs. Diff. (lb/MMBtu)	0.002	0.04

RM = Reference Method (CleanAir Data) 0519 10 17158
 CEMS = Continuous Emissions Monitoring System (Marathon Petroleum Corporation Data)
 RATA calculations are based on 9 of 10 runs. * indicates the excluded run.



End of Section 2 – Results