



RICK SNYDER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF ENVIRONMENTAL QUALITY
LANSING DISTRICT OFFICE



DAN WYANT
DIRECTOR

December 4, 2015

Mr. Mark Matus
Manager of Environmental Services
Lansing Board of Water and Light
1201 South Washington Avenue
Lansing, Michigan 48910

SRN: B2647, Ingham County

Dear Mr. Matus:

VIOLATION NOTICE

The Department of Environmental Quality (DEQ), Air Quality Division (AQD) reviewed the third quarter 2015 Renewable Operating Permit (ROP) report for the Lansing Board of Water and Light (LBWL) – Eckert Station and REO Town Plant. This facility is located at 601 Island Avenue, Lansing.

During the review, staff identified the following:

Process Description	Rule/Permit Condition Violated	Comments
EUBOILER3	ROP No. MI-ROP-B2647-2012c, A. General Condition 11; and Rule 301.	108 minutes of excess opacity which was 13.81% of boiler operating time for the third quarter.

Please initiate actions necessary to correct the cited violation and submit a written response to this Violation Notice by December 28, 2015. The written response should include: the dates the violation occurred; an explanation of the causes and duration of the violation; whether the violation is ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violation and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

If LBWL believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violation cited above. If you have any questions regarding the violation or the actions necessary to bring this facility into compliance, please contact me at the telephone number listed below.

Sincerely,

A handwritten signature in black ink, appearing to read "Julie L. Brunner". The signature is fluid and cursive, written in a professional style.

Julie L. Brunner, P.E.
Senior Environmental Engineer
Air Quality Division
517-284-6789

JLB:TG

cc: Mr. Brad Myott, DEQ
cc/via e-mail: Ms. Shannon Whiton, LBWL
Ms. Lynn Fiedler, DEQ
Ms. Teresa Seidel, DEQ
Mr. Thomas Hess, DEQ