

FINAL REPORT RECEIVED

FEB 06 2024



AIR QUALITY DIVISION

**DTE ENERGY CORPORATE
SERVICES (DECS)**

FOWLerville, MICHIGAN

**DTE ELECTRIC COLFAX PEAKING FACILITY:
EMISSION TESTING FOR CO DESTRUCTION EFFICIENCY**

RWDI #2401241

January 29, 2024

SUBMITTED TO

Mr. Mark Grigereit, QSTI
Principal Engineer
Mark.grigereit@dteenergy.com

Colfax Peaking Facility
4025 Gregory Road
Fowlerville, MI 48836

T: 313.412.0305

SUBMITTED BY

Steve Smith, QSTI
Project Manager / Associate
Steve.Smith@rwdi.com

Brad Bergeron, d.E.T., A.Sc.T.
Technical Director / Principal
Brad.Bergeron@rwdi.com

Mason Sakshaug, QSTI
Supervisor, USA Field Services / Associate Principal
Mason.Sakshaug@rwdi.com

RWDI USA LLC
Consulting Engineers & Scientists
2239 Star Court
Rochester Hills, Michigan 48309

T: 248.841.8442
F: 519.823.1316



rwdi.com



EXECUTIVE SUMMARY

RWDI USA LLC (RWDI) was retained by DTE Energy Corporate Services (DECS) to complete the emission sampling program at the DTE Electric Colfax Peaking Facility (Colfax) located at 4025 Gregory Rd Fowlerville, MI. This facility operates five (5) GM Electro-Motive Division MP45, 20-cylinder, diesel fueled, 3600 horsepower compression ignition engines. These engines are identified as DG 11-1, DG 11-2, DG 11-3, DG 11-4, and DG 11-5. The site is used as an electrical substation, which generates supplemental electrical power during peak electrical demand periods or when required for load stability.

Table i: DG 11-1 Results

Parameter	DG 11-1 Concentrations & Destruction Efficiency (ppm, % & % Destruction)			
	Test 1	Test 2	Test 3	Average
Inlet	CO - 431.2 ppmvd CO - 270.1 ppmvd @ 15% O ₂ O ₂ - 11.5%	CO - 434.5 ppmvd CO - 272.9 ppmvd @ 15% O ₂ O ₂ - 11.5%	CO - 454.8 ppmvd CO - 283.2 ppmvd @ 15% O ₂ O ₂ - 11.4%	CO - 440.1 ppmvd CO - 275.4 ppmvd @ 15% O ₂ O ₂ - 11.5%
Outlet	CO - 76.4 ppmvd CO - 47.1 ppmvd @ 15% O ₂ O ₂ - 11.3%	CO - 74.7 ppmvd CO - 45.8 ppmvd @ 15% O ₂ O ₂ - 11.3%	CO - 81.2 ppmvd CO - 49.3 ppmvd @ 15% O ₂ O ₂ - 11.2%	CO - 77.4 ppmvd CO - 47.4 ppmvd @ 15% O ₂ O ₂ - 11.3%
Destruction Efficiency	82.6%	83.2%	82.6%	82.8%
Power Rating (kW)	2700 kW			
Catalyst Temperature (°F)	689.76			
ROP Limit	Outlet Concentration - 23 ppmvd @ 15% O ₂ OR 70% Destruction Efficiency			

Table ii: DG 11-2 Results

Parameter	DG 11-2 Concentrations & Destruction Efficiency (ppm, % & % Destruction)			
	Test 1	Test 2	Test 3	Average
Inlet	CO - 59.5 ppmvd CO - 42.3 ppmvd @ 15% O ₂ O ₂ - 12.6%	CO - 59.1 ppmvd CO - 41.6 ppmvd @ 15% O ₂ O ₂ - 12.5%	CO - 55.2 ppmvd CO - 39.0 ppmvd @ 15% O ₂ O ₂ - 12.6%	CO - 57.9 ppmvd CO - 41.0 ppmvd @ 15% O ₂ O ₂ - 12.6%
Outlet	CO - 17.0 ppmvd CO - 11.5 ppmvd @ 15% O ₂ O ₂ - 12.2%	CO - 15.6 ppmvd CO - 10.6 ppmvd @ 15% O ₂ O ₂ - 12.2%	CO - 15.7 ppmvd CO - 10.6 ppmvd @ 15% O ₂ O ₂ - 12.2%	CO - 16.1 ppmvd CO - 10.9 ppmvd @ 15% O ₂ O ₂ - 12.2%
Destruction Efficiency	72.9%	74.5%	72.8%	73.4%
Power Rating (kW)	2800 kW			
Catalyst Temperature (°F)	650.64			
ROP Limit	Outlet Concentration - 23 ppmvd @ 15% O ₂ OR 70% Destruction Efficiency			



Table iii: DG 11-3 Results

Parameter	DG 11-3 Concentrations & Destruction Efficiency (ppm, % & % Destruction)			
	Test 1	Test 2	Test 3	Average
Inlet	CO - 322.0 ppmvd CO - 206.9 ppmvd @ 15% O ₂ O ₂ - 11.7%	CO - 302.3 ppmvd CO - 195.4 ppmvd @ 15% O ₂ O ₂ - 11.8%	CO - 284.3 ppmvd CO - 185.6 ppmvd @ 15% O ₂ O ₂ - 11.9%	CO - 302.9 ppmvd CO - 196.0 ppmvd @ 15% O ₂ O ₂ - 11.8%
Outlet	CO - 64.9 ppmvd CO - 40.4 ppmvd @ 15% O ₂ O ₂ - 11.4%	CO - 58.8 ppmvd CO - 36.9 ppmvd @ 15% O ₂ O ₂ - 11.5%	CO - 55.1 ppmvd CO - 34.7 ppmvd @ 15% O ₂ O ₂ - 11.5%	CO - 59.6 ppmvd CO - 37.3 ppmvd @ 15% O ₂ O ₂ - 11.5%
Destruction Efficiency	80.5%	81.1%	81.3%	81.0%
Power Rating (kW)	2700 kW			
Catalyst Temperature (°F)	707.41			
ROP Limit	Outlet Concentration - 23 ppmvd @ 15% O ₂ OR 70% Destruction Efficiency			

Table iv: DG 11-4 Results

Parameter	DG 11-4 Concentrations & Destruction Efficiency (ppm, % & % Destruction)			
	Test 1	Test 2	Test 3	Average
Inlet	CO - 72.8 ppmvd CO - 49.2 ppmvd @ 15% O ₂ O ₂ - 12.2%	CO - 73.5 ppmvd CO - 50.1 ppmvd @ 15% O ₂ O ₂ - 12.3%	CO - 78.1 ppmvd CO - 52.9 ppmvd @ 15% O ₂ O ₂ - 12.2%	CO - 74.8 ppmvd CO - 50.7 ppmvd @ 15% O ₂ O ₂ - 12.2%
Outlet	CO - 19.9 ppmvd CO - 13.6 ppmvd @ 15% O ₂ O ₂ - 12.3%	CO - 20.0 ppmvd CO - 13.9 ppmvd @ 15% O ₂ O ₂ - 12.4%	CO - 21.3 ppmvd CO - 14.7 ppmvd @ 15% O ₂ O ₂ - 12.3%	CO - 20.4 ppmvd CO - 14.1 ppmvd @ 15% O ₂ O ₂ - 12.3%
Destruction Efficiency	72.3%	72.3%	72.3%	72.3%
Power Rating (kW)	2700 kW			
Catalyst Temperature (°F)	651.02			
ROP Limit	Outlet Concentration - 23 ppmvd @ 15% O ₂ OR 70% Destruction Efficiency			



Table v: DG 11-5 Results

Parameter	DG 11-5 Concentrations & Destruction Efficiency (ppm, % & % Destruction)			
	Test 1	Test 2	Test 3	Average
Inlet	CO - 72.8 ppmvd CO - 50.6 ppmvd @ 15% O ₂ O ₂ - 12.4%	CO - 74.4 ppmvd CO - 51.5 ppmvd @ 15% O ₂ O ₂ - 12.4%	CO - 77.0 ppmvd CO - 53.2 ppmvd @ 15% O ₂ O ₂ - 12.4%	CO - 74.7 ppmvd CO - 51.8 ppmvd @ 15% O ₂ O ₂ - 12.4%
Outlet	CO - 17.6 ppmvd CO - 12.3 ppmvd @ 15% O ₂ O ₂ - 12.5%	CO - 17.5 ppmvd CO - 12.3 ppmvd @ 15% O ₂ O ₂ - 12.5%	CO - 18.0 ppmvd CO - 12.6 ppmvd @ 15% O ₂ O ₂ - 12.5%	CO - 17.7 ppmvd CO - 12.4 ppmvd @ 15% O ₂ O ₂ - 12.5%
Destruction Efficiency	75.6%	76.2%	76.3%	76.0%
Power Rating (kW)	2800 kW			
Catalyst Temperature (°F)	622.15			
ROP Limit	Outlet Concentration - 23 ppmvd @ 15% O ₂ OR 70% Destruction Efficiency			

Each unit met the minimum destruction limit of 70% for CO. In addition, Units 11-2, 11-4 and 11-5 met the in-stack concentration of 23 ppmvd corrected to 15% O₂.

Each engines' emission limits (in the Renewable Operating Permit (ROP) and required by 40 CFR Part 63 NESHAP Subpart ZZZZ) are:

- a) Limit concentration of CO in the stationary RICE exhaust to 23 ppmvd at 15% O₂; **OR**
- b) Reduce CO Emissions by 70% or more.

Therefore all engines were able to demonstrate compliance with the ROP and 40 CFR Part 63 NESHAP Subpart ZZZZ limits.



TABLE OF CONTENTS

1	INTRODUCTION.....	1
1.1	Location and Dates of Testing.....	1
1.2	Purpose of Testing.....	1
1.3	Description of Source.....	1
1.4	Personnel Involved in Testing.....	2
2	SUMMARY OF RESULTS.....	2
2.1	Operating Data.....	2
2.2	Applicable Permit Number.....	2
3	SOURCE DESCRIPTION.....	3
3.1	Description of Process and Emission Control Equipment.....	3
3.2	Process Flow Sheet or Diagram (if applicable).....	3
3.3	Type and Quantity of Raw and Finished Materials.....	3
3.4	Normal Rated Capacity of Process.....	3
3.5	Process Instrumentation Monitored During the Test.....	3
4	SAMPLING AND ANALYTICAL PROCEDURES.....	4
4.1	Description of Sampling Train and Field Procedures.....	4
4.1.1	Carbon Monoxide and Oxygen.....	4
4.1.2	Gas Dilution (Method 205).....	5
4.2	Description of Recovery and Analytical Procedures.....	5
4.3	Sampling Port Description.....	5
5	TEST RESULTS AND DISCUSSION.....	6
5.1	Detailed Results.....	6
5.2	Discussion of Results.....	8
5.3	Variations in Testing Procedures.....	8



5.4	Process Upset Conditions During Testing.....	8
5.5	Maintenance Performed in Last Three Months.....	9
5.6	Re-Test.....	9
5.7	Audit Samples.....	9
5.8	Field Data Sheets.....	9
5.9	Calibration Data.....	9
5.10	Example Calculations.....	9
5.11	Laboratory Data.....	9

LIST OF TABLES

(Found Within the Report)

Table i:	DG 11-1 Results.....	Executive Summary
Table ii:	DG 11-2 Results.....	Executive Summary
Table iii:	DG 11-3 Results.....	Executive Summary
Table iv:	DG 11-4 Results.....	Executive Summary
Table v:	DG 11-5 Results.....	Executive Summary
Table 1.4.1:	List of Testing Personnel.....	2
Table 5.1.1:	DG 11-1 Results.....	6
Table 5.1.2:	DG 11-2 Results.....	6
Table 5.1.3:	DG 11-3 Results.....	7
Table 5.1.4:	DG 11-4 Results.....	7
Table 5.1.5:	DG 11-5 Results.....	8

LIST OF TABLES

(Found After the Report)

Table 1:	DG 11-1 Test Summary
Table 2:	DG 11-2 Test Summary
Table 3:	DG 11-3 Test Summary
Table 4:	DG 11-4 Test Summary
Table 5:	DG 11-5 Test Summary



LIST OF FIGURES

(Found After the Report)

- Figure 1:** Sampling Locations
- Figure 2:** Schematic of USEPA Method 3A and 10

LIST OF APPENDICES

(Found After the Report)

- Appendix A:** Process Data
 - Appendix A1:** Weather Data
 - Appendix A2:** Diesel Peaker 11-1
 - Appendix A3:** Diesel Peaker 11-2
 - Appendix A4:** Diesel Peaker 11-3
 - Appendix A5:** Diesel Peaker 11-4
 - Appendix A6:** Diesel Peaker 11-5
- Appendix B:** CEMS Data
 - Appendix B1:** Diesel Peaker 11-1
 - Appendix B2:** Diesel Peaker 11-2
 - Appendix B3:** Diesel Peaker 11-3
 - Appendix B4:** Diesel Peaker 11-4
 - Appendix B5:** Diesel Peaker 11-5
- Appendix D:** Calibration Documents
- Appendix E:** Example Calculations
- Appendix F:** EGLE Correspondence and Source Testing Plan



1 INTRODUCTION

RWDI USA LLC (RWDI) was retained by DTE Energy Corporate Services (DECS) to complete the emission sampling program at the DTE Electric Colfax Peaking Facility (Colfax) located at 4025 Gregory Rd Fowlerville, MI. This facility operates five GM Electro-Motive Division MP45, 20-cylinder, diesel fueled, 3600 horsepower compression ignition engines. These engines are identified as DG 11-1, DG 11-2, DG 11-3, DG 11-4, and DG 11-5. The site is used as an electrical substation, which generates supplemental electrical power during peak electrical demand periods or when required for load stability.

1.1 Location and Dates of Testing

The test program was completed from December 12-13, 2023.

1.2 Purpose of Testing

This testing was conducted to show compliance with MI-ROP-B2795-2023 and 40 CFR Part 63 Subpart ZZZZ RICE MACT.

1.3 Description of Source

This facility operates five GM Electro-Motive Division MP45, 20-cylinder, diesel fueled, 3600 horsepower compression ignition engines. These engines are identified as 11-1, 11-2, 11-3, 11-4, and 11-5.



1.4 Personnel Involved in Testing

Table 1.4.1: Testing Personnel

Mr. Mark Grigereit Principal Engineer Mark.grigereit@dteenergy.com	DECS-EM&S 6100 West Warren Avenue Room G4-S Detroit, MI 48210	(313) 412-0305
Mr. Matt Karl Lansing District Office karlm@michigan.gov	State of Michigan Department of Environment, Great Lakes and Energy (EGLE) Air Quality Division Lansing District Office Constitution Hall 1 st Floor South 525 Allegan Street Lansing MI 48909-7760	(517) 282-2126
Steve Smith Project Manager Steve.Smith@rwdi.com	RWDI USA LLC 2239 Star Court Rochester Hills, MI 48309	(971) 234-3885
Brad Bergeron Technical Director Brad.Bergeron@rwdi.com		(248) 234-3885
Mason Sakshaug Senior Scientist Mason.Sakshaug@rwdi.com		(989) 323-0355
Cade Smith Field Technician Cade.smith@rwdi.com		(734) 552-7270

2 SUMMARY OF RESULTS

2.1 Operating Data

Operating parameters used to regulate the compressor engines include speed (RPM) and torque (HP). Additional parameters monitored include fuel flow, inlet & exhaust temperature & pressure, and timing. Operating parameters can be found in **Appendix A**.

2.2 Applicable Permit Number

MI-ROP-B2795-2023 and 40 CFR Part 63 Subpart ZZZZ.



3 SOURCE DESCRIPTION

3.1 Description of Process and Emission Control Equipment

Each engine is equipped with an oxidation catalyst to reduce HAP constituents.

3.2 Process Flow Sheet or Diagram (if applicable)

A process flow diagram can be found in the figures section.

3.3 Type and Quantity of Raw and Finished Materials

All five engines are 20 cylinder diesel fueled units.

3.4 Normal Rated Capacity of Process

The engines are rated at 3600 HP and were ran at +/- 10% of 100% load.

3.5 Process Instrumentation Monitored During the Test

See section 2.1.



4 SAMPLING AND ANALYTICAL PROCEDURES

4.1 Description of Sampling Train and Field Procedures

4.1.1 Carbon Monoxide and Oxygen

CO and O₂ concentrations were determined utilizing RWDI's continuous emissions monitoring (CEM) system. Prior to testing, a 3-point analyzer calibration error check was conducted using USEPA protocol gases. The calibration error check was performed by introducing zero, mid and high-level calibration gases directly into the analyzer. The calibration error check was performed to confirm that the analyzer response was within $\pm 2\%$ of the certified calibration gas introduced. Prior to each test run, a system-bias test was performed where known concentrations of calibration gases were introduced at the probe tip to measure if the analyzers response was within $\pm 5\%$ of the introduced calibration gas concentrations. At the conclusion of each test run a system-bias check was performed to evaluate the percent drift from pre and post-test system bias checks. The system bias checks were used to confirm that the analyzer did not drift greater than $\pm 3\%$ throughout each test run.

Zero and upscale calibration checks were conducted both before and after each test run in order to quantify measurement system calibration drift and sampling system bias. Upscale is either the mid- or high-range gas, whichever most closely approximates the flue gas level. During these checks, the calibration gases were introduced into the sampling system at the probe outlet so that the calibration gases were analyzed in the same manner as the flue gas samples.

A gas sample was continuously extracted from the stack and delivered to a series of gas analyzers, which measure the pollutant or diluent concentrations in the gas. The analyzers were calibrated on-site using EPA Protocol No. 1 certified calibration mixtures. The probe tip was equipped with a sintered stainless-steel filter for particulate removal. The end of the probe was connected to a heated Teflon sample line, which delivered the sample gases from the stack to the CEM system. The heated sample line was designed to maintain the gas temperature above 250°F in order to prevent condensation of stack gas moisture within the line.

Before entering the analyzers, the gas sample passed directly into a refrigerated condenser, which cools the gas to approximately 35°F to remove the stack gas moisture. After passing through the condenser, the dry gas entered a Teflon-head diaphragm pump and a flow control panel, which delivered the gas in series to the CO and O₂ analyzers. Each of these analyzers measure the respective gas concentrations on a dry volumetric basis.

A three point traverse was used at the inlet and outlet of each of the engine during the testing.



4.1.2 Gas Dilution (Method 205)

Calibration gas was mixed using an Environics 4040 Gas Dilution System. The mass flow controllers are factory calibrated using a primary flow standard traceable to the United States National Institute of Standards and Technology (NIST). Each flow controller utilizes an 11-point calibration table with linear interpolation, to increase accuracy and reduce flow controller nonlinearity. The calibration is done yearly, and the records are included. A multi-point EPA Method 205 check was executed in the field prior to testing to ensure accurate gas-mixtures. The gas dilution system consists of calibrated orifices or mass flow controllers and dilutes a high-level calibration gas to within $\pm 2\%$ of predicted values. The gas divider is capable of diluting gases at set increments and was evaluated for accuracy in the field in accordance with US EPA Method 205 "*Verification of Gas Dilution Systems for Field Instrument Calibrations*". Before testing, the gas divider dilutions were measured to evaluate that the responses are within $\pm 2\%$ of predicted values. In addition, a certified mid-level calibration gas within $\pm 10\%$ of one of the tested dilution gases was introduced into an analyzer to ensure the response of the gas calibration is within $\pm 2\%$ of gas divider dilution concentration.

4.2 Description of Recovery and Analytical Procedures

There were no samples to recover during this test program. All testing used real time data from the analyzers.

4.3 Sampling Port Description

The sampling locations diagram can be found in the Figures tab.



5 TEST RESULTS AND DISCUSSION

5.1 Detailed Results

Table 5.1.1: DG 11-1 Results

Parameter	DG 11-1 Concentrations & Destruction Efficiency (ppm, % & % Destruction)			
	Test 1	Test 2	Test 3	Average
Inlet	CO - 431.2 ppmvd CO - 270.1 ppmvd @ 15% O ₂ O ₂ - 11.5%	CO - 434.5 ppmvd CO - 272.9 ppmvd @ 15% O ₂ O ₂ - 11.5%	CO - 454.8 ppmvd CO - 283.2 ppmvd @ 15% O ₂ O ₂ - 11.4%	CO - 440.1 ppmvd CO - 275.4 ppmvd @ 15% O ₂ O ₂ - 11.5%
Outlet	CO - 76.4 ppmvd CO - 47.1 ppmvd @ 15% O ₂ O ₂ - 11.3%	CO - 74.7 ppmvd CO - 45.8 ppmvd @ 15% O ₂ O ₂ - 11.3%	CO - 81.2 ppmvd CO - 49.3 ppmvd @ 15% O ₂ O ₂ - 11.2%	CO - 77.4 ppmvd CO - 47.4 ppmvd @ 15% O ₂ O ₂ - 11.3%
Destruction Efficiency	82.6%	83.2%	82.6%	82.8%
Power Rating (kW)	2700 kW			
Catalyst Temperature (°F)	689.76			
ROP Limit	Outlet Concentration - 23 ppmvd @ 15% O ₂ OR 70% Destruction Efficiency			

Table 5.1.2: DG 11-2 Results

Parameter	DG 11-2 Concentrations & Destruction Efficiency (ppm, % & % Destruction)			
	Test 1	Test 2	Test 3	Average
Inlet	CO - 59.5 ppmvd CO - 42.3 ppmvd @ 15% O ₂ O ₂ - 12.6%	CO - 59.1 ppmvd CO - 41.6 ppmvd @ 15% O ₂ O ₂ - 12.5%	CO - 55.2 ppmvd CO - 39.0 ppmvd @ 15% O ₂ O ₂ - 12.6%	CO - 57.9 ppmvd CO - 41.0 ppmvd @ 15% O ₂ O ₂ - 12.6%
Outlet	CO - 17.0 ppmvd CO - 11.5 ppmvd @ 15% O ₂ O ₂ - 12.2%	CO - 15.6 ppmvd CO - 10.6 ppmvd @ 15% O ₂ O ₂ - 12.2%	CO - 15.7 ppmvd CO - 10.6 ppmvd @ 15% O ₂ O ₂ - 12.2%	CO - 16.1 ppmvd CO - 10.9 ppmvd @ 15% O ₂ O ₂ - 12.2%
Destruction Efficiency	72.9%	74.5%	72.8%	73.4%
Power Rating (kW)	2800 kW			
Catalyst Temperature (°F)	650.64			
ROP Limit	Outlet Concentration - 23 ppmvd @ 15% O ₂ OR 70% Destruction Efficiency			



Table 5.1.3: DG 11-3 Results

Parameter	DG 11-3 Concentrations & Destruction Efficiency (ppm, % & % Destruction)			
	Test 1	Test 2	Test 3	Average
Inlet	CO – 322.0 ppmvd CO – 206.9 ppmvd @ 15% O ₂ O ₂ – 11.7%	CO – 302.3 ppmvd CO – 195.4 ppmvd @ 15% O ₂ O ₂ – 11.8%	CO – 284.3 ppmvd CO – 185.6 ppmvd @ 15% O ₂ O ₂ – 11.9%	CO – 302.9 ppmvd CO – 196.0 ppmvd @ 15% O ₂ O ₂ – 11.8%
Outlet	CO – 64.9 ppmvd CO – 40.4 ppmvd @ 15% O ₂ O ₂ – 11.4%	CO – 58.8 ppmvd CO – 36.9 ppmvd @ 15% O ₂ O ₂ – 11.5%	CO – 55.1 ppmvd CO – 34.7 ppmvd @ 15% O ₂ O ₂ – 11.5%	CO – 59.6 ppmvd CO – 37.3 ppmvd @ 15% O ₂ O ₂ – 11.5%
Destruction Efficiency	80.5%	81.1%	81.3%	81.0%
Power Rating (kW)	2700 kW			
Catalyst Temperature (°F)	707.41			
ROP Limit	Outlet Concentration – 23 ppmvd @ 15% O ₂ OR 70% Destruction Efficiency			

Table 5.1.4: DG 11-4 Results

Parameter	DG 11-4 Concentrations & Destruction Efficiency (ppm, % & % Destruction)			
	Test 1	Test 2	Test 3	Average
Inlet	CO – 72.8 ppmvd CO – 49.2 ppmvd @ 15% O ₂ O ₂ – 12.2%	CO – 73.5 ppmvd CO – 50.1 ppmvd @ 15% O ₂ O ₂ – 12.3%	CO – 78.1 ppmvd CO – 52.9 ppmvd @ 15% O ₂ O ₂ – 12.2%	CO – 74.8 ppmvd CO – 50.7 ppmvd @ 15% O ₂ O ₂ – 12.2%
Outlet	CO – 19.9 ppmvd CO – 13.6 ppmvd @ 15% O ₂ O ₂ – 12.3%	CO – 20.0 ppmvd CO – 13.9 ppmvd @ 15% O ₂ O ₂ – 12.4%	CO – 21.3 ppmvd CO – 14.7 ppmvd @ 15% O ₂ O ₂ – 12.3%	CO – 20.4 ppmvd CO – 14.1 ppmvd @ 15% O ₂ O ₂ – 12.3%
Destruction Efficiency	72.3%	72.3%	72.3%	72.3%
Power Rating (kW)	2700 kW			
Catalyst Temperature (°F)	651.02			
ROP Limit	Outlet Concentration – 23 ppmvd @ 15% O ₂ OR 70% Destruction Efficiency			



Table 5.1.5: DG 11-5 Results

Parameter	DG 11-5 Concentrations & Destruction Efficiency (ppm, % & % Destruction)			
	Test 1	Test 2	Test 3	Average
Inlet	CO – 72.8 ppmvd CO – 50.6 ppmvd @ 15% O ₂ O ₂ – 12.4%	CO – 74.4 ppmvd CO – 51.5 ppmvd @ 15% O ₂ O ₂ – 12.4%	CO – 77.0 ppmvd CO – 53.2 ppmvd @ 15% O ₂ O ₂ – 12.4%	CO – 74.7 ppmvd CO – 51.8 ppmvd @ 15% O ₂ O ₂ – 12.4%
Outlet	CO – 17.6 ppmvd CO – 12.3 ppmvd @ 15% O ₂ O ₂ – 12.5%	CO – 17.5 ppmvd CO – 12.3 ppmvd @ 15% O ₂ O ₂ – 12.5%	CO – 18.0 ppmvd CO – 12.6 ppmvd @ 15% O ₂ O ₂ – 12.5%	CO – 17.7 ppmvd CO – 12.4 ppmvd @ 15% O ₂ O ₂ – 12.5%
Destruction Efficiency	75.6%	76.2%	76.3%	76.0%
Power Rating (kW)	2800 kW			
Catalyst Temperature (°F)	622.15			
ROP Limit	Outlet Concentration – 23 ppmvd @ 15% O ₂ OR 70% Destruction Efficiency			

5.2 Discussion of Results

Detailed results for each CEMs run are provided in **Appendix B**. Each unit met the minimum destruction limit of 70% for CO. In addition, Units 11-2, 11-4 and 11-5 met the in-stack concentration of 23 ppmvd corrected to 15% O₂.

Each engine's emission limits (in the Renewable Operating Permit (ROP) and required by 40 CFR Part 63 NESHAP Subpart ZZZZ) are:

- a) Limit concentration of CO in the stationary RICE exhaust to 23 ppmvd at 15% O₂; **OR**
- b) Reduce CO Emissions by 70% or more.

Therefore all engines were able to demonstrate compliance with the ROP and 40 CFR Part 63 NESHAP Subpart ZZZZ limits.

5.3 Variations in Testing Procedures

There were no variations in testing procedures.

5.4 Process Upset Conditions During Testing

There were normal process breaks during production.



5.5 Maintenance Performed in Last Three Months

Regular maintenance is performed monthly.

5.6 Re-Test

This was not a retest.

5.7 Audit Samples

This test did not require any audit samples.

5.8 Field Data Sheets

Field data sheets can be found in **Appendix C**.

5.9 Calibration Data

Calibration data can be found in **Appendix D**.

5.10 Example Calculations

Example calculations can be found in **Appendix E**.

5.11 Laboratory Data

There was no laboratory data from this testing program.

TABLES



Table 1: DG 11-1 Testing Summary

RWDI Project #2401241

DG 11-1				O ₂		CO		CO Emission Rate		Destruction Efficiency
Test ID	Date	Start	End	%		ppm		ppm corrected to 15% O ₂		DE %
				Inlet	Outlet	Inlet	Outlet	Inlet	Outlet	
1	2023-12-12	6:20	7:19	11.5	11.3	431.2	76.4	270.1	47.1	82.6%
2	2023-12-12	7:32	8:31	11.5	11.3	434.5	74.7	272.9	45.8	83.2%
3	2023-12-12	8:44	9:43	11.4	11.2	454.8	81.2	283.2	49.3	82.6%
		Average		11.5	11.3	440.1	77.4	275.4	47.4	82.8%

Limits: Outlet 23 ppmvd @ 15% O₂
DE 70%

Table 2: DG 11-2 Testing Summary

RWDI Project #2401241

DG 11-2				O ₂		CO		CO Emission Rate		Destruction Efficiency
Test ID	Date	Start	End	%		ppm		ppm corrected to 15% O ₂		
				Inlet	Outlet	Inlet	Outlet	Inlet	Outlet	DE %
1	2023-12-12	10:10	11:09	12.6	12.2	59.5	17.0	42.3	11.5	72.9%
2	2023-12-12	11:21	12:20	12.5	12.2	59.1	15.6	41.6	10.6	74.5%
3	2023-12-12	12:31	13:30	12.6	12.2	55.2	15.7	39.0	10.6	72.8%
		Average		12.6	12.2	57.9	16.1	41.0	10.9	73.4%

Limits: Outlet 23 ppmvd @ 15% O₂
DE 70%

Table 3: DG 11-3 Testing Summary

RWDI Project #2401241

DG 11-3				O ₂		CO		CO Emission Rate		Destruction Efficiency
Test ID	Date	Start	End	%		ppm		ppm corrected to 15% O ₂		DE %
				Inlet	Outlet	Inlet	Outlet	Inlet	Outlet	
1	2023-12-12	13:55	14:54	11.7	11.4	322.0	64.9	206.9	40.4	80.5%
2	2023-12-12	15:10	16:09	11.8	11.5	302.3	58.8	195.4	36.9	81.1%
3	2023-12-12	16:18	17:17	11.9	11.5	284.3	55.1	185.6	34.7	81.3%
		Average		11.8	11.5	302.9	59.6	196.0	37.3	81.0%

Limits: Outlet 23 ppmvd @ 15% O₂
DE 70%

Table 4: DG 11-4 Testing Summary

RWDI Project #2401241

DG 11-4				O ₂		CO		CO Emission Rate		Destruction Efficiency
Test ID	Date	Start	End	%		ppm		ppm corrected to 15% O ₂		DE %
				Inlet	Outlet	Inlet	Outlet	Inlet	Outlet	
1	2023-12-13	6:40	7:39	12.2	12.3	72.8	19.9	49.2	13.6	72.3%
2	2023-12-13	7:51	8:50	12.3	12.4	73.5	20.0	50.1	13.9	72.3%
3	2023-12-13	9:02	10:01	12.2	12.3	78.1	21.3	52.9	14.7	72.3%
		Average		12.2	12.3	74.8	20.4	50.7	14.1	72.3%

Limits: Outlet 23 ppmvd @ 15% O₂
DE 70%


Table 5: DG 11-5 Testing Summary

RWDI Project #2401241

DG 11-5				O ₂		CO		CO Emission Rate		Destruction Efficiency
Test ID	Date	Start	End	%		ppm		ppm corrected to 15% O ₂		
				Inlet	Outlet	Inlet	Outlet	Inlet	Outlet	DE %
1	2023-12-13	10:18	11:17	12.4	12.5	72.8	17.6	50.6	12.3	75.6%
2	2023-12-13	11:28	12:27	12.4	12.5	74.4	17.5	51.5	12.3	76.2%
3	2023-12-13	12:37	13:36	12.4	12.5	77.0	18.0	53.2	12.6	76.3%
		Average		12.4	12.5	74.7	17.7	51.8	12.4	76.0%

Limits: Outlet 23 ppmvd @ 15% O₂
DE 70%

FIGURES



**Figure 1 – Sampling Location
RICE Peaker Sites
2023**







Figure No. 2: USEPA Method 3A and 10 Schematic



USEPA Method 3A,6C,7E,10

DTE Energy Corporate Services
DTE Electric Colfax Peaking Facility

Fowlerville, MI

Project# 2401241

Date: Dec. 12th and 13th, 2023

