

**Relative Accuracy Test
Audit Test Report**

Billerud Quinnesec LLC
Quinnesec Mill
Package Boiler Outlet Duct,
Waste Fuel Boiler Outlet Duct,
Recovery Boiler Outlet Duct, and
Lime Kiln Stack
Quinnesec, Michigan
Project No. M242110A





Relative Accuracy Test Audit Test Report

**Billerud Quinnesec LLC
Quinnesec Mill
Package Boiler Outlet Duct, Waste Fuel Boiler Outlet Duct,
Recovery Boiler Outlet Duct, and Lime Kiln Stack
Quinnesec, Michigan
Test Dates: May 21 through 23, 2024**

**Report Submittal Date
July 9, 2024**

© Copyright 2024
All rights reserved in
Mostardi Platt

Project No. M242110A

TABLE OF CONTENTS

1.0 EXECUTIVE SUMMARY	1
2.0 TEST METHODOLOGY	4
Method 1 Traverse Point Determination	4
Method 2 Volumetric Flowrate Determination	4
Method 3A Oxygen (O ₂)/ Carbon Dioxide (CO ₂) Determination	4
Method 4 Moisture Determination	4
Method 6C Sulfur Dioxide (SO ₂) Determination	5
Method 7E Nitrogen Oxide (NO _x) Determination	6
Method 10 Carbon Monoxide (CO) Determination	7
Method 16C Total Reduced Sulfur (TRS) Determination	8
3.0 TEST RESULT SUMMARIES	9
4.0 CERTIFICATION	30
APPENDIX	
Appendix A - Test Section Diagrams	32
Appendix B - Sample Train Diagrams	39
Appendix C - Calculation Nomenclature and Formulas	44
Appendix D - Reference Method Test Data (Hand and Computerized Sheets)	62
Appendix E - Continuous Emission Monitoring Systems and Plant Operating Data	107
Appendix F - Field Data Sheets	177
Appendix G - Calibration and Response Time Data	205
Appendix H - Calibration Gas Cylinder Data	246
Appendix I - NO ₂ to NO Converter Efficiency Test Data	266

1.0 EXECUTIVE SUMMARY

Mostardi Platt conducted a Relative Accuracy Test Audit (RATA) test program for Billerud Quinnesec LLC at the Quinnesec, Michigan facility. This report summarizes the results of the test program and test methods used.

The test locations, test dates, and test parameters are summarized below.

TEST INFORMATION		
Test Locations	RATA Test Dates	Test Parameters
Package Boiler Outlet Duct	May 21, 2024	Nitrogen Oxides (NO _x), Carbon Monoxide (CO), and Oxygen (O ₂)
Waste Fuel Boiler Outlet Duct	May 23, 2024	NO _x , Sulfur Dioxide (SO ₂), Carbon Dioxide (CO ₂), O ₂ , and Volumetric Flow
Recovery Boiler Outlet Duct	May 22 and 23, 2024	NO _x , SO ₂ , O ₂ , CO, Total Reduced Sulfur (TRS), and Volumetric Flow
Lime Kiln Stack	May 21, 2024	TRS and O ₂

The purpose of the test program was to demonstrate the relative accuracy of the parameters listed above. Selected results of the test program are summarized below. A complete summary of emission test results, for each location, follows the narrative portion of this report.

TRS results were corrected to eight percent O₂ on the Recovery Boiler and ten percent O₂ on the Lime Kiln.

PACKAGE BOILER OUTLET DUCT				
Date	Parameter	Units	Acceptance Criteria	Relative Accuracy
5/21/2024	NO _x	lb/mmBtu	< 20% of the mean reference method value	7.35%
	NO _x	lb/hr	< 20% of the mean reference method value	3.42%
	O ₂	% dry	< 20% of the mean reference method value	1.83%
	CO	lb/mmBtu	< 5% of applicable standard of 0.12 lb/hr	3.06% of applicable standard of 0.12 lb/MMBtu
	CO	ppm	< 5 ppm mean difference + confidence coefficient	3.17 ppm mean difference + confidence coefficient
	CO	lb/hr	< 5% of applicable standard of 25.5 lb/hr	1.78% of applicable standard of 25.5 lb/hr

WASTE FUEL BOILER OUTLET DUCT				
Date	Parameter	Units	Acceptance Criteria	Relative Accuracy
5/23/2024	NO _x	lb/mmBtu	< 20% of the mean reference method value	6.17%
	NO _x	lb/hr	< 20% of the mean reference method value	12.09%
	CO ₂	% dry	< 20% of the mean reference method value	0.54%
	O ₂	% dry	< 20% of the mean reference method value	3.02%
	SO ₂	lb/mmBtu	< 20% of the mean reference method value	0.00%
	SO ₂	lb/hr	< 10% of applicable standard of 476 lb/hr	0.51% of applicable standard of 476 lb/hr
	Volumetric Flow	dscfm	< 20% of the mean reference method value	14.36%

RECOVERY BOILER OUTLET DUCT				
Date	Parameter	Units	Acceptance Criteria	Relative Accuracy
5/22/2024	NO _x	ppmvd @ 8% O ₂	< 20% of the mean reference method value	3.39%
	O ₂	% dry	< 20% of the mean reference method value	6.08%
	SO ₂	ppmvd @ 8% O ₂	< 10% of applicable standard of 50 ppmvd@ 8% O ₂	0.87% of applicable standard of 50 ppmvd @ 8% O ₂
	CO	ppmvd @ 8% O ₂	< 5% of applicable standard of 500 ppmvd@ 8% O ₂	1.22% of applicable standard of 425 ppmvd @ 8% O ₂
5/22/2024 & 5/23/2024	TRS	ppmvd @ 8% O ₂	< 20% of the mean reference method value	10.19%
5/22/2024	Volumetric Flow	dscfm	< 20% of the mean reference method value	1.83%

LIME KILN STACK				
Date	Parameter	Units	Acceptance Criteria	Relative Accuracy
5/21/2024	TRS	ppmvd @ 10% O ₂	< 20% of the mean reference method value	14.23%
	O ₂	% dry	< 20% of the mean reference method value	8.97%

The gas cylinders used to perform the RATA are summarized below.

GAS CYLINDER INFORMATION				
Parameter	Gas Vendor	Cylinder Serial Number	Cylinder Value	Expiration Date
NO _x	Airgas	XF003141B	124.8 ppm	3/4/2032
NO _x	Airgas	ALM-023821	150.8 ppm	1/24/2031
NO _x	Airgas	CC48275	300.5 ppm	1/24/2032
SO ₂	Airgas	CC439581	12.15 ppm	6/1/2025
SO ₂	Airgas	CC285356	12.17 ppm	10/18/2026
SO ₂	Airgas	CC501703	25.05 ppm	10/18/2026
SO ₂	Airgas	CC488384	248.5 ppm	8/7/2031
SO ₂	Airgas	CC280724	496.4 ppm	9/1/2031
O ₂	Airgas	CC35454	5.077%	2/12/2032
O ₂	Airgas	CC403240	9.041%	2/6/2032
O ₂	Airgas	CC47224	9.151%	2/6/2032
O ₂	Airgas	CC440339	21.93%	7/7/2030
CO ₂	Airgas	CC309474	9.940%	5/1/2031
CO ₂	Airgas	CC709438	19.17%	6/23/2031
CO	Airgas	XF003141B	78.02 ppm	3/4/2032
CO	Airgas	000006	173.5 ppm	2/23/2027
CO	Airgas	CC218918	470.6 ppm	3/23/2030
CO	Airgas	CC713835	920.9 ppm	8/12/2027

The identifications of the individuals associated with the test program are summarized below.

Location	Address	Contact
Test Facility	Billerud Quinnesec LLC W-679 U. S. Highway 2 Quinnesec, Michigan 49876	Ms. Paula LaFleur Environmental Engineer (906) 779-3494 (phone) paula.lafleur@billerud.com
Testing Company Representative	Mostardi Platt 888 Industrial Drive Elmhurst, Illinois 60126	Mr. Christopher Jensen Senior Project Manager (630) 993-2100 (phone) cjensen@mp-mail.com

The test crew consisted of B. Truett, J. Jimenez, T. Yanowsky, and C. Jensen of Mostardi Platt.

2.0 TEST METHODOLOGY

Emissions testing was conducted following the methods specified in 40CFR, Part 40 CFR, Part 60, Appendix A. Schematics of the test section diagrams and sampling trains used are included in Appendix A and B, respectively. Copies of example calculation and nomenclature are included in Appendix C. Copies of analyzer print-outs for each test run are included in Appendix D. CEM data and process data as provided by Billerud Quinnesec, LLC are included in Appendix E.

The following methodologies were used during the test program:

Method 1 Traverse Point Determination

Test measurement points were selected in accordance with Method 1. The characteristics of the measurement locations are summarized below.

Location	Upstream Distance	Downstream Distance	Test Parameter	Number of Sampling Points
Waste Fuel Boiler Outlet Duct	20 feet	100 feet	Volumetric Flow	18
Recovery Boiler Outlet Duct	20 feet	80 feet		

Method 2 Volumetric Flowrate Determination

Gas velocity was measured following Method 2, for purposes of calculating stack gas volumetric flow rate at the Waste Fuel Boiler Outlet Duct and Recovery Boiler Outlet Duct. An S-type pitot tube, differential pressure gauge, thermocouple and temperature readout were used to determine gas velocity at each sample point at each test location. Copies of field data sheets are included in Appendix F. All of the equipment used was calibrated in accordance with the specifications of the Method. Calibration data are presented in Appendix G. This testing met the performance specifications as outlined in the Method.

Method 3A Oxygen (O₂)/ Carbon Dioxide (CO₂) Determination

Stack gas O₂ and/or CO₂ concentrations were determined in accordance with USEPA Method 3A. Servomex analyzers were used to determine the O₂ and/or CO₂ concentrations in the manner specified in the Method. Each instrument has a paramagnetic detector and the O₂ operates in the nominal range of 0% to 25% with the specific range determined by the high-level calibration gas and the CO₂ operates in the nominal range of 0 to 20% with the specific range determined by the high-level calibration gas. High-range calibrations were performed using USEPA Protocol gas. Zero nitrogen (a low ppm pollutant in balance nitrogen calibration gases) was introduced during other instrument calibrations to check instrument zero. High- and a mid-range % O₂ and/or CO₂ levels in balance nitrogen were also introduced. Zero and mid-range calibrations were performed using USEPA Protocol gas after each test run. Copies of the gas cylinder certifications are found in Appendix H. This testing met the performance specifications as outlined in the Method.

Method 4 Moisture Determination

USEPA Method 4, 40CFR60, Appendix A, was utilized to determine water (H₂O) content of the exhaust gas Waste Fuel Boiler Outlet Duct and Recovery Boiler Outlet Duct. 100 milliliters (ml) of water were added to each of the first two impingers, the third impinger was left empty, and the fourth impinger was charged with approximately 200 grams of silica gel. The impingers were placed in an ice bath to maintain the sampled gas passed through the silica gel impinger outlet below 68°F in order to increase the accuracy of the sampled dry gas volume measurement. The water volumes

of the impinger train were measured and the silica gel was weighed before and after each test run to determine the mass of moisture condensed.

Each sample was extracted through a heated stainless-steel probe and filter assembly at a constant sample rate of approximately 0.75 cubic feet per minute, which was maintained throughout the course of the test run. Approximately 21 dry standard cubic feet (dscf) were sampled for, each moisture run. After each run, a leak check of the sampling train was performed at a vacuum greater than the sampling vacuum to determine if any leakage had occurred during sampling. Following the leak check, the impingers were removed from the ice bath, water levels were measured, and the silica gel weight was recorded.

All of the equipment used was calibrated in accordance with the specifications of the Method.

Copies of field data sheets are included in Appendix F. Calibration data is presented in Appendix G. This testing met the performance specifications as outlined in the Method.

Method 6C Sulfur Dioxide (SO₂) Determination

Stack gas SO₂ concentrations and emission rates were determined in accordance with USEPA Method 6C, 40CFR60, Appendix A at the Waste Fuel Boiler Outlet Duct and Recovery Boiler Outlet Duct. A Thermo Scientific Model 43C Pulsed Fluorescence Sulfur Dioxide Analyzer was used to determine sulfur dioxide concentrations, in the manner specified in the Method. The instrument for the Recovery Boiler operated in the nominal range of 0 ppm to 100 ppm with the specific range determined by the high-level span calibration gas of 90.56 ppm. The instrument for the Waste Fuel Boiler operated in the nominal range of 0 ppm to 500 ppm with the specific range determined by the high-level span calibration gas of 496.4 ppm.

The Model 43C High Level is based on the principle that SO₂ molecules absorb ultraviolet (UV) light and become excited at one wavelength, then decay to a lower energy state emitting UV light at a different wavelength. Specifically,



The sample is drawn into the Model 43C High Level through the sample bulkhead. The sample passes a pressure sensor then flows through a capillary and a flow sensor. The sample then flows into the fluorescence chamber, where pulsating UV light excites the SO₂ molecules. The condensing lens focuses the pulsating UV light into the mirror assembly. The mirror assembly contains four selective mirrors that reflect only the wavelengths which excite SO₂ molecules. As the excited SO₂ molecules decay to lower energy states they emit UV light that is proportional to the SO₂ concentration. The bandpass filter allows only the wavelengths emitted by the excited SO₂ molecules to reach the photomultiplier tube (PMT). The PMT detects the UV light emission from the decaying SO₂ molecules. The photodetector, located at the back of the fluorescence chamber, continuously monitors the pulsating UV light source and is connected to a circuit that compensates for fluctuations in the UV light.

The sample then flows to the pump and is exhausted out the exhaust bulkhead of the analyzer. The Model 43C High Level outputs the SO₂ concentration to the front panel display and the analog outputs.

Stack gas was delivered to the analyzer via a Teflon® sampling line, heated to a minimum temperature of 250°F. Excess moisture in the stack gas was removed using a refrigerated

condenser. The entire system was calibrated in accordance with the Method, using certified calibration gases introduced at the probe, before and after each test run.

A list of calibration gases used and the results of all calibration and other required quality assurance checks are found in Appendix G. Copies of the gas cylinder certifications are found in Appendix H. This testing met the performance specifications as outlined in the Method.

Method 7E Nitrogen Oxide (NO_x) Determination

Stack gas NO_x concentrations and emission rates were determined in accordance with USEPA Method 7E, 40CFR60, Appendix A, at the Package Boiler Outlet Duct, Waste Fuel Boiler Outlet Duct, and Recovery Boiler Outlet Duct. A Thermo Scientific Model 42i Chemiluminescence Nitrogen Oxides Analyzer was used to determine nitrogen oxides concentrations, in the manner specified in the Method. The instrument operated in the nominal range of 0 ppm to 500 ppm with the specific range determined by the high-level span calibration gas of 300.5 ppm.

The Model 42i operates on the principle that nitric oxide (NO) and ozone (O₃) react to produce a characteristic luminescence with an intensity linearly proportional to the NO concentration. Infrared light emission results when electronically excited NO₂ molecules decay to lower energy states. Specifically,



Nitrogen dioxide (NO₂) must first be transformed into NO before it can be measured using the chemiluminescent reaction. NO₂ is converted to NO by a molybdenum NO₂-to-NO converter heated to about 205°C. The flue gas sample is drawn into the Model 42i through the sample bulkhead. The sample flows through a capillary, and then to the mode solenoid valve. The solenoid valve routes the sample either straight to the reaction chamber (NO mode) or through the NO₂-to-NO converter and then to the reaction chamber (NO_x mode). A flow sensor prior to the reaction chamber measures the sample flow. Dry air enters the Model 42i through the dry air bulkhead, passes through a flow switch, and then through a silent discharge ozonator. The ozonator generates the ozone needed for the chemiluminescent reaction. At the reaction chamber, the ozone reacts with the NO in the sample to produce excited NO₂ molecules. A photomultiplier tube (PMT) housed in a thermoelectric cooler detects the luminescence generated during this reaction. From the reaction chamber, the exhaust travels through the ozone (O₃) converter to the pump, and is released through the vent.

The NO and NO_x concentrations calculated in the NO and NO_x modes are stored in memory. The difference between the concentrations is used to calculate the NO₂ concentration. The Model 42i outputs NO, NO₂, and NO_x concentrations to the front panel display, the analog outputs, and also makes the data available over the serial or ethernet connection.

Stack gas was delivered to the analyzer via a Teflon® sampling line, heated to a minimum temperature of 250°F. Excess moisture in the stack gas was removed using a refrigerated condenser. The entire system was calibrated in accordance with the Method, using certified calibration gases introduced at the probe, before and after each test run. This testing met the performance specifications as outlined in the Method.

A list of calibration gases used and the results of all calibration and other required quality assurance checks are found in Appendix G. Copies of the gas cylinder certifications are found in Appendix H. The NO₂ to NO converter tests can be found in Appendix I. This testing met the performance specifications as outlined in the Method.

Method 10 Carbon Monoxide (CO) Determination

Stack gas CO concentrations and emission rates were determined in accordance with USEPA Method 10, 40CFR60, Appendix A at the Package Boiler Outlet Duct and Recovery Boiler Outlet Duct. A Fischer Scientific Model 48C Gas Filter Correlation Carbon Monoxide was used to determine carbon monoxide concentrations, in the manner specified in the Method. The instrument operated in the nominal range of 0 ppm to 500 ppm or 1,000 ppm with the specific range determined by the high-level span calibration gas of 173.5 ppm and 920.9 ppm.

The Model 48C High Level is based on the principle that CO absorbs infrared radiation at a wavelength of 4.6 microns. Because infrared absorption is a nonlinear measurement technique, it is necessary for the instrument electronics to transform the basic analyzer signal into a linear output. The Model 48C High Level uses an exact calibration curve to accurately linearize the instrument output over any range up to a concentration of 20,000 ppm. The sample is drawn into the analyzer through the sample bulkhead. The sample flows through the optical bench. Radiation from an infrared source is chopped and then passed through a gas filter alternating between CO and N₂. The radiation then passes through a narrow bandpass interference filter and enters the optical bench where absorption by the sample gas occurs. The infrared radiation then exits the optical bench and falls on an infrared detector. The CO gas filter acts to produce a reference beam which cannot be further attenuated by CO in the sample cell. The N₂ side of the filter wheel is transparent to the infrared radiation and therefore produces a measure beam which can be absorbed by CO in the cell. The chopped detector signal is modulated by the alternation between the two gas filters with an amplitude related to the concentration of CO in the sample cell. Other gases do not cause modulation of the detector signal since they absorb the reference and measure beams equally. Thus, the GFC system responds specifically to CO. The Model 48C High Level outputs the CO concentration to the front panel display and the analog outputs.

Stack gas was delivered to the analyzer via a Teflon® sampling line, heated to a minimum temperature of 250°F. Excess moisture in the stack gas was removed using a refrigerated condenser. The entire system was calibrated in accordance with the Method, using certified calibration gases introduced at the probe, before and after each test run.

A list of calibration gases used and the results of all calibration and other required quality assurance checks are found in Appendix G. Copies of the gas cylinder certifications are found in Appendix H. This testing met the performance specifications as outlined in the Method.

Method 16C Total Reduced Sulfur (TRS) Determination

Integrated gas samples were extracted from the Lime Kiln and Recovery Boiler Outlet Duct gas streams in accordance with Method 16C (SO₂ Monitor), 40CFR60, for the determination of total reduced sulfur (TRS) emissions from stationary sources. This method selectively removed sulfur dioxide (SO₂) by bubbling the gas sample through a citrate buffer solution, then thermally oxidizing TRS compounds present to SO₂. A portion of the gas stream was conveyed to the gas analyzer for determination of SO₂ content. Prior to sampling, the SO₂ analyzer was zeroed and calibrated with high-range, mid-range, and zero gases. After each test run, zero and mid-range calibration gases were introduced to check calibration.

Interferences caused by particulate matter entering the sampling train were eliminated by the use of a heated filter medium placed at the end of the heated Teflon®-lined (or glass-lined) probe.

Prior to field sampling, an optional 30-minute system performance test was performed to validate the sampling train components and procedure. The checks involved sampling a known concentration of hydrogen sulfide (H₂S) and comparing the analyzed concentration with the known concentration. The H₂S recovery gas was mixed with combustion gas in a dilution system. The flowrates were adjusted to generate an H₂S concentration in the range of the stack gas. The samples were collected and analyzed in the same manner as a normal stack test. The sample was collected through the end of the probe to ensure extraction of a representative sample. System validations were performed following each one-hour test in the same manner as the system performance test.

A list of calibration gases used and the results of all calibration and other required quality assurance checks can be found in Appendix G. Copies of calibration gas certifications can be found in Appendix H.

3.0 TEST RESULT SUMMARIES

Client: Billerud Quinnesec, LLC					Location: Package Boiler Outlet Duct			
Facility: Quinnesec Mill					Date: 5/21/24			
Project #: M242110					Test Method: 7E, 3A			
Fuel Type: Natural Gas					Fuel Factor: 8710			
O2 based NOx lb/mmBtu RATA								
CEM Analyzer Information								
NO _x Monitor/Model:			Thermo 42iQ		NO _x Serial # :		1180090011	
O2 Monitor/Model:			Thermo CTL902C		O2 Serial # :		1180390002	
1=accept 0=reject	Test Run	Test Date	Start Time	End Time	RM NO _x lb/MMBtu	CEM NO _x lb/MMBtu	(RM-CEM) Difference (di)	(RM-CEM) Difference ² (di ²)
1	1	05/21/24	08:35	08:55	0.05	0.04	0.01	0.0001
1	2	05/21/24	09:07	09:27	0.05	0.05	0.00	0.0000
1	3	05/21/24	09:35	09:55	0.05	0.05	0.00	0.0000
0	4	05/21/24	10:04	10:24	0.05	0.04	0.01	0.0001
1	5	05/21/24	10:34	10:54	0.05	0.05	0.00	0.0000
1	6	05/21/24	11:04	11:24	0.05	0.05	0.00	0.0000
1	7	05/21/24	11:34	11:54	0.05	0.05	0.00	0.0000
1	8	05/21/24	12:04	12:24	0.05	0.05	0.00	0.0000
1	9	05/21/24	12:34	12:54	0.05	0.05	0.00	0.0000
1	10	05/21/24	13:06	13:26	0.05	0.05	0.00	0.0000
n					9			
t(0.975)					2.306			
Mean Reference Method Value					0.050		RM avg	
Mean CEM Value					0.049		CEM avg	
Sum of Differences					0.010		di	
Mean Difference					0.001		d	
Sum of Differences Squared					0.000		di ²	
Standard Deviation					0.003		sd	
Confidence Coefficient 2.5% Error (1-tail)					0.003		cc	
Relative Accuracy					7.35		RA	

Client: Billerud Quinnesec, LLC					Location: Package Boiler Outlet Duct			
Facility: Quinnesec Mill					Date: 5/21/24			
Project #: M242110					Test Method: 7E, 2			
Applicable Standard: 41.9								
NO _x lb/hr RATA								
CEM Analyzer Information								
NO _x Monitor/Model:			Thermo 42iQ		NO _x Serial # :		1180090011	
1=accept 0=reject	Test Run	Test Date	Start Time	End Time	RM NO _x lb/hr	CEM NO _x lb/hr	(RM-CEM) Difference (di)	(RM-CEM) Difference ² (di ²)
1	1	05/21/24	08:35	08:55	7.66	7.48	0.18	0.0324
1	2	05/21/24	09:07	09:27	7.74	7.52	0.22	0.0484
1	3	05/21/24	09:35	09:55	7.81	7.54	0.27	0.0729
0	4	05/21/24	10:04	10:24	7.85	7.51	0.34	0.1156
1	5	05/21/24	10:34	10:54	7.79	7.57	0.22	0.0484
1	6	05/21/24	11:04	11:24	7.79	7.55	0.24	0.0576
1	7	05/21/24	11:34	11:54	7.86	7.59	0.27	0.0729
1	8	05/21/24	12:04	12:24	7.84	7.57	0.27	0.0729
1	9	05/21/24	12:34	12:54	7.79	7.55	0.24	0.0576
1	10	05/21/24	13:06	13:26	7.83	7.56	0.27	0.0729
n					9			
t(0.975)					2.306			
Mean Reference Method Value					7.790		RM avg	
Mean CEM Value					7.548		CEM avg	
Sum of Differences					2.180		di	
Mean Difference					0.242		d	
Sum of Differences Squared					0.536		di ²	
Standard Deviation					0.032		sd	
Confidence Coefficient 2.5% Error (1-tail)					0.024		cc	
Relative Accuracy					3.42		RA	

Client: Billerud Quinnesec, LLC					Location: Package Boiler Outlet Duct			
Facility: Quinnesec Mill					Date: 5/21/24			
Project #: M242110					Test Method: 3A			
O ₂ % (dry) RATA								
CEM Analyzer Information								
O ₂ Monitor/Model:			Thermo CTL902C		O ₂ Serial # :		1180390002	
1=accept 0=reject	Test Run	Test Date	Start Time	End Time	RM O ₂ % (dry)	CEM O ₂ % (dry)	(RM-CEM) Difference (di)	(RM-CEM) Difference ² (di ²)
1	1	05/21/24	08:35	08:55	3.8	3.8	0.0	0.00
1	2	05/21/24	09:07	09:27	3.9	4.0	-0.1	0.01
1	3	05/21/24	09:35	09:55	4.2	4.1	0.1	0.01
1	4	05/21/24	10:04	10:24	4.0	4.0	0.0	0.00
1	5	05/21/24	10:34	10:54	4.1	4.1	0.0	0.00
1	6	05/21/24	11:04	11:24	4.3	4.3	0.0	0.00
1	7	05/21/24	11:34	11:54	3.9	4.0	-0.1	0.01
0	8	05/21/24	12:04	12:24	3.9	4.0	-0.1	0.01
1	9	05/21/24	12:34	12:54	4.0	4.1	-0.1	0.01
1	10	05/21/24	13:06	13:26	4.0	4.0	0.0	0.00
n					9			
t(0.975)					2.306			
Mean Reference Method Value					4.022		RM avg	
Mean CEM Value					4.044		CEM avg	
Sum of Differences					-0.200		di	
Mean Difference					-0.022		d	
Sum of Differences Squared					0.040		di ²	
Standard Deviation					0.067		sd	
Confidence Coefficient 2.5% Error (1-tail)					0.051		cc	
Relative Accuracy					1.83		RA	

Client: Billerud Quinnesec, LLC					Location: Package Boiler Outlet Duct			
Facility: Quinnesec Mill					Date: 5/21/24			
Project #: M242110					Test Method: 10, 3A			
Fuel Type: Natural Gas					Fuel Factor: 8710			
Applicable Standard: 0.12								
O2 based CO lb/mmBtu RATA								
CEM Analyzer Information								
CO Monitor/Model:			Thermo 48iQ		CO Serial # :		1180930081	
O2 Monitor/Model:			Thermo CTL902C		O2 Serial # :		1180390002	
1=accept 0=reject	Test Run	Test Date	Start Time	End Time	RM CO lb/MMBtu	CEM CO lb/MMBtu	(RM-CEM) Difference (di)	(RM-CEM) Difference ² (di ²)
1	1	05/21/24	08:35	08:55	0.01	0.01	0.00	0.000000
1	2	05/21/24	09:07	09:27	0.00	0.01	-0.01	0.000100
1	3	05/21/24	09:35	09:55	0.00	0.00	0.00	0.000000
1	4	05/21/24	10:04	10:24	0.00	0.00	0.00	0.000000
1	5	05/21/24	10:34	10:54	0.00	0.00	0.00	0.000000
1	6	05/21/24	11:04	11:24	0.00	0.00	0.00	0.000000
1	7	05/21/24	11:34	11:54	0.01	0.01	0.00	0.000000
0	8	05/21/24	12:04	12:24	0.00	0.01	-0.01	0.000100
1	9	05/21/24	12:34	12:54	0.01	0.01	0.00	0.000000
1	10	05/21/24	13:06	13:26	0.01	0.01	0.00	0.000000
n					9			
t(0.975)					2.306			
Mean Reference Method Value					0.004		RM avg	
Mean CEM Value					0.006		CEM avg	
Sum of Differences					-0.010		di	
Mean Difference					-0.001		d	
Sum of Differences Squared					0.000		di ²	
Standard Deviation					0.003		sd	
Confidence Coefficient 2.5% Error (1-tail)					0.003		cc	
Relative Accuracy - APS					3.06		RA	

^A Relative accuracy based upon +/- 5% of applicable standard

Client: Billerud Quinnesec, LLC					Location: Package Boiler Outlet Duct			
Facility: Quinnesec Mill					Date: 5/21/24			
Project #: M242110					Test Method: 10			
Applicable Standard: 195								
CO ppmvd RATA								
CEM Analyzer Information								
CO Monitor/Model:			Thermo 48iQ		CO Serial # :		1180930081	
1=accept 0=reject	Test Run	Test Date	Start Time	End Time	RM CO ppmvd	CEM CO ppmvd	(RM-CEM) Difference (di)	(RM-CEM) Difference ² (di ²)
1	1	05/21/24	08:35	08:55	10.4	13.6	-3.2	10.24
1	2	05/21/24	09:07	09:27	6.3	9.1	-2.8	7.84
1	3	05/21/24	09:35	09:55	2.9	5.4	-2.5	6.25
1	4	05/21/24	10:04	10:24	4.8	7.6	-2.8	7.84
1	5	05/21/24	10:34	10:54	3.3	6.0	-2.7	7.29
1	6	05/21/24	11:04	11:24	2.5	5.2	-2.7	7.29
0	7	05/21/24	11:34	11:54	9.3	13.0	-3.7	13.69
1	8	05/21/24	12:04	12:24	5.6	8.9	-3.3	10.89
1	9	05/21/24	12:34	12:54	8.2	10.8	-2.6	6.76
1	10	05/21/24	13:06	13:26	6.4	9.9	-3.5	12.25
n					9			
t(0.975)					2.306			
Mean Reference Method Value					5.600		RM avg	
Mean CEM Value					8.500		CEM avg	
Sum of Differences					-26.100		di	
Mean Difference					-2.900		d	
Sum of Differences Squared					76.650		di ²	
Standard Deviation					0.346		sd	
Confidence Coefficient 2.5% Error (1-tail)					0.266		cc	
Relative Accuracy - APS					3.17		ppm + cc difference ^A	

^A Relative accuracy based upon alternate performance standard of +/- 5 ppm CO plus the confidence coefficient.

Client: Billerud Quinnesec, LLC					Location: Package Boiler Outlet Duct			
Facility: Quinnesec Mill					Date: 5/21/24			
Project #: M242110					Test Method: 10, 2			
Applicable Standard: 25.5								
CO lb/hr RATA								
CEM Analyzer Information								
CO Monitor/Model:			Thermo 48iQ		CO Serial # :		1180930081	
1=accept 0=reject	Test Run	Test Date	Start Time	End Time	RM CO lb/hr	CEM CO lb/hr	(RM-CEM) Difference (di)	(RM-CEM) Difference ² (di ²)
1	1	05/21/24	08:35	08:55	1.4	1.8	-0.4	0.16
1	2	05/21/24	09:07	09:27	0.8	1.2	-0.4	0.16
1	3	05/21/24	09:35	09:55	0.4	0.7	-0.3	0.09
1	4	05/21/24	10:04	10:24	0.6	1.0	-0.4	0.16
1	5	05/21/24	10:34	10:54	0.4	0.8	-0.4	0.16
1	6	05/21/24	11:04	11:24	0.3	0.7	-0.4	0.16
1	7	05/21/24	11:34	11:54	1.2	1.7	-0.5	0.25
0	8	05/21/24	12:04	12:24	0.7	1.2	-0.5	0.25
1	9	05/21/24	12:34	12:54	1.1	1.4	-0.3	0.09
1	10	05/21/24	13:06	13:26	0.8	1.3	-0.5	0.25
n					9			
t(0.975)					2.306			
Mean Reference Method Value					0.778		RM avg	
Mean CEM Value					1.178		CEM avg	
Sum of Differences					-3.600		di	
Mean Difference					-0.400		d	
Sum of Differences Squared					1.480		di ²	
Standard Deviation					0.071		sd	
Confidence Coefficient 2.5% Error (1-tail)					0.054		cc	
Relative Accuracy - APS					1.78		RA	

^A Relative accuracy based upon +/- 5% of applicable standard

Client: Billerud Quinnesec, LLC					Location: Waste Fuel boiler Outlet Duct			
Facility: Quinnesec Mill					Date: 5/23/24			
Project #: M242110					Test Method: 7E, 3A			
Fuel Type: Other					Fuel Factor: 9518			
O2 based NOx lb/mmBtu RATA								
CEM Analyzer Information								
NO _x Monitor/Model:			Thermo 42iQ		NO _x Serial # :		1180030057	
O2 Monitor/Model:			Thermo CTL902C		O2 Serial # :		1180530001	
1=accept 0=reject	Test Run	Test Date	Start Time	End Time	RM NO _x lb/MMBtu	CEM NO _x lb/MMBtu	(RM-CEM) Difference (di)	(RM-CEM) Difference ² (di ²)
1	1	05/23/24	08:15	08:35	0.19	0.20	-0.01	0.0001
1	2	05/23/24	08:58	09:18	0.18	0.19	-0.01	0.0001
0	3	05/23/24	09:40	10:00	0.13	0.14	-0.01	0.0001
1	4	05/23/24	10:20	10:40	0.19	0.19	0.00	0.0000
1	5	05/23/24	11:00	11:20	0.18	0.18	0.00	0.0000
1	6	05/23/24	11:38	11:58	0.18	0.19	-0.01	0.0001
1	7	05/23/24	12:17	12:37	0.17	0.18	-0.01	0.0001
1	8	05/23/24	12:56	13:16	0.18	0.19	-0.01	0.0001
1	9	05/23/24	13:34	13:54	0.17	0.18	-0.01	0.0001
1	10	05/23/24	14:12	14:32	0.19	0.20	-0.01	0.0001
n					9			
t(0.975)					2.306			
Mean Reference Method Value					0.181		RM avg	
Mean CEM Value					0.189		CEM avg	
Sum of Differences					-0.070		di	
Mean Difference					-0.008		d	
Sum of Differences Squared					0.001		di ²	
Standard Deviation					0.004		sd	
Confidence Coefficient 2.5% Error (1-tail)					0.003		cc	
Relative Accuracy					6.17		RA	

Client: Billerud Quinnesec, LLC					Location: Waste Fuel boiler Outlet Duct			
Facility: Quinnesec Mill					Date: 5/23/24			
Project #: M242110					Test Method: 7E, 2			
Applicable Standard: 437								
NO _x lb/hr RATA								
CEM Analyzer Information								
NO _x Monitor/Model:			Thermo 42iQ		NO _x Serial # :		1180030057	
1=accept 0=reject	Test Run	Test Date	Start Time	End Time	RM NO _x lb/hr	CEM NO _x lb/hr	(RM-CEM) Difference (di)	(RM-CEM) Difference ² (di ²)
1	1	05/23/24	08:15	08:35	83.2	72.9	10.3	106.09
1	2	05/23/24	08:58	09:18	75.0	65.6	9.4	88.36
1	3	05/23/24	09:40	10:00	60.7	54.1	6.6	43.56
1	4	05/23/24	10:20	10:40	80.7	73.0	7.7	59.29
0	5	05/23/24	11:00	11:20	77.6	66.2	11.4	129.96
1	6	05/23/24	11:38	11:58	70.2	66.2	4.0	16.00
1	7	05/23/24	12:17	12:37	76.5	67.7	8.8	77.44
1	8	05/23/24	12:56	13:16	75.5	68.3	7.2	51.84
1	9	05/23/24	13:34	13:54	71.5	66.6	4.9	24.01
1	10	05/23/24	14:12	14:32	76.6	68.6	8.0	64.00
n					9			
t(0.975)					2.306			
Mean Reference Method Value					74.433		RM avg	
Mean CEM Value					67.000		CEM avg	
Sum of Differences					66.900		di	
Mean Difference					7.433		d	
Sum of Differences Squared					530.590		di ²	
Standard Deviation					2.040		sd	
Confidence Coefficient 2.5% Error (1-tail)					1.568		cc	
Relative Accuracy					12.09		RA	

Client: Billerud Quinnesec, LLC					Location: Waste Fuel boiler Outlet Duct			
Facility: Quinnesec Mill					Date: 5/23/24			
Project #: M242110					Test Method: 3A			
CO ₂ % (dry) RATA								
CEM Analyzer Information								
1=accept 0=reject	Test Run	Test Date	Start Time	End Time	RM CO ₂ % (dry)	CEM CO ₂ % (dry)	(RM-CEM) Difference (di)	(RM-CEM) Difference ² (di ²)
1	1	05/23/24	08:15	08:35	13.0	13.0	0.0	0.00
0	2	05/23/24	08:58	09:18	13.1	13.0	0.1	0.01
1	3	05/23/24	09:40	10:00	14.5	14.6	-0.1	0.01
1	4	05/23/24	10:20	10:40	13.4	13.4	0.0	0.00
1	5	05/23/24	11:00	11:20	13.5	13.5	0.0	0.00
1	6	05/23/24	11:38	11:58	12.8	12.8	0.0	0.00
1	7	05/23/24	12:17	12:37	13.6	13.6	0.0	0.00
1	8	05/23/24	12:56	13:16	13.6	13.5	0.1	0.01
1	9	05/23/24	13:34	13:54	13.9	13.8	0.1	0.01
1	10	05/23/24	14:12	14:32	13.2	13.1	0.1	0.01
n					9			
t(0.975)					2.306			
Mean Reference Method Value					13.500		RM avg	
Mean CEM Value					13.478		CEM avg	
Sum of Differences					0.200		di	
Mean Difference					0.022		d	
Sum of Differences Squared					0.040		di ²	
Standard Deviation					0.067		sd	
Confidence Coefficient 2.5% Error (1-tail)					0.051		cc	
Relative Accuracy					0.54		RA	

Client: Billerud Quinnesec, LLC					Location: Waste Fuel boiler Outlet Duct			
Facility: Quinnesec Mill					Date: 5/23/24			
Project #: M242110					Test Method: 3A			
O ₂ % (dry) RATA								
CEM Analyzer Information								
O ₂ Monitor/Model:			Thermo CTL902C		O ₂ Serial # :		1180530001	
1=accept 0=reject	Test Run	Test Date	Start Time	End Time	RM O ₂ % (dry)	CEM O ₂ % (dry)	(RM-CEM) Difference (di)	(RM-CEM) Difference ² (di ²)
0	1	05/23/24	08:15	08:35	7.1	7.4	-0.3	0.09
1	2	05/23/24	08:58	09:18	7.1	7.3	-0.2	0.04
1	3	05/23/24	09:40	10:00	5.5	5.7	-0.2	0.04
1	4	05/23/24	10:20	10:40	6.7	6.9	-0.2	0.04
1	5	05/23/24	11:00	11:20	6.6	6.8	-0.2	0.04
1	6	05/23/24	11:38	11:58	7.4	7.6	-0.2	0.04
1	7	05/23/24	12:17	12:37	6.5	6.7	-0.2	0.04
1	8	05/23/24	12:56	13:16	6.6	6.8	-0.2	0.04
1	9	05/23/24	13:34	13:54	6.3	6.5	-0.2	0.04
1	10	05/23/24	14:12	14:32	7.0	7.2	-0.2	0.04
n					9			
t(0.975)					2.306			
Mean Reference Method Value					6.633		RM avg	
Mean CEM Value					6.833		CEM avg	
Sum of Differences					-1.800		di	
Mean Difference					-0.200		d	
Sum of Differences Squared					0.360		di ²	
Standard Deviation					0.000		sd	
Confidence Coefficient 2.5% Error (1-tail)					0.000		cc	
Relative Accuracy					3.02		RA	

Client: Billerud Quinnesec, LLC					Location: Waste Fuel boiler Outlet Duct			
Facility: Quinnesec Mill					Date: 5/23/24			
Project #: M242110					Test Method: 6C, 3A			
Fuel Type: Other					Fuel Factor: 9518			
Applicable Standard: 1.2								
O2 based SO2 lb/mmBtu RATA								
CEM Analyzer Information								
SO ₂ Monitor/Model:			Thermo 43iQ		SO ₂ Serial # :		1180930080	
O2 Monitor/Model:			Thermo CTL902C		O2 Serial # :		1180530001	
1=accept 0=reject	Test Run	Test Date	Start Time	End Time	RM SO ₂ lb/MMBtu	CEM SO ₂ lb/MMBtu	(RM-CEM) Difference (di)	(RM-CEM) Difference ² (di ²)
1	1	05/23/24	08:15	08:35	0.0	0.0	0.0	0.000
1	2	05/23/24	08:58	09:18	0.0	0.0	0.0	0.000
1	3	05/23/24	09:40	10:00	0.0	0.0	0.0	0.000
1	4	05/23/24	10:20	10:40	0.0	0.0	0.0	0.000
1	5	05/23/24	11:00	11:20	0.0	0.0	0.0	0.000
1	6	05/23/24	11:38	11:58	0.0	0.0	0.0	0.000
0	7	05/23/24	12:17	12:37	0.1	0.0	0.1	0.010
1	8	05/23/24	12:56	13:16	0.0	0.0	0.0	0.000
1	9	05/23/24	13:34	13:54	0.1	0.1	0.0	0.000
1	10	05/23/24	14:12	14:32	0.0	0.0	0.0	0.000
n					9			
t(0.975)					2.306			
Mean Reference Method Value					0.011		RM avg	
Mean CEM Value					0.011		CEM avg	
Sum of Differences					0.000		di	
Mean Difference					0.000		d	
Sum of Differences Squared					0.000		di ²	
Standard Deviation					0.000		sd	
Confidence Coefficient 2.5% Error (1-tail)					0.000		cc	
Relative Accuracy					0.00		RA	

Client: Billerud Quinnesec, LLC					Location: Waste Fuel boiler Outlet Duct			
Facility: Quinnesec Mill					Date: 5/23/24			
Project #: M242110					Test Method: 6C, 2			
Applicable Standard: 476								
SO2 lb/hr RATA								
CEM Analyzer Information								
SO2 Monitor/Model:			Thermo 43iQ		SO2 Serial # :		1180930080	
1=accept 0=reject	Test Run	Test Date	Start Time	End Time	RM SO2 lb/hr	CEM SO2 lb/hr	(RM-CEM) Difference (di)	(RM-CEM) Difference ² (di ²)
1	1	05/23/24	08:15	08:35	3.5	1.9	1.6	2.56
1	2	05/23/24	08:58	09:18	2.4	0.4	2.0	4.00
1	3	05/23/24	09:40	10:00	3.7	6.1	-2.4	5.76
1	4	05/23/24	10:20	10:40	5.0	6.5	-1.5	2.25
1	5	05/23/24	11:00	11:20	3.3	2.1	1.2	1.44
1	6	05/23/24	11:38	11:58	4.6	3.1	1.5	2.25
0	7	05/23/24	12:17	12:37	26.2	18.7	7.5	56.25
1	8	05/23/24	12:56	13:16	20.5	19.5	1.0	1.00
1	9	05/23/24	13:34	13:54	42.8	39.3	3.5	12.25
1	10	05/23/24	14:12	14:32	6.7	4.5	2.2	4.84
n					9			
t(0.975)					2.306			
Mean Reference Method Value					10.278		RM avg	
Mean CEM Value					9.267		CEM avg	
Sum of Differences					9.100		di	
Mean Difference					1.011		d	
Sum of Differences Squared					36.350		di ²	
Standard Deviation					1.842		sd	
Confidence Coefficient 2.5% Error (1-tail)					1.416		cc	
Relative Accuracy - APS					0.51		RA ^A	

^A Relative accuracy based upon +/- 10% of applicable standard of 476 lb/hr

Client: Billeruid Quinnesec, LLC					Test Location: Waste Fuel Boiler Outlet Duct			
Facility: Quinnesec Mill					Test Date: 5/23/2024			
Project #: M242110					Test Method: 2			
Volumetric Flow RATA - Normal Load								
CEM Analyzer Information								
Flow Monitor/Model:			Deterich		Flow Serial # :		22-F-C-179,274797.01.1	
1=accept 0=reject	Test Run	Test Date	Start Time	End Time	Reference Method Flow DSCFM	CEM Flow DSCFM	(RM-CEM) Difference (di)	(RM-CEM) Difference ² (di ²)
1	1	05/23/24	8:15	8:35	104,865	89,326	15,539	241,460,521
0	2	05/23/24	8:58	9:18	100,194	85,299	14,895	221,861,025
1	3	05/23/24	9:40	10:00	98,896	85,945	12,951	167,728,401
1	4	05/23/24	10:20	10:40	101,138	90,514	10,624	112,869,376
1	5	05/23/24	11:00	11:20	100,878	84,678	16,200	262,440,000
1	6	05/23/24	11:38	11:58	94,453	86,534	7,919	62,710,561
1	7	05/23/24	12:17	12:37	102,319	88,482	13,837	191,462,569
1	8	05/23/24	12:56	13:16	97,719	86,591	11,128	123,832,384
1	9	05/23/24	13:34	13:54	94,153	85,942	8,211	67,420,521
1	10	05/23/24	14:12	14:32	97,539	86,091	11,448	131,056,704
n					9			
t(0.975)					2.306			
Mean Reference Method Value					99106.667		RM avg	
Mean CEM Value					87122.556		CEM avg	
Sum of Differences					107857.000		di	
Mean Difference					11984.111		d	
Sum of Differences Squared					1360981037.000		di ²	
Standard Deviation					2924.268		sd	
Confidence Coefficient 2.5% Error (1-tail)					2247.788		cc	
Relative Accuracy					14.36		RA	

Client: Billerud Quinnesec, LLC					Location: Recovery Boiler Outlet Duct			
Facility: Quinnesec Mill					Date: 5/22/24			
Project #: M242110					Test Method: 7E, 3A			
Applicable Standard: 110								
NOx ppmvd @ 8% O2 RATA								
CEM Analyzer Information								
NO _x Monitor/Model:			Thermo 42iQ		NO _x Serial # :		1180090013	
O ₂ Monitor/Model:			Thermo CTL902C		O ₂ Serial # :		1180240002	
1=accept 0=reject	Test Run	Test Date	Start Time	End Time	RM NOx ppmvd @ 8 %O2	CEM NOx ppmvd @ 8 %O2	(RM-CEM) Difference (di)	(RM-CEM) Difference ² (di ²)
1	1	05/22/24	09:35	09:55	83.5	81.4	2.1	4.41
1	2	05/22/24	10:18	10:38	83.7	80.7	3.0	9.00
1	3	05/22/24	11:02	11:22	87.4	84.3	3.1	9.61
1	4	05/22/24	11:46	12:06	83.0	80.5	2.5	6.25
1	5	05/22/24	12:32	12:52	83.8	81.5	2.3	5.29
1	6	05/22/24	13:14	13:34	77.0	74.6	2.4	5.76
0	7	05/22/24	13:56	14:16	78.9	75.9	3.0	9.00
1	8	05/22/24	14:38	14:58	85.4	82.5	2.9	8.41
1	9	05/22/24	15:18	15:38	86.7	84.2	2.5	6.25
1	10	05/22/24	15:58	16:18	87.8	85.2	2.6	6.76
n					9			
t(0.975)					2.306			
Mean Reference Method Value					84.256		RM avg	
Mean CEM Value					81.656		CEM avg	
Sum of Differences					23.400		di	
Mean Difference					2.600		d	
Sum of Differences Squared					61.740		di ²	
Standard Deviation					0.335		sd	
Confidence Coefficient 2.5% Error (1-tail)					0.258		cc	
Relative Accuracy					3.39		RA	

Client: Billerud Quinnesec, LLC					Location: Recovery Boiler Outlet Duct			
Facility: Quinnesec Mill					Date: 5/22/24			
Project #: M242110					Test Method: 3A			
O ₂ % (dry) RATA								
CEM Analyzer Information								
O ₂ Monitor/Model:			Thermo CTL902C		O ₂ Serial # :		1180240002	
1=accept 0=reject	Test Run	Test Date	Start Time	End Time	RM O ₂ % (dry)	CEM O ₂ % (dry)	(RM-CEM) Difference (di)	(RM-CEM) Difference ² (di ²)
1	1	05/22/24	09:35	09:55	5.2	5.4	-0.2	0.04
1	2	05/22/24	10:18	10:38	5.3	5.5	-0.2	0.04
1	3	05/22/24	11:02	11:22	5.3	5.6	-0.3	0.09
1	4	05/22/24	11:46	12:06	5.5	5.8	-0.3	0.09
1	5	05/22/24	12:32	12:52	5.3	5.6	-0.3	0.09
1	6	05/22/24	13:14	13:34	4.8	5.1	-0.3	0.09
0	7	05/22/24	13:56	14:16	4.6	4.9	-0.3	0.09
1	8	05/22/24	14:38	14:58	4.8	5.1	-0.3	0.09
1	9	05/22/24	15:18	15:38	5.0	5.3	-0.3	0.09
1	10	05/22/24	15:58	16:18	4.9	5.2	-0.3	0.09
n					9			
t(0.975)					2.306			
Mean Reference Method Value					5.122		RM avg	
Mean CEM Value					5.400		CEM avg	
Sum of Differences					-2.500		di	
Mean Difference					-0.278		d	
Sum of Differences Squared					0.710		di ²	
Standard Deviation					0.044		sd	
Confidence Coefficient 2.5% Error (1-tail)					0.034		cc	
Relative Accuracy					6.08		RA	

Client: Billerud Quinnesec, LLC Facility: Quinnesec Mill Project #: M242110					Location: Recovery Boiler Outlet Duct Date: 5/22/24 Test Method: 6C, 3A Applicable Standard: 50 SO2 ppmvd @ 8% O2 RATA CEM Analyzer Information			
SO₂ Monitor/Model:		Thermo 43iQ		SO₂ Serial # :		1180090009		
O₂ Monitor/Model:		Thermo CTL902C		O₂ Serial # :		1180240002		
1=accept 0=reject	Test Run	Test Date	Start Time	End Time	RM SO2 ppmvd @ 8 %O2	CEM SO2 ppmvd @ 8 %O2	(RM-CEM) Difference (di)	(RM-CEM) Difference ² (di ²)
1	1	05/22/24	09:35	09:55	0.4	0.7	-0.3	0.09
1	2	05/22/24	10:18	10:38	1.0	0.6	0.4	0.16
1	3	05/22/24	11:02	11:22	0.1	0.6	-0.5	0.25
1	4	05/22/24	11:46	12:06	0.7	0.5	0.2	0.04
1	5	05/22/24	12:32	12:52	0.9	0.5	0.4	0.16
0	6	05/22/24	13:14	13:34	2.0	0.5	1.5	2.25
1	7	05/22/24	13:56	14:16	1.5	0.5	1.0	1.00
1	8	05/22/24	14:38	14:58	0.5	0.6	-0.1	0.01
1	9	05/22/24	15:18	15:38	0.4	0.6	-0.2	0.04
1	10	05/22/24	15:58	16:18	0.4	0.6	-0.2	0.04
n					9			
t(0.975)					2.306			
Mean Reference Method Value					0.656		RM avg	
Mean CEM Value					0.578		CEM avg	
Sum of Differences					0.700		di	
Mean Difference					0.078		d	
Sum of Differences Squared					1.790		di²	
Standard Deviation					0.466		sd	
Confidence Coefficient 2.5% Error (1-tail)					0.358		cc	
Relative Accuracy - APS					0.87		RA^A	

^A Relative accuracy based upon +/- 10% of applicable standard of 50 ppmvd @ 8% O₂

Client: Billerud Quinnesec, LLC					Location: Recovery Boiler Outlet Duct			
Facility: Quinnesec Mill					Date: 5/22/24			
Project #: M242110					Test Method: 10, 3A			
Applicable Standard: 425								
CO ppmvd @ 8% O2 RATA								
CEM Analyzer Information								
CO Monitor/Model:			Thermo 48iQ		CO Serial # :		11706800002	
O ₂ Monitor/Model:			Thermo CTL902C		O ₂ Serial # :		1180240002	
1=accept 0=reject	Test Run	Test Date	Start Time	End Time	RM CO ppmvd @ 8 %O2	CEM CO ppmvd @ 8 %O2	(RM-CEM) Difference (di)	(RM-CEM) Difference ² (di ²)
1	1	05/22/24	09:35	09:55	5.4	2.9	2.5	6.25
1	2	05/22/24	10:18	10:38	35.6	33.5	2.1	4.41
1	3	05/22/24	11:02	11:22	22.9	15.7	7.2	51.84
1	4	05/22/24	11:46	12:06	22.4	18.6	3.8	14.44
1	5	05/22/24	12:32	12:52	16.7	18.0	-1.3	1.69
1	6	05/22/24	13:14	13:34	99.1	99.2	-0.1	0.01
1	7	05/22/24	13:56	14:16	73.8	75.2	-1.4	1.96
1	8	05/22/24	14:38	14:58	10.1	6.0	4.1	16.81
1	9	05/22/24	15:18	15:38	25.0	17.7	7.3	53.29
0	10	05/22/24	15:58	16:18	14.1	6.7	7.4	54.76
n					9			
t(0.975)					2.306			
Mean Reference Method Value					34.556		RM avg	
Mean CEM Value					31.867		CEM avg	
Sum of Differences					24.200		di	
Mean Difference					2.689		d	
Sum of Differences Squared					150.700		di ²	
Standard Deviation					3.272		sd	
Confidence Coefficient 2.5% Error (1-tail)					2.515		cc	
Relative Accuracy - APS					1.22		RA	

^A Relative accuracy based upon +/- 5% of applicable standard of 425 ppmvd @ 8% O₂

Client: Billerud Quinnesec, LLC

Facility: Quinnesec Mill

Project #: M242110

Location: Recovery Boiler Outlet Duct

Date: 5/22 and 5/23

Test Method: 16C, 3A

Applicable Standard: 10

TRS as SO2 ppmvd @ 8% O2 RATA

CEM Analyzer Information

TRS Monitor/Model:			Thermo 43iQ		TRS Serial # :		1180090014	
O ₂ Monitor/Model:			Thermo CTL902C		O ₂ Serial # :		1180240002	
1=accept 0=reject	Test Run	Test Date	Start Time	End Time	RM TRS as SO2 ppmvd @ 8 %O2	CEM TRS ppmvd @ 8 %O2	(RM-CEM) Difference (di)	(RM-CEM) Difference ² (di ²)
1	1	05/22/24	12:32	12:52	1.0	1.0	0.0	0.00
1	2	05/22/24	13:14	13:34	1.3	1.1	0.2	0.04
1	3	05/22/24	13:56	14:16	0.8	1.0	-0.2	0.04
1	4	05/22/24	15:18	15:38	1.1	1.1	0.0	0.00
1	5	05/22/24	15:58	16:18	1.2	1.2	0.0	0.00
1	6	05/22/24	16:36	16:56	1.2	1.2	0.0	0.00
1	7	05/23/24	08:19	08:39	0.8	0.7	0.1	0.01
1	8	05/23/24	09:06	09:26	0.7	0.6	0.1	0.01
1	9	05/23/24	09:52	10:12	0.8	0.9	-0.1	0.01
n					9			
t(0.975)					2.306			
Mean Reference Method Value					0.989		RM avg	
Mean CEM Value					0.978		CEM avg	
Sum of Differences					0.100		di	
Mean Difference					0.011		d	
Sum of Differences Squared					0.110		di ²	
Standard Deviation					0.117		sd	
Confidence Coefficient 2.5% Error (1-tail)					0.090		cc	
Relative Accuracy					10.19		RA	

Client: Billerud Quinnesec, LLC Facility: Quinnesec Mill Project #: M242110					Test Location: Recovery Boiler Outlet Duct Test Date: 5/22/2024 Test Method: 2 Volumetric Flow RATA - Normal Load CEM Analyzer Information			
Flow Monitor/Model: OSI-OFS 2000W					Flow Serial # :		15110807E	
1=accept 0=reject	Test Run	Test Date	Start Time	End Time	Reference Method Flow DSCFM	CEM Flow DSCFM	(RM-CEM) Difference (di)	(RM-CEM) Difference ² (di ²)
1	1	05/22/24	9:00	9:25	185,457	186,915	-1,458	2,126,931
1	2	05/22/24	9:27	9:35	186,597	186,799	-202	40,925
1	3	05/22/24	10:10	10:15	188,452	186,177	2,275	5,173,350
1	4	05/22/24	10:16	10:26	188,828	186,481	2,347	5,508,878
1	5	05/22/24	10:30	10:40	189,003	186,833	2,170	4,708,900
0	6	05/22/24	11:30	11:36	192,755	187,152	5,603	31,393,609
1	7	05/22/24	11:37	11:47	191,713	187,631	4,082	16,658,642
1	8	05/22/24	11:48	11:58	193,134	187,791	5,343	28,548,718
1	9	05/22/24	12:30	12:40	189,301	187,597	1,704	2,902,253
1	10	05/22/24	12:45	12:55	186,188	188,094	-1,906	3,632,836
n					9			
t(0.975)					2.306			
Mean Reference Method Value					188741.233		RM avg	
Mean CEM Value					187146.444		CEM avg	
Sum of Differences					14353.100		di	
Mean Difference					1594.789		d	
Sum of Differences Squared					69301433.330		di ²	
Standard Deviation					2408.611		sd	
Confidence Coefficient 2.5% Error (1-tail)					1851.419		cc	
Relative Accuracy					1.83		RA	

Client: Billerud Quinnesec, LLC					Location: Lime Kiln			
Facility: Quinnesec Mill					Date: 5/21/24			
Project #: M242110					Test Method: 16C, 3A			
Applicable Standard: 10								
TRS as SO2 ppmvd @ 10% O2 RATA								
CEM Analyzer Information								
TRS Monitor/Model:			Thermo 43iQ		TRS Serial # :		1180090014	
1=accept 0=reject	Test Run	Test Date	Start Time	End Time	RM TRS as SO2 ppmvd @ 10 %O2	CEM TRS ppmvd @ 10 %O2	(RM-CEM) Difference (di)	(RM-CEM) Difference ² (di ²)
1	1	05/21/24	09:29	09:49	2.4	2.3	0.1	0.01
1	2	05/21/24	10:43	11:03	1.4	1.1	0.3	0.09
1	3	05/21/24	11:22	11:42	1.2	1.1	0.1	0.01
1	4	05/21/24	12:29	12:49	1.1	1.3	-0.2	0.04
1	5	05/21/24	13:27	13:47	1.1	1.1	0.0	0.00
1	6	05/21/24	14:08	14:28	1.3	1.2	0.1	0.01
1	7	05/21/24	15:11	15:31	1.6	1.5	0.1	0.01
1	8	05/21/24	15:58	16:18	1.7	1.4	0.3	0.09
1	9	05/21/24	16:37	16:57	1.1	1.2	-0.1	0.01
n					9			
t(0.975)					2.306			
Mean Reference Method Value					1.433		RM avg	
Mean CEM Value					1.356		CEM avg	
Sum of Differences					0.700		di	
Mean Difference					0.078		d	
Sum of Differences Squared					0.270		di ²	
Standard Deviation					0.164		sd	
Confidence Coefficient 2.5% Error (1-tail)					0.126		cc	
Relative Accuracy					14.23		RA	


Client: Billerud Quinnesec, LLC					Location: Lime Kiln			
Facility: Quinnesec Mill					Date: 5/21/24			
Project #: M242110					Test Method: 3A			
O ₂ % (dry) RATA								
CEM Analyzer Information								
O ₂ Monitor/Model:			Thrmo CTL902C		O ₂ Serial # :		1180570001	
1=accept 0=reject	Test Run	Test Date	Start Time	End Time	RM O ₂ % (dry)	CEM O ₂ % (dry)	(RM-CEM) Difference (di)	(RM-CEM) Difference ² (di ²)
1	1	05/21/24	09:29	09:49	2.83	3.24	-0.41	0.17
1	2	05/21/24	10:43	11:03	4.45	4.52	-0.07	0.00
1	3	05/21/24	11:22	11:42	4.21	4.57	-0.36	0.13
1	4	05/21/24	12:29	12:49	3.68	4.10	-0.42	0.18
1	5	05/21/24	13:27	13:47	4.40	4.50	-0.10	0.01
1	6	05/21/24	14:08	14:28	4.09	4.22	-0.13	0.02
1	7	05/21/24	15:11	15:31	3.40	3.65	-0.25	0.06
1	8	05/21/24	15:58	16:18	4.00	4.33	-0.33	0.11
1	9	05/21/24	16:37	16:57	4.60	4.52	0.08	0.01
n					9			
t(0.975)					2.306			
Mean Reference Method Value					3.962		RM avg	
Mean CEM Value					4.183		CEM avg	
Sum of Differences					-1.990		di	
Mean Difference					-0.221		d	
Sum of Differences Squared					0.684		di ²	
Standard Deviation					0.175		sd	
Confidence Coefficient 2.5% Error (1-tail)					0.134		cc	
Relative Accuracy					8.97		RA	

4.0 CERTIFICATION

Mostardi Platt is pleased to have been of service to Billerud Quinnesec, LLC. If you have any questions regarding this test report, please do not hesitate to contact us at 630-993-2100.


As project manager, I hereby certify that this test report represents a true and accurate summary of emissions test results and the methodologies employed to obtain those results, and the test program was performed in accordance with the methods specified in this test report.

MOSTARDI PLATT



Christopher E. Jensen

Program Manager




Scott W. Banach

Quality Assurance

APPENDICES

Appendix A - Test Section Diagrams

THREE POINT GASEOUS TRAVERSE FOR RECTANGULAR DUCTS



Job: Billerud Quinnesec LLC
Quinnesec, Michigan

Date: May 21, 2024

Test Location: Package Boiler Duct

Length: 5.5 Feet

Width: 7.5 Feet

Area: 41.25 Square Feet

Upstream Distance: ~75 Feet

Downstream Distance: ~40 Feet


No. Test Ports: 1

Tests Points per Port: 3

Distance from Inside Wall
To Traverse Point:

1. 2.0 Meters
2. 1.2 Meters
3. 0.4 Meters

EQUAL AREA TRAVERSE FOR RECTANGULAR DUCTS



Job: Billerud Quinnesec LLC
Quinnesec, Michigan

Date: May 23, 2024

Test Location: Waste Fuel Boiler Duct

Length: 10 Feet


Width: 7 Feet

Area: 70 Square Feet

No. Test Ports: 3

Tests Points per Port: 6

THREE POINT GASEOUS TRAVERSE FOR RECTANGULAR DUCTS



Job: Billerud Quinnesec LLC
Quinnesec, Michigan

Date: May 23, 2024

Test Location: Waste Fuel Boiler Duct

Length: 10 Feet

Width: 7 Feet

Area: 70 Square Feet

Upstream Distance: ~100 Feet

Downstream Distance: ~20 Feet


No. Test Ports: 1

Tests Points per Port: 3

Distance from Inside Wall
To Traverse Point:

1. 2.0 Meters
2. 1.2 Meters
3. 0.4 Meters

EQUAL AREA TRAVERSE
FOR RECTANGULAR DUCTS



Job: Billerud Quinnesec LLC
Quinnesec, Michigan

Date: May 22 and 23, 2024

Test Location: Recovery Boiler Duct

Length: 12.25 Feet


Width: 8 Feet

Area: 98 Square Feet

No. Test Ports: 3

Tests Points per Port: 6

THREE POINT GASEOUS TRAVERSE FOR RECTANGULAR DUCTS



Job: Billerud Quinnesec LLC
Quinnesec, Michigan

Date: May 22 and 23, 2024

Test Location: Recovery Boiler Duct

Length: 12.25 Feet

Width: 8 Feet

Area: 98 Square Feet

Upstream Distance: ~90 Feet

Downstream Distance: ~25 Feet



No. Test Ports: 1

Tests Points per Port: 3

Distance from Inside Wall
To Traverse Point:

1. 2.0 Meters
2. 1.2 Meters
3. 0.4 Meters

THREE POINT GASEOUS TRAVERSE FOR ROUND DUCTS



Job: Billerud Quinnesec LLC
Quinnesec, Michigan

Date: May 21, 2024

Test Location: Lime Kiln Stack

Stack Diameter: 8.0 Feet

Stack Area: 50.265 Square Feet

No. Sample Points: 3

Upstream Disturbance: ~75 Feet

Downstream Disturbance ~40 Feet

Distance from Inside Wall
To Traverse Point:

1. 2.0 Meters
2. 1.2 Meters
3. 0.4 Meters