

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION
ACTIVITY REPORT: Off-site Inspection

F418156688

FACILITY: MARQUETTE GENERAL HOSPITAL		SRN / ID: F4181
LOCATION: 420 W MAGNETIC ST, MARQUETTE		DISTRICT: Marquette
CITY: MARQUETTE		COUNTY: MARQUETTE
CONTACT: Cheryl Bollero-Oberstar , Director of Maintenance		ACTIVITY DATE: 09/18/2020
STAFF: Joe Scanlan	COMPLIANCE STATUS: Compliance	SOURCE CLASS: MINOR
SUBJECT: Update on status of emission units located at the former UP Health Systems hospital campus		
RESOLVED COMPLAINTS:		

UP Health System Marquette (UPHS-Marquette) relocated its operations from its W. College Ave. location to its brand-new hospital located at 850 W. Baraga Ave. on Sunday, June 2, 2019. Because the new facility does not have any emission units that require permitting an Unregistered Facility id was assigned (U522100181).

UPHS is maintaining the former hospital campus on College Avenue for some of its medical offices and is hoping to lease the remaining portion of the structure. All the existing emission units, and permits (if applicable) are listed below and are still being operated and maintained.

PTI#189-82 was issued for the 3 identical Kewanee Scotch Generator boilers, model HS-500-G02, fired by natural gas utilizing #2 fuel oil as backup. Boilers 1 & 2 were installed in 1967 and Boiler 3 was installed in 1980.

The 4 compression-ignition emergency generators are exempt from permitting.

- 1. Cummins Onan Generator (750 kW; manufactured 2005)**
- 2. Cummins Onan Generator (750 kW; manufactured 1991)**
- 3. Caterpillar 3412 (750 kW; manufactured 2002)**
- 4. Cummins Standby Generator (300 kW; manufactured 1976)**

NAME 

DATE 01/29/2021

SUPERVISOR 