

DEPARTMENT OF ENVIRONMENTAL QUALITY

AIR QUALITY DIVISION

FCE Summary Report

Facility : WILLIAM BEAUMONT HOSPITAL	SRN : G5067
Location : 3601 W. 13 MILE RD.	District : Warren
	County : OAKLAND
City : ROYAL OAK State: MI Zip Code : 48073	Compliance Status : Compliance
Source Class : MAJOR	Staff : Shamim Ahammod
FCE Begin Date : 7/18/2022	FCE Completion Date : 7/17/2023
Comments : Full Compliance Evaluation.	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
04/20/2023	NSPS (Part 60)	Compliance	Semi-Annual Fuel Oil Report. October 6, 2022-Portable Generator #1 Tank - 300 gallons October 6, 2022-Portable Generator #2 Tank - 300 gallons
04/20/2023	MAERS	Compliance	2022 MAERS Report Certification.
04/20/2023	ROP Other	Compliance	Notification of EU-ELECGEN3R and EU-ELECGEN4R Engine Commencement of Trial Operation. Trial Operation started on 2/27/2023, and notified AQD by March 6, 2023.
04/20/2023	ROP Annual Cert	Compliance	No deviations reported.
04/20/2023	ROP SEMI 2 CERT	Compliance	No deviations reported.
02/23/2023	On-site Inspection	Compliance	Conducted full compliance evaluation(FCE).
12/02/2022	ROP Semi 1 Cert	Compliance	Semi-Annual Report. Review complete. No deviations reported. The report includes information specified in Rule 213(4)(c)(i) through (v) and certification by the authorized representative.
07/21/2022	ROP SEMI 2 CERT	Compliance	No deviations reported. The report includes information specified in Rule 213(4)(c)(i) through (v) and a certification by the responsible official.

Activity Date	Activity Type	Compliance Status	Comments
07/21/2022	ROP Annual Cert	Compliance	No deviations reported. The report includes information specified in Rule 213(4)(c)(i) through (v) and a certification by the responsible official.
07/20/2022	NSPS (Part 60)	Compliance	Semi-Annual Fuel Oil Report required in 40 CFR 60.48c(d) and (e) (FG-FUELOIL SC VII.4). Beaumont reported no fuel oil was received during the reporting period and the sulfur content of the fuel oil combusted during the reporting period was provided in a previous report. The previous report stated the maximum sulfur content was 15 ppm.

Name: Shamim Ahammod Date: 7/17/2023

Supervisor: *K. Kelly*