

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION
ACTIVITY REPORT: Self Initiated Inspection

N079630408

FACILITY: Jilbert Dairy Inc.		SRN / ID: N0796
LOCATION: 200 Meeske Avenue, MARQUETTE		DISTRICT: Upper Peninsula
CITY: MARQUETTE		COUNTY: MARQUETTE
CONTACT: Bela Sandor , Operations Manager		ACTIVITY DATE: 07/31/2015
STAFF: Ed Lancaster	COMPLIANCE STATUS: Compliance	SOURCE CLASS:
SUBJECT: Self-initiated inspection, facility has an active permit, but no records of inspection being conducted.		
RESOLVED COMPLAINTS:		

On July 31, 2015, I arrived at the Jilbert Dairy facility and met with Mr. Bela Sandor, Operations Manager, to conduct an unannounced inspection, of the company's 100 hp Keweenaw wood-fired boiler (PTI No 265-84A).

Mr. Sandor informed me the wood-fired boiler was dismantled approximately 2 years ago and had not been used in the 8-years he has been working for Jilbert's. Mr. Sandor then escorted me to the boiler house where I observed the wood-fired boiler and the two natural gas-fired, 50 hp (1.67 MMBtu/hr) replacement boilers.

The natural gas-fired boilers are exempt from the requirement to obtain a permit to install per Rule 282 (b)(i) (i.e. they are less than 50 MMBtu/hr) and due to their size (less than 10 MMBTU/hr) are not subject to the Federal New Source Performance Standard Subpart Dc.

At the time of the inspection the company is in compliance with air pollution control rules. Due to the facility being a true minor source follow-up inspections are not required as long as they continue to operate as they were on the day of the inspection.

I will request PTI No. 265-84A be voided as the equipment was dismantled.

NAME Ed Lancaster DATE 7/31/15 SUPERVISOR _____