

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION

FCE Summary Report

Facility : Sebewaing Light and Water Dept.	SRN : N2726
Location : 350 Pine Street	District : Saginaw Bay
	County : HURON
City : SEBEWAING State: MI Zip Code : 48759	Compliance Status : Compliance
Source Class : SM OPT OUT	Staff : Matthew Karl
FCE Begin Date : 3/30/2018	FCE Completion Date : 8/29/2019
Comments : FCE report. The facility has not completed construction at this time. PTI No. 146-17 covers the two new engines that will be installed at the Pine Street address.	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
08/14/2019	Scheduled Inspection	Compliance	Scheduled inspection to determine compliance with PTI No. 146-17.
12/20/2018	Malfunction Abatement Plan	Compliance	Updated Malfunction Abatement Plan for Pine Street Facility, Two Natural Gas Fired Engines, dated October 2018.
07/11/2018	Malfunction Abatement Plan	Unknown	MAP for two natural gas fired engines required under PTI 146-17. Plan was submitted to meet the requirement that a MAP be submitted within 90 days of permit issuance. Plan was not approved due to lack of specific monitoring parameter ranges. Expect a new MAP to be submitted once engines are installed.

Name: Matthew K. Karl Date: 8/29/19 Supervisor: C. Kone