



RICK SNYDER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF ENVIRONMENTAL QUALITY  
CADILLAC DISTRICT OFFICE



DAN WYANT  
DIRECTOR

August 21, 2014

Mr. Joseph Kuckinski  
DCP Midstream  
3026 4<sup>th</sup> Avenue  
Greeley, Colorado 80631

SRN: N2940, Otsego County

Dear Mr. Kuckinski:

**VIOLATION NOTICE**

On July 24, 2014, the Department of Environmental Quality (DEQ), Air Quality Division (AQD), received a testing report for the South Chester Antrim CO<sub>2</sub> Removal Facility located at 6250 Old State Road, Johannesburg, Michigan. This testing is required by Renewable Operating Permit Number MI-ROP-N2940-2009a and was performed in May and June of 2014.

Review of the results of this testing demonstrate that actual emissions of carbon monoxide (CO) from EUP5TUR01 were 2.6 pounds per hour. The conditions of ROP Number Mi-ROP-N2940-2009a limit emissions of CO from EUP5TUR01 to 2.3 pounds per hour.

Please initiate actions necessary to correct the cited violation and submit a written response to this Violation Notice by September 11, 2014 (which coincides with 21 calendar days from the date of this letter). The written response should include; the dates the violation occurred; and explanation of the causes and duration of the violation; whether the violation is ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violation and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

If DCP Midstream believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violation cited above. If you have any questions regarding the violation or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,

Shane Nixon  
Senior Environmental Engineer  
Air Quality Division  
231-876-4413

cc: Mr. David Bennett, DCP Midstream  
cc/via email: Ms. Lynn Fiedler, DEQ  
Ms. Teresa Seidel, DEQ  
Mr. Thomas Hess, DEQ