



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
KALAMAZOO DISTRICT OFFICE



PHILLIP D. ROOS
DIRECTOR

August 31, 2023

Dustin Enright
ANR Pipeline Company - Hamilton Compressor Station
23677 230th Avenue
Elridge, Iowa, 52748

SRN: N5574, Allegan County

Dear Dustin Enright:

VIOLATION NOTICE

On June 26, 2023, the Department of Environment, Great Lakes, and Energy (EGLE), Air Quality Division (AQD), conducted an inspection of ANR Pipeline Company - Hamilton Compressor Station located at 4193 134th Avenue, Hamilton, Michigan. The purpose of this inspection was to determine ANR Pipeline Company - Hamilton Compressor Station's compliance with the requirements of the federal Clean Air Act; Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (Act 451); the Air Pollution Control Rules; and

-- the conditions of Permit to Install (PTI) number 98-20;

During the inspection, staff observed the following:

| Process Description | Rule/Permit Condition Violated | Comments |
|---------------------|--------------------------------|--|
| EUHM017 | Special Condition VIII.1 | Staff observed the exhaust stack discharging horizontally instead of vertically upward as stated in the permit |

Please initiate actions necessary to correct the cited violation and submit a written response to this Violation Notice by September 21, 2023 (which coincides with 21 calendar days from the date of this letter). The written response should include: the dates the violation occurred; an explanation of the causes and duration of the violation; whether the violation is ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violation and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

Please submit the written response to Cody Yazzie at EGLE, AQD, Kalamazoo District, at 7953 Adobe Road, Kalamazoo, Michigan 49009 or YazzieC@michigan.gov and submit a copy to Jenine Camilleri, Enforcement Unit Supervisor at EGLE, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760.

Dustin Enright
ANR Pipeline Company - Hamilton Compressor Station
Page 2
August 31, 2023

If ANR Pipeline Company - Hamilton Compressor Station believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violation cited above and for the cooperation that was extended to me during my inspection of ANR Pipeline Company - Hamilton Compressor Station. If you have any questions regarding the violation or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,

A handwritten signature in black ink that reads "Cody Yazzie". The signature is written in a cursive, slightly slanted style.

Cody Yazzie
Environmental Engineer
Air Quality Division
269-312-2754

cc: Annette Switzer, EGLE
Christopher Ethridge, EGLE
Brad Myott, EGLE
Jenine Camilleri, EGLE
Monica Brothers, EGLE