

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION
ACTIVITY REPORT: Scheduled Inspection

N660333733

FACILITY: CITY OF CHELSEA		SRN / ID: N6603
LOCATION: 660 E INDUSTRIAL DRIVE, CHELSEA		DISTRICT: Jackson
CITY: CHELSEA		COUNTY: WASHTENAW
CONTACT:		ACTIVITY DATE: 03/15/2016
STAFF: Brian Carley	COMPLIANCE STATUS: Compliance	SOURCE CLASS: SM OPT OUT
SUBJECT: Scheduled inspection		
RESOLVED COMPLAINTS:		

Facility contact: Chuck Stevens, Electric Operations Supervisor
Phone: 734-475-1771
Email: cstevens@city-chelsea.org

Zack Durham and I arrived at the facility and met with Chuck Stevens, Electric Operations Supervisor, Chelsea Light and Power. The facility has three 2,000 HP compression ignition engines. Chuck told me that they did not operate at all in 2015. They have installed catalytic converters on the engines to comply with the RICE MACT. Chuck told us that they have not run the engines at all this year except for about 10 minutes. He told us that before they run the engines again, they have lines that go to the engines on the ground that they need to either bury or elevate off the ground. He then took us out to where the engines were located and to show us what needs to be done before they start operating the engines later this year. Based on the information from their 2015 MAERS (EI YR 2014) submittal and this inspection, I determined that they are in compliance. I thanked Chuck for his time and left.

NAME Brian CarleyDATE 3/14/16SUPERVISOR [Signature]