



RICK SNYDER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF ENVIRONMENTAL QUALITY  
GRAND RAPIDS DISTRICT OFFICE



C. HEIDI GREYHER  
DIRECTOR

October 5, 2016

Mr. Deron Kippen  
Michigan Department of Corrections - Muskegon Complex  
2400 South Sheridan Drive  
Muskegon, Michigan 49442

SRN: P0625, Muskegon County

Dear Mr. Kippen

**VIOLATION NOTICE**

On August 17 & September 9, 2016, the Department of Environmental Quality (DEQ), Air Quality Division (AQD), conducted an inspection of the Michigan Department of Corrections (MDOC) Muskegon Complex located at 2400 South Sheridan Drive, Muskegon, Michigan. The purpose of this inspection was to determine MDOC Muskegon Complex's compliance with the requirements of the federal Clean Air Act; Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (Act 451); the Air Pollution Control Rules; the conditions of Permit to Install (PTI) No. 133-15; and Consent Order No. AQD 13-2016.

During the inspection, staff observed the following:

Process Description	Rule/Permit Condition Violated	Comments
FG-EMGGENS	PTI No. 133-15, Special Condition 11.2;  Consent Order No. AQD 13-2016, Paragraph 9.B	The site utilized fuel oil containing a sulfur content of 0.14%, which is in exceedance of the limit established for fuel oil sulfur content (0.05%).

Please initiate actions necessary to correct the cited violation and submit a written response to this Violation Notice by October 26, 2016 (which coincides with 21 calendar days from the date of this letter). The written response should include: the dates the violation occurred; an explanation of the causes and duration of the violation; whether the violation is ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violation and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

Mr. Deron Kippen  
MDCO Muskegon Complex  
Page 2  
October 5, 2016

If MDOC Muskegon Complex believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violation cited above and for the cooperation that was extended to me during our inspection of the MDOC Muskegon Complex. If you have any questions regarding the violation, or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,

A handwritten signature in black ink, appearing to read "S.J. Lachance", with a long horizontal flourish extending to the right.

Stephen J. Lachance  
Environmental Quality Specialist  
Air Quality Division  
616-356-0239

cc: Ms. Heidi Hollenbach, DEQ  
cc/via e-mail: Ms. Lynn Fiedler, DEQ  
Ms. Mary Ann Dolehanty, DEQ  
Mr. Chris Ethridge, DEQ  
Mr. Thomas Hess, DEQ