

P1491  
MANUA-FCE

DEPARTMENT OF ENVIRONMENTAL QUALITY

AIR QUALITY DIVISION

FCE Summary Report

<b>Facility :</b> Norplas Industries, Inc.	<b>SRN :</b> P1491
<b>Location :</b> 12800 Oakland Parkway	<b>District :</b> Detroit
	<b>County :</b> WAYNE
<b>City :</b> HIGHLAND PARK <b>State:</b> MI <b>Zip Code :</b> 48203	<b>Compliance Status :</b> Non Compliance
<b>Source Class :</b> SM OPT OUT	<b>Staff :</b> Diana Serban
<b>FCE Begin Date :</b> 9/1/2023	<b>FCE Completion Date :</b> 8/9/2024
<b>Comments :</b> During the self-initiated inspection, it was determined the facility has been operating two emergency generators subject to air permitting requirements without a permit	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
08/09/2024	On-site Inspection	Non Compliance	FY 24 Onsite Inspection

Name:

D. Serban

Date:

10/23/24

Supervisor:

JK