




June 26, 2019

Department of Environment, Great Lakes and Energy
State of Michigan - Kalamazoo District Office
Air Quality Division
Attn: Monica Brothers
7953 Adobe Road
Kalamazoo, MI 49009-5025



Re: Violation Notice Dated 6/21/19 for Complaint on June 20, 2019

Dear Ms. Brothers

Below is our response to the foul order complaint addressed in the above referenced Violation Notice at our facility on June 20, 2109 (copy enclosed).

Explanation: Upon our inspection of the scrubber system, it was determined that a sensor had failed and automatically shut the scrubber system down. Due to the existing scrubber system design we were not aware that the system had failed and ceased operation. We surmise the scrubber system may have not been operational for no more than 24 hours. The replacement sensor was ordered that afternoon on June 20th and installed June 21st. The scrubber system is back up and fully operational.

Steps Taken to Prevent Recurrence: To prevent a future problem should this sensor fail again; we have installed an alarm monitor on the system control panel that will alert us immediately in the event of any failure within the system.

Clean Earth Environmental takes these violations very seriously and immediately took steps to remedy the problem. Should you have any further questions, please feel free to contact me at 269-381-2400.

Sincerely,

A handwritten signature in blue ink, appearing to read "Dale W. Hubbard".

Dale W. Hubbard
President

DWH:nan

cc: Ms. Jenine Camilleri

Enclosure: Copy of Violation Notice