



GRETCHEN WHITMER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF ENVIRONMENTAL QUALITY  
UPPER PENINSULA DISTRICT OFFICE



LIESL EICHLER CLARK  
DIRECTOR

March 26, 2019

Mr. Dan Skewis, Superintendent  
Negaunee Public Schools  
101 South Pioneer Street  
Negaunee, Michigan 49866

Mr. Brian Frustaglio  
G.E. Builders, Inc  
848 Camelot Drive  
Negaunee, Michigan 49866

SRN: U521903390, Marquette County

Dear Superintendent Skewis and Mr. Frustaglio:

**VIOLATION NOTICE**

On March 21, 2019, the Department of Environmental Quality (DEQ), Air Quality Division (AQD), conducted an inspection of the Negaunee Public Schools Bus Garage located at the intersection of Highway US-41 and Snowfield Road, Negaunee, Michigan. The purpose of this inspection was to determine compliance with the requirements of Title 40 of the Code of Federal Regulations (CFR), Part 61, National Emission Standards for Hazardous Air Pollutants (NESHAP), Subpart M and Rule 942 of the administrative rules promulgated under Part 55, Air Pollution Control of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended.

According to our investigation, Negaunee Public Schools owns the facility and G.E. Builders, Inc., performed the demolition activities at the facility. The NESHAP for Asbestos holds both the owner and operator equally liable for violations.

During the inspection, staff observed the following:

Process Description	Section Violated	Comments
Building suffered from roof collapse due to snow load; debris was removed without notification to DEQ or thorough asbestos inspection	40 CFR 61.145(b)(1)	Failure to provide 10 working day notification.
	40 CFR 61.145(b)(4)(vi)	Failure to estimate the amount of Regulated Asbestos-Containing Material (RACM)

Mr. Dan Skewis  
Mr. Brian Frustaglio

2

March 26, 2019


Please initiate actions necessary to correct the cited violations and submit a signed written response to this Violation Notice by April 15, 2019 (which coincides with 21 calendar days from the date of this letter). The response should include: the dates the violation occurred; an explanation of the causes and duration of the violation; whether the violation is ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violation and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

Please submit the written response to Mr. Joseph Scanlan at DEQ, AQD, 1504 West Washington Street, Marquette, Michigan 49855 or scanlanj@michigan.gov and submit a copy to Mr. Jason Wolf, Enforcement Unit at DEQ, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760 or WOLFJ2@michigan.gov.

If Negaunee Public Schools or G.E. Builders, Inc., believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide factual information to explain your position.

Thank you for your attention to resolving the violations cited above. If you have any questions regarding the violations or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,



Joseph Scanlan  
Upper Peninsula District  
Air Quality Division  
906-458-6405

cc: Ms. Mary Ann Dolehanty, DEQ  
Dr. Eduardo Olaguer, DEQ  
Mr. Christopher Ethridge, DEQ  
Ms. Jenine Camilleri, DEQ  
Ms. Karen Kajiya-Mills, DEQ  
Mr. Jason Wolf, DEQ  
Mr. Ed Lancaster, DEQ