



GRETCHEN WHITMER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF  
ENVIRONMENT, GREAT LAKES, AND ENERGY  
DETROIT DISTRICT OFFICE



LIESL EICHLER CLARK  
DIRECTOR

April 15, 2020

Mr. Paul Schwartz  
Servpro of Saginaw  
470 Adams St.  
Saginaw, MI 48604

Mr. Steve Waligora  
Belle Tire Distributors, Inc  
1000 Enterprise Drive  
Allen Park, MI 48101

SRN: U822001281, Oakland County

Dear Sirs:

**VIOLATION NOTICE**

On March 31, 2020, the Department of Environment, Great Lakes, and Energy (EGLE), Air Quality Division (AQD), conducted an inspection of the Belle Tire located at 1650 W Maple, Troy. The purpose of this inspection was to determine compliance with the requirements of Title 40 of the Code of Federal Regulations (CFR), Part 61, National Emission Standards for Hazardous Air Pollutants (NESHAP), Subpart M and Rule 942 of the administrative rules promulgated under Part 55, Air Pollution Control of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended.

According to our investigation, Belle Tire Distributors, Inc. owns the facility and Servpro performed the partial demolition activities at the facility. The NESHAP for Asbestos holds both the owner and operator equally liable for violations.

On March 31, 2020, the AQD noted that the north east side of the building had been demolished. A notice of intent to demolish for partial demolition of the fire damaged structure had not been submitted to the AQD. The asbestos survey conducted at the site did not include the portion of the building that was demolished; nor were the building materials presumed to contain asbestos if the area was not safe to survey.

Process Description	Section Violated	Comments
Partial demolition of a commercial structure damaged by fire.	40 CFR 61.145(a)	Failure to thoroughly inspect for asbestos.
	40 CFR 61.145(b)(1)	Failure to provide the AQD with notice of intention to demolish

Mr. Paul Schwartz  
Mr. Steve Waligora  
Page 2  
April 15, 2020


Please initiate actions necessary to correct the cited violations and submit a signed written response to this Violation Notice by May 6, 2020 (which coincides with 21 calendar days from the date of this letter). The response should include: the dates the violations occurred; an explanation of the causes and duration of the violations; whether the violations are ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violations and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

Please submit the written response to Tammy Bell at EGLE, AQD 3058 West Grand Boulevard, Suite 2-300, Detroit, Michigan 48202 or bellt4@michigan.gov and submit a copy to Mr. Jason Wolf, Enforcement Unit at EGLE, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760 or wolfj2@michigan.gov.

If Servpro and/or Belle Tire Distributors, Inc. believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide factual information to explain your position.

Thank you for your attention to resolving the violations cited above and for the cooperation that was extended to me during my inspection of 1650 W. Maple Road, Troy. If you have any questions regarding the violations or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,



Tammy Bell  
Senior Environmental Quality Analyst  
Air Quality Division  
313-330-0105

Enclosure

cc: Ms. Mary Ann Dolehanty, EGLE  
Dr. Eduardo Olaguer, EGLE  
Ms. Jenine Camilleri, EGLE  
Mr. Christopher Ethridge, EGLE  
Ms. Karen Kajiya-Mills, EGLE  
Mr. Jason Wolf, EGLE  
Ms. Joyce Zhu, EGLE